

DOCKET NO. 60

AN APPLICATION SUBMITTED BY FLAGG : CONNECTICUT SITING
ENERGY DEVELOPMENT CORPORATION FOR A
CERTIFICATE OF ENVIRONMENTAL COMPATIBILITY :
AND PUBLIC NEED FOR THE CONSTRUCTION, : COUNCIL
MAINTENANCE, AND OPERATION OF A 10,000 KW
COGENERATION FACILITY LOCATED IN HARTFORD, :
CONNECTICUT. : May 7, 1986

D E C I S I O N A N D O R D E R

The application submitted by Flagg Energy Development Corporation to construct and operate a cogeneration facility is hereby approved. A Certificate of Environmental Compatibility and Public Need, as provided by section 16-50k of the Connecticut General Statutes (CGS), shall be issued, subject to the following terms, limitations, and conditions. Any changes to specifications pertaining to the following conditions, notice, and report requirements will require Council approval no less than two weeks prior to such changes.

1. Conditions

- a) the facility shall be constructed as proposed in the application, as amended and as detailed in the Council's record;
- b) the construction, operation, and maintenance of the facility shall be in accordance with all applicable federal, state, and municipal laws, regulations, ordinances, codes, and standards;
- c) existing ambient noise levels shall comply with all state and local noise regulations and standards; and
- d) this certificate shall be void if all construction authorized herein is not completed by July, 1988.

2. Notifications

The certificate holder shall provide to the Council two weeks advance notification of the following:

- a) commencement of construction;
- b) commencement of testing; and
- c) commencement of operation.

3. Reports

The certificate holder shall provide to the Council the following reports:

- a) a quarterly progress report, starting with the commencement of construction;
- b) the final approved state air emission permit to operate, when available;
- c) the final National Pollution Discharge Elimination System and state discharge permits, when available; and
- d) documentation of compliance with state noise regulations, due no later than six months after commencement of operation.

Documentation is to be in the form of day and nighttime testing conducted under normal operating conditions no sooner than one month after commencement of operations.

Pursuant to section 16-50p of the CGS, we hereby direct that a copy of the Opinion and Decision and Order shall be served on each person listed below and that a notice of the issuance shall be published in the Hartford Courant.







The parties to this proceeding are:

Mr. Joel M. Canino (its representative)
President
Flagg Energy Development Corporation
One Research Parkway
Meriden, Connecticut 06450-7124

C E R T I F I C A T I O N

The undersigned members of the Connecticut Siting Council hereby certify that they have heard this case or read the record thereof, and that we voted as follows:


Dated at New Britain, Connecticut, this 7th day of May, 1986.

<u>Council Members</u>	<u>Vote Cast</u>
 Gloria Dibble Pond Chairperson	Yes
_____) Commissioner John Downey Designee: Commissioner Peter G. Boucher	Absent
 Commissioner Stanley Pac Designee: Christopher Cooper	Yes
_____) Owen L. Clark	Absent
 Mortimer A. Gelston	Yes
 James G. Horsfall	Yes
_____) Pamela B. Katz	Absent
 William H. Smith	Yes
 Colin C. Tait	Yes

STATE OF CONNECTICUT)
 :
COUNTY OF HARTFORD) ss. New Britain, May 7, 1986

I hereby certify that the foregoing is a true and correct copy of the decision and order issued by the Connecticut Siting Council, State of Connecticut.

ATTEST:



Christopher S. Wood, Executive Director
Connecticut Siting Council