




EM-AT&T-083-140114

atore D. Ianiero

Chestnut Street, Suite 220
Foxboro, MA 02035
Tel (781) 831-1281
Fax (774) 215-5423



Melanie Bachman
Acting Executive Director
Connecticut Siting Counsel
10 Franklin Square
New Britain, CT 06051

Re: **Notice of Exempt Modification - Emergency Backup Generator**
FA#:10035088/ 290 Preston Avenue, Middletown, CT 06457/ Project Code: 2051691655

Dear Ms. Bachman:

American Telephone and Telegraph Company ("AT&T") currently maintains a wireless telecommunications facility at the above referenced address. AT&T's facility consists of antennas at the 150' mark of the existing 150' tower and an existing AT&T equipment shelter. The tower and AT&T's shelter are located within an existing lease area. The shelter houses AT&T's equipment and space for a back-up generator. AT&T does not currently maintain a generator at this cell site.

In an effort to further enhance multiple tenants' network reliability, AT&T intends to modify its facility by installing a new diesel generator outside in a designated 4' x 8' ground space. The generator incorporates a built-in fuel tank as part of the unit. The diesel fuel tanks are double walled for added safety and will be filled by a licensed fuel filling company. The proposed modification will remain within the existing fenced compound within the limits of the existing lease area. The new generator and tank will be surrounded by a security fence and gate. (See Facility Compound Plan attached).

Please accept this letter as notification pursuant to R.C.S.A Section 16-50j-73, for construction that constitutes modification pursuant to R.C.S.A Section 16-50j-72(b)(2). In accordance with R.C.S.A Section 16-50j-73, a copy of this submission is being sent to the Town of Middletown. A copy of this submission is also being sent to Ernest & Brenda Trumpold, the property owners on which the tower is located.


ATCs' Proposed Wireless Modifications Constitutes An "Exempt Modification"

The proposed modification to the above mentioned Facility constitutes an exempt modification of an existing facility provided for in R.C.S.A Section 16-50j-72(b)(2) and Council regulations promulgated pursuant thereto.

- 1) The proposed modification will not result in an increase in the height of the existing tower.
- 2) The generator and attached fuel tank will remain entirely within the limits of the leased area. The modifications therefor, will not require the extension of the boundary.
- 3) The proposed modification does not increase the noise levels at the boundary by six(6) decibels or more under normal conditions. Proposed modification is only used during emergency power failure.
- 4) The installation of a new generator and attached fuel tank will not change, in any way, radio frequency (RF) emissions at the facility.
- 5) The facility has received all municipal zoning approvals and building permits. (Regs., Conn. State Agencies Section 16-50j-72))

For all the foregoing reasons, American Telephone and Telegraph Company respectfully submits that the proposed modifications to the above-referenced telecommunications facility constitutes an exempt modification under R.C.S.A Section 16-50j-72(b)(2)

Respectfully submitted,



Salvatore 401-533-0728

On behalf of American Tower Corporation
c/o Tower Resource Management, Inc.
16 Chestnut Street, Suite 220
Foxboro, MA 02035

cc: **Town of Middletown, CT**
Ernest & Brenda Trumpold

Exhibit 1

Site Plan

ADVANCED ENGINEERING GROUP, P.C.
 Civil Engineering - Site Development
 Surveying - Telecommunications
 1000 WASHINGTON STREET
 SUITE 200
 PROVIDENCE, RI 02914
 PH: 401-354-2493 FAX: 401-333-6554

TRM
 Convergent Network Solutions
 1000 WASHINGTON STREET
 SUITE 200
 PROVIDENCE, RI 02914
 PH: 401-354-2493 FAX: 401-333-6554

at&t
 1000 WASHINGTON STREET
 SUITE 200
 PROVIDENCE, RI 02914
 PH: 401-354-2493 FAX: 401-333-6554

Sabre Industries
 1810 MORRIS ROAD, 6TH FLOOR, SUITE 1
 ALPHARETTA, GA 30004

SITE NUMBER:
10035088

SITE NAME:
MIDDLETOWN SW

SITE ADDRESS:
 280 PRESTON AVENUE
 MIDDLETOWN, CT 06460


STATE OF CONNECTICUT
 WALTER R. CHREFFER
 No. 28307
 LICENSED PROFESSIONAL ENGINEER

W.R. Chreffler

DATE: HERE	
DRAWN BY: CJB	
CHECKED BY: SNA	
DATE DRAWN: 11-22-13	
JOB NO.: 10035088	
SHEET TITLE: COMPOUND PLAN	
SHEET NUMBER: A-1	REV. 1

NOTE:
 SITE VISIT SURVEY WAS NOT CONDUCTED BY ADVANCED ENGINEERING GROUP, P.C. SITE INFORMATION AND PLANS ARE BASED UPON INFORMATION PROVIDED BY CLIENT

CONTRACTOR TO VERIFY EXISTING MUX LOCATION. IF MUX LOCATION IS OUTSIDE OF AT&T EQUIPMENT AREA, CONTRACTOR IS TO FIELD VERIFY MUX LOCATION. CONTRACTOR TO VERIFY MUX LOCATION AND ROUTE NEW SERVICE FROM AT&T EQUIPMENT AREA.



1 COMPOUND PLAN
 SCALE: 1" = 10'
 0 5' 10' 20'

