



May 15, 2017

Melanie A. Bachman  
Executive Director  
Connecticut Siting Council  
10 Franklin Street  
New Britain, CT 06051

Regarding: Notice of Exempt Modification – Swap of 3 Antennas, Addition of (6) TMA's and addition of associated lines  
Property Address: 310 Rowayton Ave, Norwalk, CT (the "Property")  
Applicant: AT&T Mobility ("AT&T" Site: CT5013)

Dear Ms. Bachman:

AT&T currently maintains a wireless telecommunications facility on an existing 95 foot utility tower ("tower") at the above-referenced address, latitude 41.07759444, longitude -73.4426083. AT&T's facility consists of three (3) wireless telecommunications antennas at 103 feet. The tower is controlled and owned by Eversource Energy. Assessor's information is attached hereto.

AT&T desires to modify its existing telecommunications facility by swapping three (3) antennas, adding (6) TMA's, and adding associated lines. The centerline height of said antennas is and will remain at 103 feet.

Please accept this application as notification pursuant to R.C.S.A. § 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. § 16-50j-72 (b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this letter is being sent to the Mayor of the City of Norwalk, the Chief Building Official of the City of Norwalk, and the Director of Planning and Zoning of the City of Norwalk. A copy of this letter is also being sent to Eversource Energy, the owner of the structure that AT&T is located.

The planned modifications to AT&T's facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2).

1. The planned modifications will not result in an increase in the height of the existing structure. AT&T's antennas and associated lines will be installed at 103 foot level of the 95 foot utility tower.
2. The proposed modifications will not involve any changes to ground-mounted equipment and, therefore will not require an extension of the site boundary.
3. The proposed modification will not increase the noise level at the facility by six decibel or more, or to levels that exceed state and local criteria.



4. The operation of the modified facility will not increase radio frequency (RF) emissions at the facility to a level at or above the Federal Communications Commission (FCC) safety standard. An RF emissions calculation is attached.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The tower and its foundation can support AT&T's proposed modifications. (Please see attached Structural analysis completed by Centek Engineering Dated November 22, 2016).

For the foregoing reasons AT&T respectfully requests that the proposed swap of 3 antennas, the addition of (6) TMAs, and addition of associated lines be allowed within the exempt modifications under R.C.S.A. § 16-50j-72(b)(2).


Sincerely,

Nicole Caplan  
Site Acquisition Specialist  
Empire Telecom

CC: The Honorable Harry Rilling, Mayor, City of Norwalk  
William Ireland, Chief Building Official, City of Norwalk  
Steven Kleppin, Director of Planning and Zoning, City of Norwalk  
Eversource Energy, c/o Joel Szarkowicz


16 Esquire Road, Billerica, MA 01862      Phone 978-284-3906      Email: [ncaplan@empiretelecomm.com](mailto:ncaplan@empiretelecomm.com)





0 120 240 480 Feet  
1 inch = 181 feet

### 310 Rowayton Ave







# WIRELESS COMMUNICATIONS FACILITY

## CT5013 - LTE BWE

### NORWALK CT

### EVERSOURCE TOWER NO.: 489S

### 310 ROWAYTON AVE

### NORWALK, CT 06853

#### GENERAL NOTES

1. ALL WORK SHALL BE IN ACCORDANCE WITH THE 2012 INTERNATIONAL BUILDING CODE AS MODIFIED BY THE 2016 CONNECTICUT STATE BUILDING CODE, INCLUDING THE TIA-222 REVISION "G" STRUCTURAL STANDARDS FOR STEEL ANTENNA TOWERS AND SUPPORTING STRUCTURES, 2016 CONNECTICUT FIRE SAFETY CODE AND, NATIONAL ELECTRICAL CODE AND LOCAL CODES.
2. THE COMPOUND, TOWER, PRIMARY GROUND RING, ELECTRICAL SERVICE TO THE METER BANK AND TELEPHONE SERVICE TO THE DEMARCATION POINT ARE PROVIDED BY SITE OWNER. AS BUILT FIELD CONDITIONS REGARDING THESE ITEMS SHALL BE CONFIRMED BY THE CONTRACTOR. SHOULD ANY FIELD CONDITIONS PRECLUDE COMPLIANCE WITH THE DRAWINGS, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE ENGINEER AND SHALL NOT PROCEED WITH ANY AFFECTED WORK.
3. CONTRACTOR SHALL REVIEW ALL DRAWINGS AND SPECIFICATIONS IN THE CONTRACT DOCUMENT SET. CONTRACTOR SHALL COORDINATE ALL WORK SHOWN IN THE SET OF DRAWINGS. THE CONTRACTOR SHALL PROVIDE A COMPLETE SET OF DRAWINGS TO ALL SUBCONTRACTORS AND ALL RELATED PARTIES. THE SUBCONTRACTORS SHALL EXAMINE ALL THE DRAWINGS AND SPECIFICATIONS FOR THE INFORMATION THAT AFFECTS THEIR WORK.
4. CONTRACTOR SHALL PROVIDE A COMPLETE BUILD-OUT WITH ALL FINISHES, STRUCTURAL, MECHANICAL, AND ELECTRICAL COMPONENTS AND PROVIDE ALL ITEMS AS SHOWN OR INDICATED ON THE DRAWINGS OR IN THE WRITTEN SPECIFICATIONS.
5. CONTRACTOR SHALL FURNISH ALL MATERIAL, LABOR AND EQUIPMENT TO COMPLETE THE WORK AND FURNISH A COMPLETED JOB ALL IN ACCORDANCE WITH LOCAL AND STATE GOVERNING AUTHORITIES AND OTHER AUTHORITIES HAVING LAWFUL JURISDICTION OVER THE WORK.
6. CONTRACTOR SHALL SECURE AND PAY FOR ALL PERMITS AND ALL INSPECTIONS REQUIRED AND SHALL ALSO PAY FEES REQUIRED FOR THE GENERAL CONSTRUCTION, PLUMBING, ELECTRICAL AND HVAC. PERMITS SHALL BE PAID FOR BY THE RESPECTIVE SUBCONTRACTORS.
7. CONTRACTOR SHALL MAINTAIN A CURRENT SET OF DRAWINGS AND SPECIFICATIONS ON SITE AT ALL TIMES AND INSURE DISTRIBUTION OF NEW DRAWINGS TO SUBCONTRACTORS AND OTHER RELEVANT PARTIES AS SOON AS THEY ARE MADE AVAILABLE. ALL OLD DRAWINGS SHALL BE MARKED VOID AND REMOVED FROM THE CONTRACT AREA. THE CONTRACTOR SHALL FURNISH AN "AS-BUILT" SET OF DRAWINGS TO OWNER UPON COMPLETION OF PROJECT.
8. LOCATION OF EQUIPMENT, AND WORK SUPPLIED BY OTHERS THAT IS DIAGRAMMATICALLY INDICATED ON THE DRAWINGS SHALL BE DETERMINED BY THE CONTRACTOR. THE CONTRACTOR SHALL DETERMINE LOCATIONS AND DIMENSIONS SUBJECT TO STRUCTURAL CONDITIONS AND WORK OF THE SUBCONTRACTORS.
9. THE CONTRACTOR IS SOLELY RESPONSIBLE TO DETERMINE CONSTRUCTION PROCEDURE AND SEQUENCE, AND TO ENSURE THE SAFETY OF THE EXISTING STRUCTURES AND ITS COMPONENT PARTS DURING CONSTRUCTION. THIS INCLUDES THE ADDITION OF WHATEVER SHORING, BRACING, UNDERPINNING, ETC. THAT MAY BE NECESSARY. MAINTAIN EXISTING BUILDING'S/PROPERTY'S OPERATIONS, COORDINATE WORK WITH BUILDING/PROPERTY OWNER.
10. DRAWINGS INDICATE THE MINIMUM STANDARDS, BUT IF ANY WORK SHOULD BE INDICATED TO BE SUBSTANDARD TO ANY ORDINANCES, LAWS, CODES, RULES, OR REGULATIONS BEARING ON THE WORK, THE CONTRACTOR SHALL INCLUDE IN HIS WORK AND SHALL EXECUTE THE WORK CORRECTLY IN ACCORDANCE WITH SUCH ORDINANCES, LAWS, CODES, RULES OR REGULATIONS WITH NO INCREASE IN COSTS.
11. ALL UTILITY WORK SHALL BE IN ACCORDANCE WITH LOCAL UTILITY COMPANY REQUIREMENTS AND SPECIFICATIONS.
12. ALL EQUIPMENT AND PRODUCTS PURCHASED ARE TO BE REVIEWED BY CONTRACTOR AND ALL APPLICABLE SUBCONTRACTORS FOR ANY CONDITION PER MFR.'S RECOMMENDATIONS. CONTRACTOR TO SUPPLY THESE ITEMS AT NO COST TO OWNER OR CONSTRUCTION MANAGER.
13. ANY AND ALL ERRORS, DISCREPANCIES, AND "MISSED" ITEMS ARE TO BE BROUGHT TO THE ATTENTION OF THE AT&T CONSTRUCTION MANAGER DURING THE BIDDING PROCESS BY THE CONTRACTOR. ALL THESE ITEMS ARE TO BE INCLUDED IN THE BID. NO 'EXTRA' WILL BE ALLOWED FOR MISSED ITEMS.
14. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ON-SITE SAFETY FROM THE TIME THE JOB IS AWARDED UNTIL ALL WORK IS COMPLETE AND ACCEPTED BY THE OWNER.
15. CONTRACTOR TO REVIEW ALL SHOP DRAWINGS AND SUBMIT COPY TO ENGINEER FOR APPROVAL. DRAWINGS MUST BEAR THE CHECKER'S INITIALS BEFORE SUBMITTING TO THE CONSTRUCTION MANAGER FOR REVIEW.
16. THE CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS, ELEVATIONS, ANGLES, AND EXISTING CONDITIONS AT THE SITE, PRIOR TO FABRICATION AND/OR INSTALLATION OF ANY WORK IN THE CONTRACT AREA.
17. COORDINATION, LAYOUT, FURNISHING AND INSTALLATION OF CONDUIT AND ALL APPURTENANCES REQUIRED FOR PROPER INSTALLATION OF ELECTRICAL AND TELECOMMUNICATION SERVICE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR.
18. ALL EQUIPMENT AND PRODUCTS PURCHASED ARE TO BE REVIEWED BY CONTRACTOR AND ALL APPLICABLE SUB-CONTRACTORS FOR ANY CONDITION PER THE MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR TO SUPPLY THESE ITEMS AT NO COST TO OWNER OR CONSTRUCTION MANAGER.
19. ALL DAMAGE CAUSED TO ANY EXISTING STRUCTURE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR. THE CONTRACTOR WILL BE HELD LIABLE FOR ALL REPAIRS REQUIRED FOR EXISTING STRUCTURES IF DAMAGED DURING CONSTRUCTION ACTIVITIES.
20. THE CONTRACTOR SHALL CONTACT "CALL BEFORE YOU DIG" AT LEAST 48 HOURS PRIOR TO ANY EXCAVATIONS AT 1-800-922-4455. ALL UTILITIES SHALL BE IDENTIFIED AND CLEARLY MARKED PRIOR TO ANY EXCAVATION WORK. CONTRACTOR SHALL MAINTAIN AND PROTECT MARKED UTILITIES THROUGHOUT PROJECT COMPLETION.
21. CONTRACTOR SHALL COMPLY WITH OWNERS ENVIRONMENTAL ENGINEER ON ALL METHODS AND PROVISIONS FOR ALL EXCAVATION ACTIVITIES INCLUDING SOIL DISPOSAL. ALL BACKFILL MATERIALS TO BE PROVIDED BY THE CONTRACTOR.

#### SITE DIRECTIONS

FROM:	TO:
500 ENTERPRISE DRIVE ROCKY HILL, CONNECTICUT	310 ROWAYTON AVE NORWALK, CONNECTICUT
1. HEAD NORTHEAST ON ENTERPRISE DR TOWARD CAPITAL BLVD	0.37 MI
2. TURN LEFT ONTO CAPITAL BLVD	0.27 MI
3. TURN LEFT ONTO WEST ST	0.30 MI
4. TURN LEFT TO MERGE ONTO I-91 S TOWARD NEW HAVEN	9.59 MI
5. TAKE EXIT 17 FOR CT-15 S	49.00 MI
6. TAKE EXIT 38 FOR CT-123	0.15 MI
7. TURN RIGHT ONTO NEW CANAAN AVE	0.22 MI
8. TAKE FIRST RIGHT ONTO NURSERY ST	0.24 MI
9. TAKE FIRST LEFT ONTO PONUS AVE	0.34 MI
10. TAKE FIRST RIGHT ONTO FOX RUN RD	0.71 MI
11. FOX RUN RD BECOMES FOLLOW ST	0.19 MI
12. TURN LEFT ONTO RICHARDS AVE	1.98 MI
13. TURN LEFT ONTO FLAX HILL RD	0.04 MI
14. STAY STRAIGHT ONTO ROWAYTON AVE. DESTINATION IS ON THE RIGHT	0.81 MI

#### VICINITY MAP

SCALE: 1" = 1000'



#### PROJECT SUMMARY

1. THE PROPOSED SCOPE OF WORK CONSISTS OF A MODIFICATION TO THE EXISTING UNMANNED TELECOMMUNICATIONS FACILITY INCLUDING THE FOLLOWING:
  - A. REMOVE AND REPLACE EXISTING LTE ANTENNA FOR PROPOSED LTE HEXPORT ANTENNA, (1) PER SECTOR.
  - B. REMOVE AND REPLACE (3) EXISTING RRUS-12'S FOR PROPOSED RRUS-32 B2'S, TYP. OF (3) TOTAL ON EXISTING EQUIPMENT RACK WITHIN EQUIPMENT SHELTER.
  - C. INSTALL (6) NEW TOWER MOUNTED AMPLIFIERS BEHIND PROPOSED ANTENNAS, (2) PER SECTOR.
  - D. INSTALL SIX (6) ADDITIONAL 1-5/8"Ø COAX CABLES ROUTED ALONG EXISTING TOWER.


#### PROJECT INFORMATION

AT&T SITE NUMBER: CT5013  
 AT&T SITE NAME: NORWALK CT  
 SITE ADDRESS: EVERSOURCE TOWER NO.: 489S  
 310 ROWAYTON AVE  
 NORWALK, CT 06853  
 LESSEE/APPLICANT: AT&T MOBILITY  
 500 ENTERPRISE DRIVE, SUITE 3A  
 ROCKY HILL, CT 06067  
 ENGINEER: CENTEX ENGINEERING, INC.  
 63-2 NORTH BRANFORD RD.  
 BRANFORD, CT 06405  
 PROJECT COORDINATES: LATITUDE: 41°-04'-39.47" N  
 LONGITUDE: 73°-26'-33.43" W  
 GROUND ELEVATION: ±53' AMSL  
 GROUND ELEVATION AND COORDINATES REFERENCED FROM GOOGLE EARTH.

#### SHEET INDEX

SHT. NO.	DESCRIPTION	REV.
T-1	TITLE SHEET	0
N-1	NOTES AND SPECIFICATIONS	0
C-1	PLANS AND ELEVATION	0
C-2	LTE BWE EQUIPMENT DETAILS	0
E-1	TYPICAL ELECTRICAL DETAILS AND NOTES	0

REV.	DATE	BY	CHK'D	CAG	CONSTRUCTION DOCUMENTS - ISSUED FOR CONSTRUCTION
0	05/11/17	LGL			



CENTEX engineering  
 Centered on Solutions  
 (203) 488-0380  
 (203) 488-8387 Fax  
 63-2 North Branford Road  
 Branford, CT 06405  
 www.CentexEng.com

AT&T MOBILITY  
 WIRELESS COMMUNICATIONS FACILITY  
**NORWALK CT**  
**CT5013 - LTE BWE**  
**EVERSOURCE TOWER NO.: 489S**  
**310 ROWAYTON AVE**  
**NORWALK, CT 06853**

DATE: 11/10/16  
 SCALE: AS NOTED  
 JOB NO. 16071.40


TITLE SHEET

**T-1**  
 Sheet No. 1 of 5










**TOWER STRUCTURAL NOTES:**



- REFER TO STRUCTURAL ANALYSIS REPORT PREPARED BY CENTEK ENGINEERING, INC., PROJ. NO. 16071.40, DATED NOVEMBER 22, 2016 FOR ADDITIONAL INFORMATION AND REQUIREMENTS.
- ALL ANTENNAS AND COAX TO BE INSTALLED IN ACCORDANCE WITH STRUCTURAL ANALYSIS PROVIDED BY CENTEK ENGINEERING, INC. AND FINAL AT&T RF DATA SHEET.

**NOTES:**



- OTHER CARRIER EQUIPMENT NOT SHOWN FOR CLARITY
- A.G.L. = ABOVE GRADE LEVEL




**3 TOWER ELEVATION**  
 C-1 SCALE: 1/8" = 1'-0"



**1 COMPOUND PLAN**  
 C-1 SCALE: 1/4" = 1'-0"



**2 EQUIPMENT LAYOUT PLAN**  
 C-1 SCALE: 3/8" = 1'-0"



**CEN TEK** engineering  
 Centek on Solutions  
 (203) 489-0360  
 (203) 489-8387 Fax  
 63.2 North Branford Road  
 Branford, CT 06405  
 www.CentekEng.com

AT&T MOBILITY  
 WIRELESS COMMUNICATIONS FACILITY  
**NORWALK CT**  
 CT15013 - LTE BWE  
 EVERSOURCE TOWER NO: 4895  
 310 ROWAYTON AVE  
 NORWALK, CT 06853


DATE: 11/10/16  
 SCALE: AS NOTED  
 JOB NO. 16071.40

PLANS AND ELEVATION

**C-1**








**NOTE:**

- DO NOT INSTALL CABLE GROUND KIT AT A BEND AND ALWAYS DIRECT GROUND WIRE DOWN TO CIGBE


**5 CONNECTION OF GROUND WIRES TO GROUND BAR**  
E-1 NOT TO SCALE



**NOTE:**

- DO NOT INSTALL CABLE GROUND KIT AT A BEND AND ALWAYS DIRECT GROUND WIRE DOWN TO GROUND BAR.


**4 ANTENNA CABLE GROUNDING DETAIL**  
E-1 NOT TO SCALE



**LEGEND**

- TINNED COPPER GROUND BAR, 1/4" x 4" x 20", NEWTON INSTRUMENT CO. HOLE CENTERS TO MATCH NEMA DOUBLE LUG.
- INSULATORS, NEWTON INSTRUMENT CAT. NO. 2. 3061-4.
3. 5/8" LOCK WASHERS, NEWTON INSTRUMENT CO. CAT. NO. 3015-8.
- WALL MOUNTING BRACKET, NEWTON INSTRUMENT CO. CAT. NO. A-6056.
- STAINLESS STEEL SECURITY SCREWS.


**3 GROUND BAR DETAIL**  
E-1 NOT TO SCALE



**NOTES:**

- NUMBER OF GROUND BARS MAY VARY DEPENDING ON THE TYPE OF TOWER, LOCATION AND CONNECTION ORIENTATION. PROVIDE AS REQUIRED.
- A SEPARATE GROUND BAR TO BE USED FOR GPS ANTENNA IF REQUIRED.

**2 ANTENNA CABLE GROUNDING - TOWER**  
E-1 NOT TO SCALE



**NOTES:**

- BOND COAXIAL CABLE GROUND KITS TO EACH OWNER'S GROUND BAR ALONG ENTIRE COAX RUN FROM ANTENNA TO SHELTER.
- BOND ALL EQUIPMENT TO GROUND PER NEC AND MANUFACTURER'S SPECIFICATIONS.
- DETAIL IS TYPICAL FOR ALL ANTENNA SECTORS, INCLUDING GPS ANTENNA.

**1 TYPICAL ANTENNA GROUNDING DETAIL**  
E-1 NOT TO SCALE

**ELECTRICAL NOTES**

- PRIOR TO START OF CONSTRUCTION CONTRACTOR SHALL COORDINATE WITH OWNER FOR ALL CONSTRUCTION STANDARDS AND SPECIFICATIONS, AND ALL MANUFACTURER DOCUMENTATION FOR ALL EQUIPMENT TO BE INSTALLED.
- INSTALL ALL EQUIPMENT IN ACCORDANCE WITH LOCAL BUILDING CODE, NATIONAL ELECTRIC CODE, OWNER AND MANUFACTURER'S SPECIFICATIONS.
- CONNECT ALL NEW EQUIPMENT TO EXISTING TELCO AS REQUIRED BY MANUFACTURER.
- MAINTAIN ALL CLEARANCES REQUIRED BY NEC AND EQUIPMENT MANUFACTURER.
- PRIOR TO INSTALLATION CONTRACTOR SHALL MEASURE EXISTING ELECTRICAL LOAD AND VERIFY EXISTING AVAILABLE CAPACITY FOR PROPOSED INSTALLATION. IF INADEQUATE CAPACITY IS AVAILABLE, CONTRACTOR SHALL COORDINATE WITH LOCAL ELECTRIC UTILITY COMPANY TO UPGRADE EXISTING ELECTRIC SERVICE.
- CONTRACTOR SHALL INSPECT EXISTING GROUNDING AND LIGHTNING PROTECTION SYSTEM AND ENSURE THAT IT IS IN COMPLIANCE WITH NEC, AND SITE OWNER'S SPECIFICATIONS. THE RESULTS OF THIS INSPECTION SHALL BE PRESENTED TO OWNER'S REPRESENTATIVE, AND ANY DEFICIENCIES SHALL BE CORRECTED.
- ALL TRANSMISSION TOWER SITES CONTAIN AN EXTENSIVE BURIED GROUNDING SYSTEM. ALL GROUNDING WORK MUST BE COORDINATED WITH, AND APPROVED BY, THE TOWER OWNER'S SITE REPRESENTATIVE. ALL OF THE TOWER OWNER'S SPECIFICATIONS MUST BE STRICTLY FOLLOWED.
- PROVIDE AND INSTALL GROUND KITS FOR ALL NEW COAXIAL CABLES AND BOND TO EXISTING OWNERS GROUNDING SYSTEM PER OWNERS SPECIFICATIONS AND NEC.
- ALL CONDUCTORS SHALL BE TYPE THWN (INT. APPLICATION) AND XHHW (EXT. APPLICATION), 75 DEGREE C, 600 VOLT INSULATION, SOFT ANNEALED STRANDED COPPER. #10 AWG AND SMALLER SHALL BE SPLICED USING ACCEPTABLE SOLDERLESS PRESSURE CONNECTORS. #8 AWG AND LARGER SHALL BE SPLICED USING COMPRESSION SPLIT-BOLT TYPE CONNECTORS. #12 AWG SHALL BE THE MINIMUM SIZE CONDUCTOR FOR LINE VOLTAGE BRANCH CIRCUITS. REFER TO PANEL SCHEDULE FOR BRANCH CIRCUIT CONDUCTOR SIZE(S). CONDUCTORS SHALL BE COLOR CODED FOR CONSISTENT PHASE IDENTIFICATION.
- MINIMUM BENDING RADIUS FOR CONDUCTORS SHALL BE 12 TIMES THE LARGEST DIAMETER OF BRANCH CIRCUIT CONDUCTOR.
- THE ENTIRE ELECTRICAL INSTALLATION SHALL BE MADE IN STRICT ACCORDANCE WITH ALL LOCAL, STATE AND NATIONAL CODES AND REGULATIONS WHICH MAY APPLY AND NOTHING IN THE DRAWINGS OR SPECIFICATIONS SHALL BE INTERPRETED AS AN INFRINGEMENT OF SUCH CODES OR REGULATIONS.
- THE ELECTRICAL CONTRACTOR IS TO BE RESPONSIBLE FOR THE COMPLETE INSTALLATION AND COORDINATION OF THE ENTIRE ELECTRICAL SERVICE. ALL ACTIVITIES TO BE COORDINATED THROUGH OWNER'S REPRESENTATIVE, DESIGN ENGINEER AND OTHER AUTHORITIES HAVING JURISDICTION OF TRADES.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL PERMITS AND PAY ALL FEES AS MAY BE REQUIRED FOR THE ELECTRICAL WORK AND FOR SCHEDULING OF ALL INSPECTIONS AS MAY BE REQUIRED BY THE LOCAL AUTHORITY.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION WITH THE SITE AND/OR BUILDING OWNER FOR NEW AND/OR DEMOLITION WORK INVOLVED.
- THE CONTRACTOR SHALL GUARANTEE ALL NEW WORK FOR A PERIOD OF ONE YEAR FROM THE ACCEPTANCE DATE BY THE OWNER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING WARRANTIES FROM ALL EQUIPMENT MANUFACTURERS FOR SUBMISSION TO THE OWNER.
- DRAWINGS INDICATE GENERAL ARRANGEMENT OF WORK INCLUDED IN CONTRACT. CONTRACTOR SHALL WITHOUT EXTRA CHARGE, MAKE MODIFICATIONS TO THE LAYOUT OF THE WORK TO PREVENT CONFLICT WITH WORK OF OTHER TRADES AND FOR THE PROPER INSTALLATION OF WORK. CHECK ALL DRAWINGS AND VISIT JOB SITE TO VERIFY SPACE AND TYPE OF EXISTING CONDITIONS IN WHICH WORK WILL BE DONE, PRIOR TO SUBMITTAL OF BID.
- ALL NON-CURRENT CARRYING PARTS OF THE ELECTRICAL AND TELEPHONE CONDUIT SYSTEMS SHALL BE MECHANICALLY AND ELECTRICALLY CONNECTED TO PROVIDE AN INDEPENDENT RETURN PATH TO THE EQUIPMENT GROUNDING SOURCES.
- GROUNDING SYSTEM WILL BE IN ACCORDANCE WITH THE LATEST ACCEPTABLE EDITION OF THE NATIONAL ELECTRICAL CODE AND REQUIREMENTS PER LOCAL INSPECTOR HAVING JURISDICTION.
- EACH EQUIPMENT GROUND CONDUCTOR SHALL BE SIZED IN ACCORDANCE WITH THE N.E.C. ARTICLE 250-122. (MIN. #12 AWG).
- CONTRACTOR SHALL PROVIDE A CELLULAR GROUNDING SYSTEM WITH THE MAXIMUM AC RESISTANCE TO GROUND OF 5 OHM BETWEEN ANY POINT ON THE GROUNDING SYSTEM AS MEASURED BY 3-POINT GROUNDING TEST. (REFER TO SECTION 16960).

**TESTS BY INDEPENDENT ELECTRICAL TESTING FIRM**

- CONTRACTOR SHALL RETAIN THE SERVICES OF A LOCAL INDEPENDENT ELECTRICAL TESTING FIRM (WITH MINIMUM 5 YEARS COMMERCIAL EXPERIENCE IN THE ELECTRICAL TESTING INDUSTRY) AS SPECIFIED BY OWNER TO PERFORM:
  - TESTING PROCEDURE INCLUDING THE MAKE AND MODEL OF TEST EQUIPMENT.
  - CERTIFICATION OF TESTING EQUIPMENT CALIBRATION WITHIN SIX (6) MONTHS OF DATE OF TESTING. INCLUDE CERTIFICATION LAB ADDRESS AND TELEPHONE NUMBER.
  - GRAPHICAL DESCRIPTION OF TESTING METHOD ACTUALLY IMPLEMENTED.
- TESTING SHALL BE PERFORMED IN THE PRESENCE AND TO THE SATISFACTION OF OWNERS CONSTRUCTION REPRESENTATIVE. TESTING DATA SHALL BE INITIALED AND DATED BY THE CONSTRUCTION AND INCLUDED WITH THE WRITTEN REPORT/ANALYSIS.
- THE CONTRACTOR SHALL FORWARD SIX (6) COPIES OF THE INDEPENDENT ELECTRICAL TESTING FIRM REPORT/ANALYSIS TO ENGINEER A MINIMUM OF TEN (10) WORKING DAYS PRIOR TO THE JOB TURNOVER.
- CONTRACTOR TO PROVIDE A MINIMUM OF ONE (1) WEEK NOTICE TO OWNER AND ENGINEER FOR ALL TESTS REQUIRING WITNESSING.

PROFESSIONAL ENGINEER SEAL

STATE OF CONNECTICUT PROFESSIONAL ENGINEER

DATE: 05/11/17  
REV. 0  
LGL  
CAG  
ISSUED FOR CONSTRUCTION  
DRAWN BY/CHK'D BY/DESCRIPTION

at&t

EMPIRE telecom

CENTEX engineering  
Centered on Solutions™  
(203) 488-0980  
(203) 488-8587 Fax  
65.2 North Branford Road  
Branford, CT 06405  
www.CentexEng.com

AT&T MOBILITY  
WIRELESS COMMUNICATIONS FACILITY  
**NORWALK CT**  
CT5013 - LITE BWE  
EVERSOURCE TOWER NO. 4895  
310 ROWAYTON AVE  
NORWALK, CT 06853

DATE: 11/10/16  
SCALE: AS NOTED  
JOB NO. 16071.40

TYPICAL ELECTRICAL DETAILS AND NOTES

**E-1**

Sheet No. 5 of 5



**Structural Analysis of  
Antenna Mast and Tower**


*AT&T Site Ref: CT5013*

*Eversource Structure No. 489s  
95' Electric Transmission Tower*

*310 Rowayton Ave  
Norwalk, CT*

*CEN TEK Project No. 16071.40*

*Date: November 22, 2016*



**Prepared for:**  
**AT&T Mobility**  
**500 Enterprise Drive, Suite 3A**  
**Rocky Hill, CT 06067**



# **Table of Contents**

## **SECTION 1 - REPORT**

- INTRODUCTION
- PRIMARY ASSUMPTIONS USED IN THE ANALYSIS
- ANALYSIS
- DESIGN BASIS
- RESULTS
- CONCLUSION

## **SECTION 2 - CONDITIONS & SOFTWARE**

- STANDARD ENGINEERING CONDITIONS
- GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAMS
  - RISA 3-D

## **SECTION 3 - DESIGN CRITERIA**

- CRITERIA FOR DESIGN OF PCS FACILITIES ON OR EXTENDING ABOVE METAL ELECTRIC TRANSMISSION TOWERS
- NU DESIGN CRITERIA TABLE
- PCS SHAPE FACTOR CRITERIA
- WIRE LOADS SHEET

## **SECTION 4 - DRAWINGS**

- EL-1 TOWER AND MAST ELEVATION
- FP-1 FEEDLINE PLAN

## **SECTION 5 - TIA-222-G LOAD CALCULATIONS FOR MAST ANALYSIS**

- WIND & ICE LOAD

## **SECTION 6 - MAST ANALYSIS PER TIA-222-G**

- LOAD CASES AND COMBINATIONS (TIA/EIA LOADING)
- RISA 3-D ANALYSIS REPORT
- MAST CONNECTION ANALYSIS

## **SECTION 7 - NECS/NU LOAD CALCULATIONS**

- WIND LOAD



**SECTION 8 - MAST ANALYSIS PER NESC/NU**

- LOAD CASES AND COMBINATIONS (NESC/NU LOADING)
- RISA 3-D ANALYSIS REPORT

**SECTION 9 - TOWER ANALYSIS**

- NESC LOAD CALCULATIONS ON TOWER
- RISA 3-D ANALYSIS REPORT
- TOWER ANALYSIS
- ANCHOR BOLT ANALYSIS
- FOUNDATION ANALYSIS

**SECTION 10 - REFERENCE MATERIAL**

- RFDS SHEET
- EQUIPMENT CUT SHEETS



## Introduction

The purpose of this report is to analyze the existing mast and 95' tower located at 310 Rowayton Ave in Norwalk, CT for the proposed antenna and equipment upgrade by AT&T.

The existing/proposed loads consist of the following:

- **AT&T (Existing to Remain):**  
**Coax Cables:** Six (6) 1-5/8"  $\varnothing$  coax cables running on the exterior of the existing tower.  
**Mast:** Pipe 5" Sch. 80 x 19-ft long.
- **AT&T (Existing to Remove):**  
**Antennas:** Three (3) KMW FX-X-CD-65-12-65-14 panel antennas pipe on the existing mast with a RAD center elevation of 103-ft above grade.
- **AT&T (Proposed):**  
**Antennas:** Three (3) CCI HPA-65F-BUU-H2 panel antennas and six (6) Kaelus TMA2117F00V1-1 TMAs flush pipe on the existing mast with a RAD center elevation of 103-ft above grade.  
**Coax Cables:** Six (6) 1-5/8"  $\varnothing$  coax cables running on the exterior of the tower.

## Primary assumptions used in the analysis

- Design steel stresses are defined by AISC-LRFD 14<sup>th</sup> edition for design of the antenna Mast and antenna supporting elements.
- ASCE Manual No. 72, "Design of Steel Transmission Pole Structures Second Edition", defines allowable steel stresses for evaluation of the utility pole.
- All utility pole members are adequately protected to prevent corrosion of steel members.
- All proposed antenna mounts are modeled as listed above.
- Pipe mast will be properly installed and maintained.
- No residual stresses exist due to incorrect pole erection.
- All bolts are appropriately tightened providing the necessary connection continuity.
- All welds conform to the requirements of AWS D1.1.
- Pipe mast and utility pole will be in plumb condition.
- Utility pole was properly installed and maintained and all members were properly designed, detailed, fabricated, and installed and have been properly maintained since erection.
- Any deviation from the analyzed loading will require a new analysis for verification of structural adequacy.

## A n a l y s i s

Structural analysis of the existing antenna mast was independently completed using the current version of RISA-3D computer program licensed to CENTEK Engineering, Inc.

The existing mast consisting of a 5" Sch. 80 x 19' long pipe conforming to ASTM A53 Grade B ( $F_y = 53\text{ksi}$ ) connected at two points to the existing pole was analyzed for its ability to resist loads prescribed by the TIA-222-G standard. Section 5 of this report details these gravity and lateral wind loads. NESC prescribed loads were also applied to the mast in order to obtain reactions needed for analyzing the utility pole structure. These loads are developed in Section 7 of this report. Load cases and combinations used in RISA-3D for TIA/EIA loading and for NESC/NU loading are listed in report Sections 6 and 8, respectively.

An envelope solution was first made to determine maximum and minimum forces, stresses, and deflections to confirm the selected section as adequate. Additional analyses were then made to determine the NESC forces to be applied to the pole structure.

The RISA-3D program contains a library of all AISC shapes and corresponding section properties are computed and applied directly within the program. The program's Steel Code Check option was also utilized. The forces calculated in RISA-3D using NESC guidelines were then applied to the pole. Maximum usage for the pole was calculated considering the additional forces from the mast and associated appurtenances.

## D e s i g n B a s i s

Our analysis was performed in accordance with TIA-222-G, ASCE Manual No. 72 – "Design of Steel Transmission Pole Structures Second Edition", NESC C2-2007 and Northeast Utilities Design Criteria.

### ▪ UTILITY POLE ANALYSIS

The purpose of this analysis is to determine the adequacy of the existing utility pole to support the proposed antenna loads. The loading and design requirements were analyzed in accordance with the NU Design Criteria Table, NESC C2-2007 ~ Construction Grade B, and ASCE Manual No. 72.

Load cases considered:

#### Load Case 1: NESC Heavy

Wind Pressure.....	4.0 psf
Radial Ice Thickness.....	0.5"
Vertical Overload Capacity Factor.....	1.50
Wind Overload Capacity Factor.....	2.50
Wire Tension Overload Capacity Factor.....	1.65

#### Load Case 2: NESC Extreme

Wind Speed.....	110 mph <sup>(1)</sup>
Radial Ice Thickness.....	0"

Note 1: NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading, 1.25 x Gust Response Factor (wind speed: 3-second gust)



▪ **MAST ASSEMBLY ANALYSIS**

Mast, appurtenances and connections to the utility tower were analyzed and designed in accordance with the NU Design Criteria Table, TIA-222-G and AISC standards.

Load cases considered:

Load Case 1:

Wind Speed..... 93 mph <sup>(2016 CSBC Appendix-N)</sup>  
 Radial Ice Thickness..... 0"

Load Case 2:

Wind Pressure..... 50 mph wind pressure  
 Radial Ice Thickness..... 0.75"

**R e s u l t s**

▪ **MAST ASSEMBLY**

The existing mast was determined to be structurally **adequate**.

Member	Stress Ratio (% of capacity)	Result
Mast	64.3%	<b>PASS</b>
Connection	16.2%	<b>PASS</b>

▪ **UTILITY TOWER**

This analysis finds that the subject utility structure is adequate to support the existing mast and related appurtenances. The tower stresses meet the requirements set forth by the ASCE Manual No. 10-97, "Design of Latticed Steel Transmission Structures", for the applied NESC Heavy and Hi-Wind load cases. The detailed analysis results are provided in Section 9 of this report. The analysis results are summarized as follows:

A maximum usage of **96.5%** occurs in the utility tower under the **NESC Extreme** loading condition.

TOWER SECTION:

The utility tower was found to be within allowable limits.

Tower Section	Stress Ratio (% of capacity)	Result
Base	96.5%	<b>PASS</b>

▪ **FOUNDATION AND ANCHORS**

The existing tower base foundation consists of a 4-ft Ø x 23.0-ft long reinforced concrete caisson. The base of the tower is connected to the foundation by means of (4) 2.5"Ø, ASTM A36 anchor bolts embedded approximately 6-ft into the concrete foundation structure. The existing guy anchor foundation consists of two (2) 6.5-ft x 4.0-ft x 1.83-ft thick reinforced concrete pads. Foundation information was obtained from NUSCO drawing # 01153-6001.

**BASE REACTIONS:**

From analysis of CL&P pole based on NESC/NU prescribed loads.

Load Case	Transverse	Axial	Overturning Moment
NESC Heavy Wind	2.5 kips	63.3 kips	69.7 ft-kips
NESC Extreme Wind	9.8 kips	18.2 kips	498.6 ft-kips

**ANCHOR BOLTS:**

The anchor bolts were found to be within allowable limits.

Pole Component	Design Limit	Stress Ratio (percentage of capacity)	Result
Anchor Bolts	Tension	87.2%	<b>PASS</b>

**TOWER BASE FOUNDATION:**

The foundation was found to be within allowable limits.

Foundation	Design Limit	Proposed Loading <sup>(1)</sup>	Result
Reinforced Concrete Caisson	Moment Capacity	38.5%	<b>PASS</b>
	Lateral Deflection	1.23 in. <sup>(2)</sup>	<b>PASS</b>

Note 1: 10% increase to base reactions used in foundation analysis per OTRM 051.

Note 2: Lateral deflection limited to L/100 per OTRM 059 Rev 4 dated 2/01/10. (L/100 = 23\*12/100=2.76-in)

**GUY REACTIONS:**

From Risa3D analysis of CL&P pole based on NESC/NU prescribed loads.

Load Case	Horizontal (in plane)	Axial	Horizontal (out of plane)
NESC Heavy Wind	5.0 kips	13.7 kips	2.5 kips
NESC Extreme Wind	6.0 kips	16.5 kips	3.0 kips

Note 1 – 10% increase applied to guy reactions per OTRM 051

**GUY ANCHOR FOUNDATION:**

The foundation was found to be within allowable limits.

Foundation	Design Limit	Allowable	Proposed Loading <sup>(1)</sup>	Result
Reinforced Concrete Pad	Uplift	145.1 kips	18.2 kips	<b>PASS</b>
	Sliding	90.6 kips	6.6 kips	<b>PASS</b>

Note 1: 10% increase to guy reactions used in foundation analysis per OTRM 051.



**CENTEK Engineering, Inc.**  
Structural Analysis – 95-ft Structure #489s  
AT&T Antenna Upgrade – CT5013  
Norwalk, CT  
November 22, 2016


C o n c l u s i o n


This analysis shows that the subject utility pole **is adequate** to support the proposed AT&T equipment upgrade.

The analysis is based, in part on the information provided to this office by Eversource and AT&T. If the existing conditions are different than the information in this report, CENTEK engineering, Inc. must be contacted for resolution of any potential issues.

Please feel free to call with any questions or comments.

Respectfully Submitted by:

  
Timothy J. Lynn, PE  
Structural Engineer



STANDARD CONDITIONS FOR FURNISHING OF  
PROFESSIONAL ENGINEERING SERVICES ON  
EXISTING STRUCTURES

All engineering services are performed on the basis that the information used is current and correct. This information may consist of, but is not necessarily limited to:

- Information supplied by the client regarding the structure itself, its foundations, the soil conditions, the antenna and feed line loading on the structure and its components, or other relevant information.
- Information from the field and/or drawings in the possession of CEN TEK engineering, Inc. or generated by field inspections or measurements of the structure.
- It is the responsibility of the client to ensure that the information provided to CEN TEK engineering, Inc. and used in the performance of our engineering services is correct and complete. In the absence of information to the contrary, we assume that all structures were constructed in accordance with the drawings and specifications and are in an un-corroded condition and have not deteriorated. It is therefore assumed that its capacity has not significantly changed from the “as new” condition.
- All services will be performed to the codes specified by the client, and we do not imply to meet any other codes or requirements unless explicitly agreed in writing. If wind and ice loads or other relevant parameters are to be different from the minimum values recommended by the codes, the client shall specify the exact requirement. In the absence of information to the contrary, all work will be performed in accordance with the latest revision of ANSI/ASCE10 & ANSI/EIA-222.
- All services are performed, results obtained, and recommendations made in accordance with generally accepted engineering principles and practices. CEN TEK engineering, Inc. is not responsible for the conclusions, opinions and recommendations made by others based on the information we supply.



## GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ RISA - 3 D

RISA-3D Structural Analysis Program is an integrated structural analysis and design software package for buildings, bridges, tower structures, etc.

### Modeling Features:

- Comprehensive CAD-like graphic drawing/editing capabilities that let you draw, modify and load elements as well as snap, move, rotate, copy, mirror, scale, split, merge, mesh, delete, apply, etc.
- Versatile drawing grids (orthogonal, radial, skewed)
- Universal snaps and object snaps allow drawing without grids
- Versatile general truss generator
- Powerful graphic select/unselect tools including box, line, polygon, invert, criteria, spreadsheet selection, with locking
- Saved selections to quickly recall desired selections
- Modification tools that modify single items or entire selections
- Real spreadsheets with cut, paste, fill, math, sort, find, etc.
- Dynamic synchronization between spreadsheets and views so you can edit or view any data in the plotted views or in the spreadsheets
- Simultaneous view of multiple spreadsheets
- Constant in-stream error checking and data validation
- Unlimited undo/redo capability
- Generation templates for grids, disks, cylinders, cones, arcs, trusses, tanks, hydrostatic loads, etc.
- Support for all units systems & conversions at any time
- Automatic interaction with RISASection libraries
- Import DXF, RISA-2D, STAAD and ProSteel 3D files
- Export DXF, SDNF and ProSteel 3D files

### Analysis Features:

- Static analysis and P-Delta effects
- Multiple simultaneous dynamic and response spectra analysis using Gupta, CQC or SRSS mode combinations
- Automatic inclusion of mass offset (5% or user defined) for dynamic analysis
- Physical member modeling that does not require members to be broken up at intermediate joints
- State of the art 3 or 4 node plate/shell elements
- High-end automatic mesh generation — draw a polygon with any number of sides to create a mesh of well-formed quadrilateral (NOT triangular) elements.
- Accurate analysis of tapered wide flanges - web, top and bottom flanges may all taper independently
- Automatic rigid diaphragm modeling
- Area loads with one-way or two-way distributions
- Multiple simultaneous moving loads with standard AASHTO loads and custom moving loads for bridges, cranes, etc.
- Torsional warping calculations for stiffness, stress and design
- Automatic Top of Member offset modeling
- Member end releases & rigid end offsets
- Joint master-slave assignments
- Joints detachable from diaphragms
- Enforced joint displacements
- 1-Way members, for tension only bracing, slipping, etc.

- 1-Way springs, for modeling soils and other effects
- Euler members that take compression up to their buckling load, then turn off.
- Stress calculations on any arbitrary shape
- Inactive members, plates, and diaphragms allows you to quickly remove parts of structures from consideration
- Story drift calculations provide relative drift and ratio to height
- Automatic self-weight calculations for members and plates
- Automatic subgrade soil spring generator

Graphics Features:

- Unlimited simultaneous model view windows
- Extraordinary “true to scale” rendering, even when drawing
- High-speed redraw algorithm for instant refreshing
- Dynamic scrolling stops right where you want
- Plot & print virtually everything with color coding & labeling
- Rotate, zoom, pan, scroll and snap views
- Saved views to quickly restore frequent or desired views
- Full render or wire-frame animations of deflected model and dynamic mode shapes with frame and speed control
- Animation of moving loads with speed control
- High quality customizable graphics printing

Design Features:

- Designs concrete, hot rolled steel, cold formed steel and wood
- ACI 1999/2002, BS 8110-97, CSA A23.3-94, IS456:2000, EC 2-1992 with consistent bar sizes through adjacent spans
- Exact integration of concrete stress distributions using parabolic or rectangular stress blocks
- Concrete beam detailing (Rectangular, T and L)
- Concrete column interaction diagrams
- Steel Design Codes: AISC ASD 9th, LRFD 2nd & 3rd, HSS Specification, CAN/CSA-S16.1-1994 & 2004, BS 5950-1-2000, IS 800-1984, Euro 3-1993 including local shape databases
- AISI 1999 cold formed steel design
- NDS 1991/1997/2001 wood design, including Structural Composite Lumber, multi-ply, full sawn
- Automatic spectra generation for UBC 1997, IBC 2000/2003
- Generation of load combinations: ASCE, UBC, IBC, BOCA, SBC, ACI
- Unbraced lengths for physical members that recognize connecting elements and full lengths of members
- Automatic approximation of K factors
- Tapered wide flange design with either ASD or LRFD codes
- Optimization of member sizes for all materials and all design codes, controlled by standard or user-defined lists of available sizes and criteria such as maximum depths
- Automatic calculation of custom shape properties
- Steel Shapes: AISC, HSS, CAN, ARBED, British, Euro, Indian, Chilean
- Light Gage Shapes: AISI, SSMA, Dale / Incor, Dietrich, Marino\WARE
- Wood Shapes: Complete NDS species/grade database
- Full seamless integration with RISAFoot (Ver 2 or better) for advanced footing design and detailing
- Plate force summation tool



Results Features:

- Graphic presentation of color-coded results and plotted designs
- Color contours of plate stresses and forces with quadratic smoothing, the contours may also be animated
- Spreadsheet results with sorting and filtering of: reactions, member & joint deflections, beam & plate forces/stresses, optimized sizes, code designs, concrete reinforcing, material takeoffs, frequencies and mode shapes
- Standard and user-defined reports
- Graphic member detail reports with force/stress/deflection diagrams and detailed design calculations and expanded diagrams that display magnitudes at any dialed location
- Saved solutions quickly restore analysis and design results.

## GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ PLS - TOWER

PLS-TOWER is a Microsoft Windows program for the analysis and design of steel latticed towers used in electric power lines or communication facilities. Both self-supporting and guyed towers can be modeled. The program performs design checks of structures under user specified loads. For electric power structures it can also calculate maximum allowable wind and weight spans and interaction diagrams between different ratios of allowable wind and weight spans.

### Modeling Features:

- Powerful graphics module (stress usages shown in different colors)
- Graphical selection of joints and members allows graphical editing and checking
- Towers can be shown as lines, wire frames or can be rendered as 3-d polygon surfaces
- Can extract geometry and connectivity information from a DXF CAD drawing
- CAD design drawings, title blocks, drawing borders or photos can be tied to structure model
- XML based post processor interface
- Steel Detailing Neutral File (SDNF) export to link with detailing packages
- Can link directly to line design program PLS-CADD
- Automatic generation of structure files for PLS-CADD
- Databases of steel angles, rounds, bolts, guys, etc.
- Automatic generation of joints and members by symmetries and interpolations
- Automated mast generation (quickly builds model for towers that have regular repeating sections) via graphical copy/paste
- Steel angles and rounds modeled either as truss, beam or tension-only elements
- Guys are easily handled (can be modeled as exact cable elements)

### Analysis Features:

- Automatic handling of tension-only members
- Automatic distribution of loads in 2-part suspension insulators (v-strings, horizontal vees, etc.)
- Automatic calculation of tower dead, ice, and wind loads as well as drag coefficients according to:
  - ASCE 74-1991
  - NESC 2002
  - NESC 2007
  - IEC 60826:2003
  - EN50341-1:2001 (CENELEC)
  - EN50341-3-9:2001 (UK NNA)
  - EN50341-3-17:2001 (Portugal NNA)
  - ESAA C(b)1-2003 (Australia)
  - TPNZ (New Zealand)
  - REE (Spain)
  - EIA/TIA 222-F
  - ANSI/TIA 222-G
  - CSA S37-01
- Automated microwave antenna loading as per EIA/TIA 222-F and ANSI/TIA 222-G
- Minimization of problems caused by unstable joints and mechanisms
- Automatic bandwidth minimization and ability to solve large problems
- Design checks according to (other standards can be added easily):
  - ASCE Standard 10-90



- AS 3995 (Australian Standard 3995)
- BS 8100 (British Standard 8100)
- EN50341-1 (CENELEC, both empirical and analytical methods are available)
- ECCS 1985
- NGT-ECCS
- PN-90/B-03200
- EIA/TIA 222-F
- ANSI/TIA 222-G
- CSA S37-01
- EDF/RTE Resal
- IS 802 (India Standard 802)

Results Features:

- Design summaries printed for each group of members
  - Easy to interpret text, spreadsheet and graphics design summaries
  - Automatic determination of allowable wind and weight spans
  - Automatic determination of interaction diagrams between allowable wind and weight spans
  - Capability to batch run multiple tower configurations and consolidate the results
  - Automated optimum angle member size selection and bolt quantity determination
- Tool for interactive angle member sizing and bolt quantity determination.

Criteria for Design of PCS Facilities On or  
Extending Above Metal Electric Transmission  
Towers & Analysis of Transmission Towers  
Supporting PCS Masts <sup>(1)</sup>

Introduction

This criteria is the result from an evaluation of the methods and loadings specified by the separate standards, which are used in designing telecommunications towers and electric transmission towers. That evaluation is detailed elsewhere, but in summary; the methods and loadings are significantly different. This criteria specifies the manner in which the appropriate standard is used to design PCS facilities including masts and brackets (hereafter referred to as “masts”), and to evaluate the electric transmission towers to support PCS masts. The intent is to achieve an equivalent level of safety and security under the extreme design conditions expected in Connecticut and Massachusetts.

ANSI Standard TIA-222 covering the design of telecommunications structures specifies a working strength/allowable stress design approach. This approach applies the loads from extreme weather loading conditions, and designs the structure so that it does not exceed some defined percentage of failure strength (allowable stress).

ANSI Standard C2-2007 (National Electrical Safety Code) covering the design of electric transmission metal structures is based upon an ultimate strength/yield stress design approach. This approach applies a multiplier (overload capacity factor) to the loads possible from extreme weather loading conditions, and designs the structure so that it does not exceed its ultimate strength (yield stress).

Each standard defines the details of how loads are to be calculated differently. Most of the NU effort in “unifying” both codes was to establish what level of strength each approach would provide, and then increasing the appropriate elements of each to achieve a similar level of security under extreme weather loadings.

Two extreme weather conditions are considered. The first is an extreme wind condition (hurricane) based upon a 50-year recurrence (2% annual probability). The second is a winter condition combining wind and ice loadings.

The following sections describe the design criteria for any PCS mast extending above the top of an electric transmission tower, and the analysis criteria for evaluating the loads on the transmission tower from such a mast from the lower portions of such a mast, and loads on the pre-existing electric lower portions of such a mast, and loads on the pre-existing electric transmission tower and the conductors it supports.

| Note 1: Prepared from documentation provide from Northeast Utilities.



## P C S M a s t

The PCS facility (mast, external cable/trays, including the initial and any planned future support platforms, antennas, etc. extending the full height above the top level of the electric transmission structure) shall be designed in accordance with the provisions of TIA 222-G:

## E L E C T R I C T R A N S M I S S I O N T O W E R

The electric transmission tower shall be analyzed using yield stress theory in accordance with the attached table titled “NU Design Criteria”. This specifies uniform loadings (different from the TIA loadings) on the each of the following components of the installed facility:

- PCS mast for its total height above ground level, including the initial and planned future support platforms, antennas, etc. above the top of an electric transmission structure.
- Conductors are related devices and hardware.
- Electric transmission structure. The loads from the PCS facility and from the electric conductors shall be applied to the structure at conductor and PCS mast attachment points, where those load transfer to the tower.

The uniform loadings and factors specified for the above components in the table are based upon the National Electrical Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to TIA and its loads and factors with the exceptions noted above. (Note that the NESC does not require the projected wind surfaces of structures and equipment to be increased by the ice covering.)

In the event that the electric transmission tower is not sufficient to support the additional loadings of the PCS mast, reinforcement will be necessary to upgrade the strength of the overstressed members.



## Attachment A

### NU Design Criteria

			Basic Wind Speed V (MPH)	Pressure Q (PSF)	Height Factor Kz	Gust Factor Gh	Load or Stress Factor	Force Coef - Shape Factor
<b>Ice Condition</b>	<b>TIA/EIA</b>	Antenna Mount	TIA	TIA (.75Wi)	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
	<b>NESC Heavy</b>	Tower/Pole Analysis with antennas extending above top of Tower/Pole (Yield Stress)	-----	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces
		Tower/Pole Analysis with Antennas below top of Tower/Pole (on two faces)	-----	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces
			Conductors:	Conductor loads provided by NU				
<b>High Wind Condition</b>	<b>TIA/EIA</b>	Antenna Mount	85	TIA	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
	<b>NESC Extreme Wind</b>	Tower/Pole Analysis with antennas extending above top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna					1.6 Flat Surfaces 1.3 Round Surfaces
		Tower/Pole Analysis with Antennas below top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading Height above ground level based on top of Tower/Pole					1.6 Flat Surfaces 1.3 Round Surfaces
			Conductors:	Conductor loads provided by NU				
<b>NESC Extreme Ice with Wind Condition*</b>	Tower/Pole Analysis with antennas extending above top of Tower/Pole		Use NESC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna				1.6 Flat Surfaces 1.3 Round Surfaces	
	Tower/Pole Analysis with Antennas below top of Tower/Pole		Use NESC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load Height above ground level based on top of Tower/Pole				1.6 Flat Surfaces 1.3 Round Surfaces	
			Conductors:	Conductor loads provided by NU				

\* Only for Structures Installed after 2007

### Communication Antennas on Transmission Structures (CL&P & WMECo Only)

<b>Northeast Utilities</b> Approved by: KMS (NU)	<b>Design</b> NU Confidential Information	<b>OTRM 059</b>	<b>Rev.1</b> <b>03/17/2011</b>
		<b>Page 7 of 9</b>	



Shape Factor Criteria shall be per TIA Shape Factors.

- 2) STEP 2 - The electric transmission structure analysis and evaluation shall be performed in accordance with NESC requirements and shall include the mast and antenna loads determined from NESC applied loading conditions (not TIA/EIA Loads) on the structure and mount as specified below, and shall include the wireless communication mast and antenna loads per NESC criteria)

The structure shall be analyzed using yield stress theory in accordance with Attachment A, "NU Design Criteria." This specifies uniform loadings (different from the TIA loadings) on each of the following components of the installed facility:

- a) Wireless communication mast for its total height above ground level, including the initial and any planned future equipment (Support Platforms, Antennas, TMA's etc.) above the top of an electric transmission structure.
- b) Conductors and related devices and hardware (wire loads will be provided by NU).
- c) Electric Transmission Structure
  - i) The loads from the wireless communication equipment components based on NESC and NU Criteria in Attachment A, and from the electric conductors shall be applied to the structure at conductor and wireless communication mast attachment points, where those loads transfer to the tower.
  - ii) Shape Factor Multiplier:

NESC Structure Shape	Cd
Polyround (for polygonal steel poles)	1.3
Flat	1.6
Open Lattice	3.2

- iii) When Coaxial Cables are mounted along side the pole structure, the shape multiplier shall be:

Mount Type	Cable Cd	Pole Cd
Coaxial Cables on outside periphery (One layer)	1.45	1.45
Coaxial Cables mounted on stand offs	1.6	1.3

- d) The uniform loadings and factors specified for the above components in Attachment A, "NU Design Criteria" are based upon the National Electric Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to the TIA and its loads and factors with the exceptions noted above.

**Note:** The NESC does not require ice load be included in the supporting structure. (Ice on conductors and shield wire only, and NU will provide these loads).

- e) Mast reaction loads shall be evaluated for local effects on the transmission structure members at the attachment points.



Structure Load Report - Pole 489S\_1.txt

PLS-CADD Version 11.28x64 2:24:06 PM Tuesday, December 13, 2011  
 CG Power Solutions USA Inc  
 Project Name: 'c:\users\dmcclure\desktop\local saves\sai\line model for 489.DON'  
 Line Title: 'SAM'

Criteria Notes:  
 NUSCO Criteria File nusco\_green.cri  
 This criteria file is based on the 2007 edition of the National Electric Safety Code  
 This criteria file is to be applied to new transmission line designs in Central CT.  
 For a detailed map on the NUSCO design wind zones, please consult OTRM 060  
 Rule 250C Wind speed assumed to be 110 MPH  
 Rule 250D Assumed 15 deg F, 4 psf wind and 1 inch of radial ice

Structure #8 'c:\users\dmcclure\desktop\local saves\sai\structures\strb-489s.str'  
 Station (ft) 2245.53, Line angle (deg) -4, Orientation angle (deg) 0  
 Cost 0.00

Weather Cases

WC #	Description	Air Density Factor (psf/mph^2)	Wind Vel. (mph)	Wind Pres. (psf)	Wire Ice Thick (in)	Wire Ice Density (lbs/ft^3)	Wire Ice Load (lbs/ft)	Wire Temp (deg F)	Ambient Temp (deg F)	Weather Load Factor	NESC Constant (lbs/ft)	Wire Wind Height Adjust Model	Wire Gust Response Factor
1	NESC Rule 250B	0.00256	40	4.0	0.50	57.000	0.00	0	0	1.00	0.30	None	1
2	NESC Rule 250C	0.00256	110	31.0	0.00	0.000	0.00	60	60	1.00	0.00	NESC 2007	NESC 2007
3	NESC Rule 250D	0.00256	40	4.1	1.00	57.000	0.00	15	15	1.00	0.00	None	1
4	Uplift	0.00256	0	0.0	0.00	0.000	0.00	-20	-20	1.00	0.00	None	1
5	Maximum Operating	0.00256	0	0.0	0.00	0.000	0.00	285	285	1.00	0.00	None	1
6	NESC Blowout 6PSF	0.00256	48	6.0	0.00	0.000	0.00	60	60	1.00	0.00	None	1
7	GALLOPING (SWING)	0.00256	28	2.0	0.50	57.000	0.00	32	32	1.00	0.00	None	1
8	GALLOPING (SAG)	0.00256	0	0.0	0.50	57.000	0.00	32	32	1.00	0.00	None	1
9	0 Deg F	0.00256	0	0.0	0.00	0.000	0.00	0	0	1.00	0.00	None	1
10	30 Deg F	0.00256	0	0.0	0.00	0.000	0.00	30	30	1.00	0.00	None	1
11	32 Deg F	0.00256	0	0.0	0.50	57.000	0.00	32	32	1.00	0.00	None	1
12	60 Deg F	0.00256	0	0.0	0.00	0.000	0.00	60	60	1.00	0.00	None	1
13	90 Deg F	0.00256	0	0.0	0.00	0.000	0.00	90	90	1.00	0.00	None	1
14	120 Deg F	0.00256	0	0.0	0.00	0.000	0.00	120	120	1.00	0.00	None	1
15	167 Deg F	0.00256	0	0.0	0.00	0.000	0.00	167	167	1.00	0.00	None	1
16	212 Deg F	0.00256	0	0.0	0.00	0.000	0.00	212	212	1.00	0.00	None	1
17	285 Deg F	0.00256	0	0.0	0.00	0.000	0.00	285	285	1.00	0.00	None	1
18	NU Blowout	0.00256	59	9.0	0.00	0.000	0.00	60	60	1.00	0.00	None	1
19	NU Swing Cw	0.00256	0	0.0	0.00	0.000	0.00	60	60	1.00	0.00	None	1
20	NU Swing Cc	0.00256	35	3.1	0.00	0.000	0.00	45	45	1.00	0.00	None	1
21	NU Swing Cs	0.00256	48	6.0	0.00	0.000	0.00	60	60	1.00	0.00	None	1
22	NU Swing Ch	0.00256	60	9.2	0.00	0.000	0.00	60	60	1.00	0.00	None	1
23	ACSS Maximum	0.00256	0	0.0	0.00	0.000	0.00	356	356	1.00	0.00	None	1

Structure Loads Criteria

LC #	WC #	Load Case Description	Cable Condition	Wind Dir.	Bisect Wind Angle	Wire Vert. Load Factor	Wire + Struct. Wind Load Factor	Wire Tension Load Factor	Struct Weight Load Factor	Struct Wind Area Factor	Struct. Wind Load Model	Struct. Ice Thick (in)	Struct. Ice Density (lbs/ft^3)	Pole Tip Deflection Check	Pole Tip Deflect Limit % or (m)
1	1	RULE 250B NA+	Creep RS	NA+		1.50	2.50	1.65	1.50	1.00	Pre V7 Standard	0.00	0.000	No Limit	0.00
2	1	RULE 250B NA-	Creep RS	NA-		1.50	2.50	1.65	1.50	1.00	Pre V7 Standard	0.00	0.000	No Limit	0.00
3	2	RULE 250C NA+	Creep RS	NA+		1.00	1.00	1.00	1.00	1.00	Pre V7 NESC 2002	0.00	0.000	No Limit	0.00
4	2	RULE 250C NA-	Creep RS	NA-		1.00	1.00	1.00	1.00	1.00	Pre V7 NESC 2002	0.00	0.000	No Limit	0.00
5	3	RULE 250D NA+	Creep RS	NA+		1.00	1.00	1.00	1.00	1.00	Pre V7 Standard	0.00	0.000	No Limit	0.00
6	3	RULE 250D NA-	Creep RS	NA-		1.00	1.00	1.00	1.00	1.00	Pre V7 Standard	0.00	0.000	No Limit	0.00

Structure Load Report - Pole 489S_1.txt															
7	1	250B No OLF NA+	Creep RS	NA+	1.00	1.00	1.00	1.00	1.00	Pre V7	Standard	0.00	0.000	No Limit	0.00
8	1	250B No OLF NA-	Creep RS	NA-	1.00	1.00	1.00	1.00	1.00	Pre V7	Standard	0.00	0.000	No Limit	0.00
9	12	Deflection	Creep RS	NA+	1.00	1.00	1.00	1.00	1.00	Pre V7	Standard	0.00	0.000	No Limit	0.00

Span and Wire Summary

Span azimuth is measured clockwise from structure transverse axis (0=transverse, 90=back, 270=ahead)  
 Azimuth of structure transverse axis is 184.0000 (deg) measured clockwise from North.

LC #	WC #	Load Case Description	Set No.	Phase No.	Attach. Joint Labels	---Back span---					---Ahead span---						
						Cable Name	Len. (ft)	Azi. (deg)	Horiz. Load (lbs/ft)	Vert. Tension (lbs)	Cable Name	Len. (ft)	Azi. (deg)	Horiz. Load (lbs/ft)	Vert. Tension (lbs)		
1	1	RULE 250B NA+	1	1		linnet_acsr.wir	302	92	1.43	1.83	6490	linnet_acsr.wir	268	265	1.43	1.83	6495
1	1		8	1		bittern_acsr.wir	303	92	1.95	3.87	15118	bittern_acsr.wir	267	265	1.95	3.87	15121
1	1		9	1		bittern_acsr.wir	302	89	1.95	3.87	15120	bittern_acsr.wir	267	265	1.95	3.87	15120
1	1		10	1		bittern_acsr.wir	302	88	1.95	3.87	15122	bittern_acsr.wir	267	265	1.95	3.87	15119
2	1	RULE 250B NA-	1	1		linnet_acsr.wir	302	92	1.43	1.83	6490	linnet_acsr.wir	268	265	1.43	1.83	6495
2	1		8	1		bittern_acsr.wir	303	92	1.95	3.87	15118	bittern_acsr.wir	267	265	1.95	3.87	15121
2	1		9	1		bittern_acsr.wir	302	89	1.95	3.87	15120	bittern_acsr.wir	267	265	1.95	3.87	15120
2	1		10	1		bittern_acsr.wir	302	88	1.95	3.87	15122	bittern_acsr.wir	267	265	1.95	3.87	15119
3	2	RULE 250C NA+	1	1		linnet_acsr.wir	302	92	1.71	0.46	3595	linnet_acsr.wir	268	265	1.78	0.46	3611
3	2		8	1		bittern_acsr.wir	303	92	3.14	1.43	7999	bittern_acsr.wir	267	265	3.25	1.43	8014
3	2		9	1		bittern_acsr.wir	302	89	3.10	1.43	7866	bittern_acsr.wir	267	265	3.16	1.43	7862
3	2		10	1		bittern_acsr.wir	302	88	3.06	1.43	7692	bittern_acsr.wir	267	265	3.05	1.43	7677
4	2	RULE 250C NA-	1	1		linnet_acsr.wir	302	92	1.71	0.46	3595	linnet_acsr.wir	268	265	1.78	0.46	3611
4	2		8	1		bittern_acsr.wir	303	92	3.14	1.43	7999	bittern_acsr.wir	267	265	3.25	1.43	8014
4	2		9	1		bittern_acsr.wir	302	89	3.10	1.43	7866	bittern_acsr.wir	267	265	3.16	1.43	7862
4	2		10	1		bittern_acsr.wir	302	88	3.06	1.43	7692	bittern_acsr.wir	267	265	3.05	1.43	7677
5	3	RULE 250D NA+	1	1		linnet_acsr.wir	302	92	0.93	2.60	5341	linnet_acsr.wir	268	265	0.93	2.60	5344
5	3		8	1		bittern_acsr.wir	303	92	1.14	4.35	11423	bittern_acsr.wir	267	265	1.14	4.35	11425
5	3		9	1		bittern_acsr.wir	302	89	1.14	4.35	11425	bittern_acsr.wir	267	265	1.14	4.35	11425
5	3		10	1		bittern_acsr.wir	302	88	1.14	4.35	11426	bittern_acsr.wir	267	265	1.14	4.35	11424
6	3	RULE 250D NA-	1	1		linnet_acsr.wir	302	92	0.93	2.60	5341	linnet_acsr.wir	268	265	0.93	2.60	5344
6	3		8	1		bittern_acsr.wir	303	92	1.14	4.35	11423	bittern_acsr.wir	267	265	1.14	4.35	11425
6	3		9	1		bittern_acsr.wir	302	89	1.14	4.35	11425	bittern_acsr.wir	267	265	1.14	4.35	11425
6	3		10	1		bittern_acsr.wir	302	88	1.14	4.35	11426	bittern_acsr.wir	267	265	1.14	4.35	11424
7	1	250B No OLF NA+	1	1		linnet_acsr.wir	302	92	0.57	1.22	3933	linnet_acsr.wir	268	265	0.57	1.22	3936
7	1		8	1		bittern_acsr.wir	303	92	0.78	2.58	9162	bittern_acsr.wir	267	265	0.78	2.58	9164
7	1		9	1		bittern_acsr.wir	302	89	0.78	2.58	9164	bittern_acsr.wir	267	265	0.78	2.58	9163
7	1		10	1		bittern_acsr.wir	302	88	0.78	2.58	9165	bittern_acsr.wir	267	265	0.78	2.58	9163
8	1	250B No OLF NA-	1	1		linnet_acsr.wir	302	92	0.57	1.22	3933	linnet_acsr.wir	268	265	0.57	1.22	3936
8	1		8	1		bittern_acsr.wir	303	92	0.78	2.58	9162	bittern_acsr.wir	267	265	0.78	2.58	9164
8	1		9	1		bittern_acsr.wir	302	89	0.78	2.58	9164	bittern_acsr.wir	267	265	0.78	2.58	9163
8	1		10	1		bittern_acsr.wir	302	88	0.78	2.58	9165	bittern_acsr.wir	267	265	0.78	2.58	9163
9	12	Deflection	1	1		linnet_acsr.wir	302	92	0.00	0.46	1215	linnet_acsr.wir	268	265	0.00	0.46	1215
9	12		8	1		bittern_acsr.wir	303	92	0.00	1.43	4006	bittern_acsr.wir	267	265	0.00	1.43	4006
9	12		9	1		bittern_acsr.wir	302	89	0.00	1.43	4006	bittern_acsr.wir	267	265	0.00	1.43	4006
9	12		10	1		bittern_acsr.wir	302	88	0.00	1.43	4006	bittern_acsr.wir	267	265	0.00	1.43	4006

Wire Loads In Span Coordinate System

Wire loads expressed in span coordinate system (Longitudinal axis is line connecting attach. points)  
 Note: Loads in this report do not include load from counter weights, insulator weight or insulator wind area.

LC #	WC #	Load Case Description	Set No.	Phase No.	Attach. Joint Labels	--Loads from back span--			-Loads from ahead span-			Warnings
						Vert. (lbs)	Trans. (lbs)	Long.	Vert. (lbs)	Trans. (lbs)	Long.	
1	1	RULE 250B NA+	1	1		753	218	6490	365	192	6495	
1	1		8	1		1550	297	15118	1009	262	15121	
1	1		9	1		1098	295	15120	1195	262	15120	
1	1		10	1		647	295	15122	1380	262	15119	

Structure Load Report - Pole 489S\_1.txt

2	1	RULE 250B NA-	1	1	753	-218	6490	365	-192	6495			
2	1		8	1	1550	-297	15118	1009	-262	15121			
2	1		9	1	1098	-295	15120	1195	-262	15120			
2	1		10	1	647	-295	15122	1380	-262	15119			
3	2	RULE 250C NA+	1	1	424	260	3595	151	239	3611			
3	2		8	1	840	478	7999	510	435	8014			
3	2		9	1	543	469	7866	622	423	7862			
3	2		10	1	255	462	7692	727	410	7677			
4	2	RULE 250C NA-	1	1	424	-260	3595	151	-239	3611			
4	2		8	1	840	-478	7999	510	-435	8014			
4	2		9	1	543	-469	7866	622	-423	7862			
4	2		10	1	255	-462	7692	727	-410	7677			
5	3	RULE 250D NA+	1	1	921	141	5341	481	124	5344			
5	3		8	1	1549	174	11423	1036	153	11425			
5	3		9	1	1132	173	11425	1207	153	11425			
5	3		10	1	714	172	11426	1379	153	11424			
6	3	RULE 250D NA-	1	1	921	-141	5341	481	-124	5344			
6	3		8	1	1549	-174	11423	1036	-153	11425			
6	3		9	1	1132	-173	11425	1207	-153	11425			
6	3		10	1	714	-172	11426	1379	-153	11424			
7	1	250B No OLF NA+	1	1	502	87	3933	243	77	3936			
7	1		8	1	1033	119	9162	673	105	9164			
7	1		9	1	732	118	9164	796	105	9163			
7	1		10	1	431	118	9165	920	105	9163			
8	1	250B No OLF NA-	1	1	502	-87	3933	243	-77	3936			
8	1		8	1	1033	-119	9162	673	-105	9164			
8	1		9	1	732	-118	9164	796	-105	9163			
8	1		10	1	431	-118	9165	920	-105	9163			
9	12	Deflection	1	1	190	0	1215	92	0	1215			
9	12		8	1	529	0	4006	351	0	4006			
9	12		9	1	383	0	4006	411	0	4006			
9	12		10	1	237	0	4006	471	0	4006			

Wire Loads In Structure Coordinate System

Note: Loads in this report include load from counter weights, insulator weight and insulator wind area.

LC #	WC #	Load Case Description	Set No.	Phase No.	Attach. Joint Labels	---Structure Loads---			--Loads from back span--			-Loads from ahead span-			Warnings
						Vert.	Trans.	Long.	Vert.	Trans.	Long.	Vert.	Trans.	Long.	
1	1	RULE 250B NA+	1	1		1118	-291	4	753	34	6493	365	-326	-6490	
1	1		8	1		2859	-1408	36	1700	-300	15118	1159	-1108	-15082	
1	1		9	1		2593	-660	36	1248	448	15117	1345	-1108	-15081	
1	1		10	1		2327	-209	18	797	898	15098	1530	-1107	-15080	
2	1	RULE 250B NA-	1	1		1118	-1110	22	753	-402	6481	365	-709	-6459	
2	1		8	1		2859	-2543	60	1700	-904	15094	1159	-1639	-15034	
2	1		9	1		2593	-1792	89	1248	-153	15123	1345	-1639	-15033	
2	1		10	1		2327	-1341	89	797	299	15121	1530	-1640	-15032	
3	2	RULE 250C NA+	1	1		575	109	-17	424	159	3601	151	-49	-3618	
3	2		8	1		1550	-98	-8	940	178	8012	610	-276	-8020	
3	2		9	1		1365	290	-7	643	565	7861	722	-274	-7868	
3	2		10	1		1182	512	-15	355	784	7668	827	-272	-7683	
4	2	RULE 250C NA-	1	1		575	-887	7	424	-362	3587	151	-525	-3580	
4	2		8	1		1550	-1995	33	940	-815	7974	610	-1180	-7941	
4	2		9	1		1365	-1565	79	643	-411	7870	722	-1154	-7791	
4	2		10	1		1182	-1298	96	355	-175	7704	827	-1123	-7608	
5	3	RULE 250D NA+	1	1		1402	-311	6	921	-10	5343	481	-301	-5337	
5	3		8	1		2785	-1163	30	1649	-279	11421	1136	-884	-11392	
5	3		9	1		2539	-597	32	1232	286	11423	1307	-883	-11391	
5	3		10	1		2293	-257	19	814	627	11410	1479	-883	-11391	
6	3	RULE 250D NA-	1	1		1402	-842	18	921	-292	5335	481	-550	-5317	
6	3		8	1		2785	-1822	44	1649	-630	11407	1136	-1192	-11364	
6	3		9	1		2539	-1255	63	1232	-63	11426	1307	-1192	-11363	
6	3		10	1		2293	-914	61	814	278	11423	1479	-1192	-11363	



Structure Load Report - Pole 489S\_1.txt

7	1	250B No OLF NA+	1	1	745	-261	4	502	-24	3934	243	-237	-3930
7	1		8	1	1906	-970	24	1133	-244	9160	773	-726	-9136
7	1		9	1	1729	-516	27	832	210	9162	896	-726	-9135
7	1		10	1	1551	-243	18	531	483	9153	1020	-726	-9134
8	1	250B No OLF NA-	1	1	745	-588	11	502	-198	3929	243	-390	-3918
8	1		8	1	1906	-1424	34	1133	-485	9150	773	-939	-9117
8	1		9	1	1729	-969	49	832	-31	9165	896	-939	-9116
8	1		10	1	1551	-696	47	531	243	9162	1020	-939	-9115
9	12	Deflection	1	1	282	-131	3	190	-34	1214	92	-97	-1211
9	12		8	1	1080	-523	13	629	-159	4003	451	-364	-3989
9	12		9	1	994	-325	16	483	39	4006	511	-364	-3989
9	12		10	1	908	-205	13	337	159	4003	571	-364	-3989

Wire Load Induced Ground Line Moments For Single Pole Centered At Structure Origin


Note: not applicable to guyed structures or frames. These approximate values do not include nonlinear (P-delta) effects or wind on pole. ??

LC #	WC #	Load Case Description	Vert. Load (kips)	Trans. Shear (kips)	Long. Shear (kips)	Resultant Shear (kips)	Trans. Moment (ft-k)	Long. Moment (ft-k)	Resultant Moment (ft-k)
1	1	RULE 250B NA+	8.897	-2.568	0.093	2.569	-267.325	7.546	267.431
2	1	RULE 250B NA-	8.897	-6.786	0.260	6.791	-610.303	20.326	610.641
3	2	RULE 250C NA+	4.671	0.814	-0.047	0.815	32.916	-3.852	33.141
4	2	RULE 250C NA-	4.671	-5.746	0.215	5.750	-496.651	16.168	496.914
5	3	RULE 250D NA+	9.019	-2.327	0.087	2.329	-245.302	6.974	245.401
6	3	RULE 250D NA-	9.019	-4.834	0.185	4.838	-449.897	14.553	450.132
7	1	250B No OLF NA+	5.931	-1.991	0.074	1.992	-200.316	5.890	200.403
8	1	250B No OLF NA-	5.931	-3.678	0.140	3.681	-337.507	11.002	337.687
9	12	Deflection	3.264	-1.185	0.047	1.186	-116.584	3.688	116.643

Basic factored design wind pressure on structure

LC #	WC #	Load Case Description	Trans. Wind Press. (psf)	Long. Wind Press. (psf)	Notes
1	1	RULE 250B NA+	10.0	0.0	
2	1	RULE 250B NA-	-10.0	-0.0	
3	2	RULE 250C NA+	31.2	0.0	Wind adjusted for terrain category 'C' and hgt. 63.33 (ft) (larger of hgt*2/3 and 6.67m)
4	2	RULE 250C NA-	-31.2	-0.0	Wind adjusted for terrain category 'C' and hgt. 63.33 (ft) (larger of hgt*2/3 and 6.67m)
5	3	RULE 250D NA+	4.1	0.0	
6	3	RULE 250D NA-	-4.1	-0.0	
7	1	250B No OLF NA+	4.0	0.0	
8	1	250B No OLF NA-	-4.0	-0.0	
9	12	Deflection	0.0	0.0	

No structure image available (requires PLS-POLE or TOWER structure)




1
**TOWER & MAST ELEVATION**  
 EL-1      SCALE: NOT TO SCALE

REVISIONS		
00	11/22/16	ISSUED FOR REVIEW


**CEN TEK** engineering  
 Centered on Solutions™  
 www.CentekEng.com  
 (203) 488-0580  
 (203) 488-8587 Fax  
 63-2 North Branford Road, Branford, CT 06405

CT5013  
 EVERSOURCE 489S  
 310 ROWAYTON  
 NORWALK, CT 06853

PROJECT NO:	16071.40
DRAWN BY:	TJL
CHECKED BY:	CFC
SCALE:	AS NOTED
DATE:	11/22/16



TOWER AND MAST  
 ELEVATION  
**EL-1**  
 DWG. 1 OF 2



1
FEEDLINE PLAN - TOWER  
FP-1
SCALE: NOT TO SCALE

REVISIONS		
00	11/22/16	ISSUED FOR REVIEW

**CEN TEK** engineering  
 Centered on Solutions™  
www.CentekEng.com  
 (203) 488-0580  
 (203) 488-8587 Fax  
 63-2 North Branford Road, Branford, CT 06405

CT5013  
 EVERSOURCE 489S  
  
 310 ROWAYTON  
 NORWALK, CT 06853

PROJECT NO:	16071.40
DRAWN BY:	TJL
CHECKED BY:	CFC
SCALE:	AS NOTED
DATE:	11/22/16



FEEDLINE  
 PLAN  
FP-1  
 DWG. 2 OF 2



**Development of Design Heights, Exposure Coefficients, and Velocity Pressures Per TIA-222-G**

**Wind Speeds**

Basic Wind Speed  $V := 93$  mph (User Input - 2016 CSBC Appendix N)  
 Basic Wind Speed with Ice  $V_i := 50$  mph (User Input per Annex B of TIA-222-G)

**Input**

Structure Type = Structure\_Type := Pole (User Input)  
 Structure Category = SC := III (User Input)  
 Exposure Category = Exp := C (User Input)  
 Structure Height = h := 95 ft (User Input)  
 Height to Center of Antennas =  $z_{AT\&T} := 103$  ft (User Input)  
 Radial Ice Thickness =  $t_i := 0.75$  in (User Input per Annex B of TIA-222-G)  
 Radial Ice Density =  $\rho_d := 56.00$  pcf (User Input)  
 Topographic Factor =  $K_{zt} := 1.0$  (User Input)  
 $K_a := 1.0$  (User Input)  
 Gust Response Factor =  $G_H := 1.35$  (User Input)

**Output**

Wind Direction Probability Factor =  $K_d := \begin{cases} 0.95 & \text{if Structure\_Type} = \text{Pole} \\ 0.85 & \text{if Structure\_Type} = \text{Lattice} \end{cases} = 0.95$  (Per Table 2-2 of TIA-222-G)

Importance Factors =  $I_{Wind} := \begin{cases} 0.87 & \text{if SC} = 1 \\ 1.00 & \text{if SC} = 2 \\ 1.15 & \text{if SC} = 3 \end{cases} = 1.15$  (Per Table 2-3 of TIA-222-G)

$I_{Wind\_w\_Ice} := \begin{cases} 0 & \text{if SC} = 1 \\ 1.00 & \text{if SC} = 2 \\ 1.00 & \text{if SC} = 3 \end{cases} = 1$

$I_{ice} := \begin{cases} 0 & \text{if SC} = 1 \\ 1.00 & \text{if SC} = 2 \\ 1.25 & \text{if SC} = 3 \end{cases} = 1.25$

$K_{iz} := \left( \frac{z_{AT\&T}}{33} \right)^{0.1} = 1.121$

$t_{iz} := 2.0 \cdot t_i \cdot I_{ice} \cdot K_{iz} \cdot K_{zt}^{0.35} = 2.101$

Velocity Pressure Coefficient =  $K_{z_{AT\&T}} := 2.01 \left( \frac{z_{AT\&T}}{z_g} \right)^{\frac{2}{\alpha}} = 1.274$

Velocity Pressure w/o Ice =  $q_{z_{AT\&T}} := 0.00256 \cdot K_d \cdot K_{z_{AT\&T}} \cdot K_{zt} \cdot V^2 \cdot I_{Wind} = 30.806$

Velocity Pressure with Ice =  $q_{ice,AT\&T} := 0.00256 \cdot K_d \cdot K_{z_{AT\&T}} \cdot K_{zt} \cdot V_i^2 \cdot I_{Wind\_w\_Ice} = 7.743$

**Development of Wind & Ice Load on Mast**

**Mast Data:**

(Pipe 5" Sch 80)	(User Input)
Mast Shape = Round	(User Input)
Mast Diameter = $D_{mast} := 5.56$ in	(User Input)
Mast Length = $L_{mast} := 19$ ft	(User Input)
Mast Thickness = $t_{mast} := 0.375$ in	(User Input)
Mast Aspect Ratio = $A_{r_{mast}} := \frac{12L_{mast}}{D_{mast}} = 41.0$	
Mast Force Coefficient = $C_{a_{mast}} = 1.2$	

**Wind Load (without ice)**

Mast Projected Surface Area =  $A_{mast} := \frac{D_{mast}}{12} = 0.463$  sf/ft

Total Mast Wind Force =  $q_{z_{AT\&T}} G_H C_{a_{mast}} A_{mast} = 23$  plf **BLC 5**

**Wind Load (with ice)**

Mast Projected Surface Area w/ Ice =  $A_{ICE_{mast}} := \frac{(D_{mast} + 2 \cdot t_{iz})}{12} = 0.814$  sf/ft

Total Mast Wind Force w/ Ice =  $q_{z_{ice,AT\&T}} G_H C_{a_{mast}} A_{ICE_{mast}} = 10$  plf **BLC 4**

**Gravity Loads (without ice)**

Weight of the mast = Self Weight (Computed internally by Risa-3D) plf **BLC 1**

**Gravity Loads (ice only)**

Ice Area per Linear Foot =  $A_{i_{mast}} := \frac{\pi}{4} [(D_{mast} + t_{iz} \cdot 2)^2 - D_{mast}^2] = 50.6$  sq in

Weight of Ice on Mast =  $W_{ICE_{mast}} := Id \cdot \frac{A_{i_{mast}}}{144} = 20$  plf **BLC 3**

**Development of Wind & Ice Load on Antennas**

**Antenna Data:**

Antenna Model =	CCI HPA-65F-BUU-H2	
Antenna Shape =	Flat	(User Input)
Antenna Height =	$L_{ant} := 21.4$	in (User Input)
Antenna Width =	$W_{ant} := 14.4$	in (User Input)
Antenna Thickness =	$T_{ant} := 7.3$	in (User Input)
Antenna Weight =	$WT_{ant} := 15$	lbs (User Input)
Number of Antennas =	$N_{ant} := 3$	(User Input)
Antenna Aspect Ratio =	$Ar_{ant} := \frac{L_{ant}}{W_{ant}} = 1.5$	
Antenna Force Coefficient =	$Ca_{ant} = 1.2$	

**Wind Load (without ice)**

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot W_{ant}}{144} = 2.1$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 6.4$	sf
<b>Total Antenna Wind Force =</b>	<b><math>F_{ant} := qZ_{AT\&amp;T} \cdot G_H \cdot Ca_{ant} \cdot K_a \cdot A_{ant} = 320</math></b>	lbs <b>BLC 5</b>

**Wind Load (with ice)**

Surface Area for One Antenna w/ Ice =	$SA_{ICEant} := \frac{(L_{ant} + 2 \cdot t_{iz}) \cdot (W_{ant} + 2 \cdot t_{iz})}{144} = 3.3$	sf
Antenna Projected Surface Area w/ Ice =	$A_{ICEant} := SA_{ICEant} \cdot N_{ant} = 9.9$	sf
<b>Total Antenna Wind Force w/ Ice =</b>	<b><math>F_{i_{ant}} := qZ_{ice} \cdot AT\&amp;T \cdot G_H \cdot Ca_{ant} \cdot K_a \cdot A_{ICEant} = 124</math></b>	lbs <b>BLC 4</b>

**Gravity Load (without ice)**

<b>Weight of All Antennas =</b>	<b><math>WT_{ant} \cdot N_{ant} = 45</math></b>	lbs <b>BLC 2</b>
---------------------------------	---	------------------

**Gravity Loads (ice only)**

Volume of Each Antenna =	$V_{ant} := L_{ant} \cdot W_{ant} \cdot T_{ant} = 2250$	cu in
Volume of Ice on Each Antenna =	$V_{ice} := (L_{ant} + 2 \cdot t_{iz}) \cdot (W_{ant} + 2 \cdot t_{iz}) \cdot (T_{ant} + 2 \cdot t_{iz}) - V_{ant} = 3228$	cu in
Weight of Ice on Each Antenna =	$W_{ICEant} := \frac{V_{ice}}{1728} \cdot \rho_d = 105$	lbs
<b>Weight of Ice on All Antennas =</b>	<b><math>W_{ICEant} \cdot N_{ant} = 314</math></b>	lbs <b>BLC 3</b>

**Development of Wind & Ice Load on TMA's**

**TMA Data:**

TMA Model =	Kaelus TMA2117F00V1-1	
TMA Shape =	Flat	(User Input)
TMA Height =	$L_{TMA} := 8.46$	in (User Input)
TMA Width =	$W_{TMA} := 11.81$	in (User Input)
TMA Thickness =	$T_{TMA} := 4.21$	in (User Input)
TMA Weight =	$W_{TMA} := 18$	lbs (User Input)
Number of TMA's =	$N_{TMA} := 6$	(User Input)
TMA Aspect Ratio =	$Ar_{TMA} := \frac{L_{TMA}}{T_{TMA}} = 2$	
TMA Force Coefficient =	$Ca_{TMA} = 1.2$	

**Wind Load (without ice)**

Surface Area for One TMA =	$SA_{TMA} := \frac{L_{TMA} \cdot W_{TMA}}{144} = 0.7$	sf
TMA Projected Surface Area =	$A_{TMA} := SA_{TMA} \cdot N_{TMA} = 4.2$	sf
<b>Total TMA Wind Force =</b>	<b><math>F_{TMA} := qz_{AT\&amp;T} \cdot G_H \cdot Ca_{TMA} \cdot K_a \cdot A_{TMA} = 208</math></b>	lbs <b>BLC 5</b>

**Wind Load (with ice)**

Surface Area for One TMA w/ Ice =	$SA_{ICETMA} := \frac{(L_{TMA} + 2 \cdot t_{iz}) \cdot (W_{TMA} + 2 \cdot t_{iz})}{144} = 1.4$	sf
TMA Projected Surface Area w/ Ice =	$A_{ICETMA} := SA_{ICETMA} \cdot N_{TMA} = 8.4$	sf
<b>Total TMA Wind Force w/ Ice =</b>	<b><math>F_{i_{TMA}} := qz_{ice} \cdot AT\&amp;T \cdot G_H \cdot Ca_{TMA} \cdot K_a \cdot A_{ICETMA} = 106</math></b>	lbs <b>BLC 4</b>

**Gravity Load (without ice)**

<b>Weight of All TMA's =</b>	<b><math>W_{TMA} \cdot N_{TMA} = 108</math></b>	lbs <b>BLC 2</b>
------------------------------	---	------------------

**Gravity Load (ice only)**

Volume of Each TMA =	$V_{TMA} := L_{TMA} \cdot W_{TMA} \cdot T_{TMA} = 421$	cu in
Volume of Ice on Each TMA =	$V_{ice} := (L_{TMA} + 2 \cdot t_{iz})(W_{TMA} + 2 \cdot t_{iz})(T_{TMA} + 2 \cdot t_{iz}) - V_{TMA} = 1 \times 10^3$	cu in
Weight of Ice on Each TMA =	$W_{ICETMA} := \frac{V_{ice}}{1728} \cdot \rho_d = 42$	lbs
<b>Weight of Ice on All TMA's</b>	<b><math>W_{ICETMA} \cdot N_{TMA} = 250</math></b>	lbs <b>BLC 3</b>



**Development of Wind & Ice Load on Antenna Mounts**

**Mount Data:**

Mount Type =	Pipe Mounts	
Mount Shape =	Round	(User Input)
Pipe Mount Length =	$L_{mnt} := 60$	in (User Input)
2 inch Pipe Mount Linear Weight =	$W_{mnt} := 3.66$	plf (User Input)
Pipe Mount Outside Diameter =	$D_{mnt} := 2.375$	in (User Input)
Number of Mounting Pipes =	$N_{mnt} := 3$	(User Input)
Mount Bracket Weight =	$W_{b,mnt} := 101$	lbs (User Input)
Mount Aspect Ratio =	$Ar_{mnt} := \frac{L_{mnt}}{D_{mnt}} = 25$	
Mount Force Coefficient =	$Ca_{mnt} := 1.2$	

**Wind Load (without ice)**

*Assumes Mount is Shielded by Antenna*

Mount Projected Surface Area =  $A_{mnt} := 0.0$  sf

Total Mount Wind Force =  $F_{mnt} := qz_{AT\&T} \cdot G_H \cdot Ca_{mnt} \cdot A_{mnt} = 0$  lbs **BLC 5**

**Wind Load (with ice)**

*Assumes Mount is Shielded by Antenna*

Mount Projected Surface Area w/ Ice =  $A_{ICEmnt} := 0.0$  sf

Total Mount Wind Force =  $F_{mnt} := qz_{ice,AT\&T} \cdot G_H \cdot Ca_{mnt} \cdot A_{ICEmnt} = 0$  lbs **BLC 4**

**Gravity Loads (without ice)**

Weight Each Pipe Mount =  $WT_{mnt} := W_{mnt} \cdot \frac{L_{mnt}}{12} = 18$  lbs

Weight of All Mounts =  $WT_{mnt} \cdot N_{mnt} + W_{b,mnt} = 156$  lbs **BLC 2**

**Gravity Loads (ice only)**

Volume of Each Pipe =  $V_{mnt} := \frac{\pi}{4} \cdot D_{mnt}^2 \cdot L_{mnt} = 266$  cu in

Volume of Ice on Each Pipe =  $V_{ice} := \left[ \frac{\pi}{4} \cdot \left[ (D_{mnt} + 2 \cdot t_{iz})^2 \right] \cdot (L_{mnt} + 2 \cdot t_{iz}) \right] - V_{mnt} = 2 \times 10^3$  cu in

Weight of Ice each mount (incl. hardware) =  $W_{ICEmnt} := \frac{V_{ice}}{1728} \cdot \rho_d = 62$  lbs

Weight of Ice on All Mounts =  $W_{ICEmnt} \cdot N_{mnt} + 30 = 216$  lbs **BLC 3**

**Development of Wind & Ice Load on Coax Cables**

**Coax Cable Data:**

Coax Type =	HELIX 1-5/8"	
Shape =	Round	(User Input)
Coax Outside Diameter =	$D_{coax} := 1.98$	in (User Input)
Coax Cable Length =	$L_{coax} := 11$	ft (User Input)
Weight of Coax per foot =	$Wt_{coax} := 1.04$	plf (User Input)
Total Number of Coax =	$N_{coax} := 12$	(User Input)
No. of Coax Projecting Outside Face of Mast =	$NP_{coax} := 4$	(User Input)

Coax aspect ratio,  $Ar_{coax} := \frac{(L_{coax} \cdot 12)}{D_{coax}} = 66.7$

Coax Cable Force Factor Coefficient =  $Ca_{coax} = 1.2$

**Wind Load (without ice)**

Coax projected surface area =  $A_{coax} := \frac{(NP_{coax} \cdot D_{coax})}{12} = 0.7$  sf/ft

Total Coax Wind Force =  $F_{coax} := Ca_{coax} \cdot q_{zAT\&T} \cdot G_H \cdot A_{coax} = 33$  plf **BLC 5**

**Wind Load (with ice)**

Coax projected surface area w/ Ice =  $AICE_{coax} := \frac{(NP_{coax} \cdot D_{coax} + 2 \cdot t_{iz})}{12} = 1$  sf/ft

Total Coax Wind Force w/ Ice =  $F_{i_{coax}} := Ca_{coax} \cdot q_{zice} \cdot AT\&T \cdot G_H \cdot AICE_{coax} = 13$  plf **BLC 4**

**Gravity Loads (without ice)**

Weight of all cables w/o ice  $WT_{coax} := Wt_{coax} \cdot N_{coax} = 12$  plf **BLC 2**

**Gravity Loads (ice only)**

Ice Area per Linear Foot =  $Ai_{coax} := \frac{\pi}{4} [(D_{coax} + 2 \cdot t_{iz})^2 - D_{coax}^2] = 26.9$  sq in

Ice Weight All Coax per foot =  $WT_{i_{coax}} := N_{coax} \cdot Id \cdot \frac{Ai_{coax}}{144} = 126$  plf **BLC 3**

**CEN TEK engineering, INC.**  
**Consulting Engineers**  
63-2 North Branford Road  
Branford, CT 06405

Subject: **Analysis of TIA/EIA Wind and Ice Loads for Analysis of Mast Only**  
**Tabulated Load Cases**  
Location: **Norwalk, CT**

Ph. 203-488-0580 / Fax. 203-488-8587

Date: 11/22/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16071.40

Load Case	Description
1	Self Weight (Mast)
2	Weight of Appurtenances
3	Weight of Ice Only
4	TIA Wind with Ice
5	TIA Wind

Footnotes:

**CENTEK engineering, INC.**  
**Consulting Engineers**  
 63-2 North Branford Road  
 Branford, CT 06405  
 Ph. 203-488-0580 / Fax. 203-488-8587

Subject: **Analysis of TIA/EIA Wind and Ice Loads for Analysis of Mast Only**  
**Load Combinations Table**

Location: **Norwalk, CT**

Date: 11/22/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16071.40

Load Combination	Description	Envelope Wind													
		Soultion	Factor	P-Delta	BLC	Factor	BLC	Factor	BLC	Factor	BLC	Factor	BLC	Factor	BLC
1	1.2D + 1.6W	1	1	Y	1	1.2	2	1.2	5	1.6					
2	0.9D + 1.6W	1	1	Y	1	0.9	2	0.9	5	1.6					
3	1.2D + 1.0Di + 1.0Wi	1	1	Y	1	1.2	2	1.2	3	1.0	4	1.0			

Footnotes:  
 BLC = Basic Load Case  
 D = Dead Load  
 Di = Dead Load of Ice  
 W = Wind Load  
 Wi = Wind Load w/ Ice





**Global**

Display Sections for Member Calcs	5
Max Internal Sections for Member Calcs	97
Include Shear Deformation?	Yes
Include Warping?	Yes
Trans Load Btwn Intersecting Wood Wall?	Yes
Increase Nailing Capacity for Wind?	Yes
Area Load Mesh (in^2)	144
Merge Tolerance (in)	.12
P-Delta Analysis Tolerance	0.50%
Include P-Delta for Walls?	Yes
Automaticly Iterate Stiffness for Walls?	No
Maximum Iteration Number for Wall Stiffness	3
Gravity Acceleration (ft/sec^2)	32.2
Wall Mesh Size (in)	12
Eigensolution Convergence Tol. (1.E-)	4
Vertical Axis	Y
Global Member Orientation Plane	XZ
Static Solver	Sparse Accelerated
Dynamic Solver	Accelerated Solver

Hot Rolled Steel Code	AISC 14th(360-10): LRFD
Adjust Stiffness?	Yes(Iterative)
RISAConnection Code	AISC 14th(360-10): ASD
Cold Formed Steel Code	AISI 1999: ASD
Wood Code	AF&PA NDS-97: ASD
Wood Temperature	< 100F
Concrete Code	ACI 318-02
Masonry Code	ACI 530-05: ASD
Aluminum Code	AA ADM1-05: ASD - Building

Number of Shear Regions	4
Region Spacing Increment (in)	4
Biaxial Column Method	PCA Load Contour
Parne Beta Factor (PCA)	.65
Concrete Stress Block	Rectangular
Use Cracked Sections?	Yes
Use Cracked Sections Slab?	Yes
Bad Framing Warnings?	No
Unused Force Warnings?	Yes
Min 1 Bar Diam. Spacing?	No
Concrete Rebar Set	REBAR_SET_ASTMA615
Min % Steel for Column	1
Max % Steel for Column	8



**Global, Continued**

Seismic Code	UBC 1997
Seismic Base Elevation (ft)	Not Entered
Add Base Weight?	No
Ct Z	.035
Ct X	.035
T Z (sec)	Not Entered
T X (sec)	Not Entered
R Z	8.5
R X	8.5
Ca	.36
Cv	.54
Nv	1
Occupancy Category	4
Seismic Zone	3
Seismic Detailing Code	ASCE 7-05
Om Z	1
Om X	1
Rho Z	1
Rho X	1

Footing Overturning Safety Factor	1.5
Check Concrete Bearing	No
Footing Concrete Weight (k/ft^3)	0
Footing Concrete f'c (ksi)	3
Footing Concrete Ec (ksi)	4000
Lamda	1
Footing Steel fy (ksi)	60
Minimum Steel	0.0018
Maximum Steel	0.0075
Footing Top Bar	#3
Footing Top Bar Cover (in)	3.5
Footing Bottom Bar	#3
Footing Bottom Bar Cover (in)	3.5
Pedestal Bar	#3
Pedestal Bar Cover (in)	1.5
Pedestal Ties	#3

**Hot Rolled Steel Properties**

	Label	E [ksi]	G [ksi]	Nu	Therm (\1...	Density[k/ft^3]	Yield[ksi]	Ry	Fu[ksi]	Rt
1	A36 Gr.36	29000	11154	.3	.65	.49	36	1.5	58	1.2
2	A572 Gr.50	29000	11154	.3	.65	.49	50	1.1	58	1.2
3	A992	29000	11154	.3	.65	.49	50	1.1	58	1.2
4	A500 Gr.42	29000	11154	.3	.65	.49	42	1.3	58	1.1
5	A500 Gr.46	29000	11154	.3	.65	.49	46	1.2	58	1.1
6	A53 Gr. B	29000	11154	.3	.65	.49	35	1.5	58	1.2



### Hot Rolled Steel Design Parameters

	Label	Shape	Lengt...	Lbyy[ft]	Lbzz[ft]	Lcomp t...	Lcomp b...	L-torqu...	Kyy	Kzz	Cb	Function
1	M1	Mast	19									Lateral

### Hot Rolled Steel Section Sets

	Label	Shape	Type	Design List	Material	Design ...	A [in2]	Iyy [in4]	Izz [in4]	J [in4]
1	Mast	PIPE 5.0X	Beam	Pipe	A53 Gr. B	Typical	5.73	19.5	19.5	39

### Member Primary Data

	Label	I Joint	J Joint	K Joint	Rotate(d...	Section/Shape	Type	Design List	Material	Design R...
1	M1	BOTTO...	TOP-M...			Mast	Beam	Pipe	A53 Gr. B	Typical

### Joint Coordinates and Temperatures

	Label	X [ft]	Y [ft]	Z [ft]	Temp [F]	Detach From ...
1	BOTTOM-MAST	0	0	0	0	
2	BOTTOM-BRACE	0	1	0	0	
3	TOP-BRACE	0	6	0	0	
4	TOP-MAST	0	19	0	0	

### Joint Boundary Conditions

	Joint Label	X [k/in]	Y [k/in]	Z [k/in]	X Rot.[k-ft/rad]	Y Rot.[k-ft/rad]	Z Rot.[k-ft/rad]	Footing
1	BOTTOM-MAST							
2	BOTTOM-BRACE	Reaction	Reaction	Reaction		Reaction		
3	TOP-BRACE	Reaction	Reaction	Reaction		Reaction		

### Member Point Loads (BLC 2 : Weight of Appurtenances)

	Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	Y	-.045	16
2	M1	Y	-.108	16
3	M1	Y	-.156	16

### Member Point Loads (BLC 3 : Weight of Ice Only)

	Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	Y	-.314	16
2	M1	Y	-.25	16
3	M1	Y	-.216	16

### Member Point Loads (BLC 4 : TIA Wind with Ice)

	Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	X	.124	16
2	M1	X	.106	16

### Member Point Loads (BLC 5 : TIA Wind)

	Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	X	.32	16



**Member Point Loads (BLC 5 : TIA Wind) (Continued)**

	Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
2	M1	X	.208	16

**Joint Loads and Enforced Displacements**

Joint Label	L,D,M	Direction	Magnitude[(k,k-ft), (in,rad), (k*s^2/ft, k*s^2*ft)]
No Data to Print ...			

**Member Distributed Loads (BLC 2 : Weight of Appurtenances)**

	Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1	M1	Y	-.012	-.012	0	0

**Member Distributed Loads (BLC 3 : Weight of Ice Only)**

	Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1	M1	Y	-.02	-.02	0	0
2	M1	Y	-.126	-.126	0	0

**Member Distributed Loads (BLC 4 : TIA Wind with Ice)**

	Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1	M1	X	.01	.01	0	0
2	M1	X	.013	.013	0	0

**Member Distributed Loads (BLC 5 : TIA Wind)**

	Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1	M1	X	.023	.023	0	0
2	M1	X	.033	.033	0	0

**Basic Load Cases**

	BLC Description	Category	X Gra...	Y Gravity	Z Gra...	Joint	Point	Distrib..	Area(... Surfa...
1	Self Weight	None		-1					
2	Weight of Appurtenances	None					3	1	
3	Weight of Ice Only	None					3	2	
4	TIA Wind with Ice	None					2	2	
5	TIA Wind	None					2	2	

**Load Combinations**

	Description	Sol...	PDelta	SR..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..
1	1.2D + 1.6W	Yes	Y		1	1.2	2	1.2	5	1.6			
2	0.9D + 1.6W	Yes	Y		1	.9	2	.9	5	1.6			
3	1.2D + 1.0Di + 1.0Wi	Yes	Y		1	1.2	2	1.2	3	1	4	1	





### Envelope Member Section Forces

Member	Sec	Axial[k]	LC	y Shear[k]	LC	z Shear[k]	LC Torqu...	LC y-y Mo...	LC z-z Mo...	LC					
1	M1	1	max	0	1	0	3	0	1	0	1	0	1	0	1
2			min	0	1	0	2	0	1	0	1	0	1	0	1
3		2	max	-.035	2	-.909	3	0	1	0	1	0	1	11.927	1
4			min	-.23	3	-3.337	1	0	1	0	1	0	1	3.257	3
5		3	max	2.897	3	1.707	1	0	1	0	1	0	1	9.643	1
6			min	.547	2	.461	3	0	1	0	1	0	1	2.656	3
7		4	max	2.024	3	1.282	1	0	1	0	1	0	1	2.544	1
8			min	.413	2	.352	3	0	1	0	1	0	1	.723	3
9		5	max	0	1	.013	3	0	1	0	1	0	1	0	1
10			min	0	1	.009	2	0	1	0	1	0	1	0	1

### Envelope Member Section Stresses

Member	Sec	Axial[kpsi]	LC	y Shear[...]	LC	z Shear[...]	LC	y-Top[kpsi]	LC	y-Bot[kpsi]	LC	z-Top[kpsi]	LC	z-Bot[kpsi]	LC
1	M1	1	max	0	1	0	3	0	1	0	1	0	1	0	1
2			min	0	1	0	2	0	1	0	1	0	1	0	1
3		2	max	-.006	2	-.317	3	0	1	-5.573	3	20.405	1	0	1
4			min	-.04	3	-1.165	1	0	1	-20.405	1	5.573	3	0	1
5		3	max	.506	3	.596	1	0	1	-4.543	3	16.498	1	0	1
6			min	.096	2	.161	3	0	1	-16.498	1	4.543	3	0	1
7		4	max	.353	3	.447	1	0	1	-1.237	3	4.352	1	0	1
8			min	.072	2	.123	3	0	1	-4.352	1	1.237	3	0	1
9		5	max	0	1	.005	3	0	1	0	1	0	1	0	1
10			min	0	1	.003	2	0	1	0	1	0	1	0	1

### Envelope Joint Reactions

Joint	X [k]	LC	Y [k]	LC	Z [k]	LC	MX [k-ft]	LC	MY [k-ft]	LC	MZ [k-ft]	LC
1	BOTTOM-BR...	max	2.911	1	.643	3	0	1	0	1	0	1
2		min	.799	3	.099	2	0	1	0	1	0	1
3	TOP-BRACE	max	-1.466	3	4	3	0	1	0	1	0	1
4		min	-5.458	1	.717	2	0	1	0	1	0	1
5	Totals:	max	-.667	3	4.643	3	0	1				
6		min	-2.547	2	.817	2	0	1				

### Envelope Joint Displacements

Joint	X [in]	LC	Y [in]	LC	Z [in]	LC	X Rotatio...	LC	Y Rotatio...	LC	Z Rotation...	LC
1	BOTTOM-MA...	max	.049	1	0	2	0	1	0	1	0	1
2		min	.013	3	0	3	0	1	0	1	0	1
3	BOTTOM-BR...	max	0	3	0	2	0	1	0	1	0	1
4		min	0	1	0	3	0	1	0	1	0	1
5	TOP-BRACE	max	0	1	0	2	0	1	0	1	0	1
6		min	0	3	0	3	0	1	0	1	0	1
7	TOP-MAST	max	4.151	1	0	2	0	1	0	1	0	1
8		min	1.14	3	-.002	3	0	1	0	1	0	1



Company : CENTEK Engineering, INC.  
 Designer : tjf, cfc  
 Job Number : 16071.40 /AT&T CT5013  
 Model Name : Structure # 489S Mast

Nov 22, 2016

Checked By: \_\_\_\_\_

**Envelope AISC 14th(360-10): LRFD Steel Code Checks**

Member	Shape	Code Check	Loc...	LC	Sh...	Loc[ft]	Dir	LC	phi*Pn...	phi*...	phi*...	phi*...	Eqn
1	M1	PIPE_5.0X	.643	6.135	1	.064	5.938	1	82.589	180...	24.9...	24.9...	H1...



Company : CENTEK Engineering, INC.  
Designer : tjf, cfc  
Job Number : 16071.40 /AT&T CT5013  
Model Name : Structure # 489S Mast

Nov 22, 2016

Checked By: \_\_\_\_\_

### Joint Reactions

	LC	Joint Label	X [k]	Y [k]	Z [k]	MX [k-ft]	MY [k-ft]	MZ [k-ft]
1	1	BOTTOM-BRACE	2.911	.132	0	0	0	0
2	1	TOP-BRACE	-5.458	.957	0	0	0	0
3	1	Totals:	-2.547	1.089	0			
4	1	COG (ft):	X: 0	Y: 11.713	Z: 0			



Company : CENTEK Engineering, INC.  
Designer : tjf, cfc  
Job Number : 16071.40 /AT&T CT5013  
Model Name : Structure # 489S Mast

Nov 22, 2016

Checked By: \_\_\_\_\_

### Joint Reactions

	LC	Joint Label	X [k]	Y [k]	Z [k]	MX [k-ft]	MY [k-ft]	MZ [k-ft]
1	2	BOTTOM-BRACE	2.904	.099	0	0	0	0
2	2	TOP-BRACE	-5.451	.717	0	0	0	0
3	2	Totals:	-2.547	.817	0			
4	2	COG (ft):	X: 0	Y: 11.713	Z: 0			



Company : CENTEK Engineering, INC.  
Designer : tjf, cfc  
Job Number : 16071.40 /AT&T CT5013  
Model Name : Structure # 489S Mast


Nov 22, 2016

Checked By: \_\_\_\_\_


### Joint Reactions

	LC	Joint Label	X [k]	Y [k]	Z [k]	MX [k-ft]	MY [k-ft]	MZ [k-ft]
1	3	BOTTOM-BRACE	.799	.643	0	0	0	0
2	3	TOP-BRACE	-1.466	4	0	0	0	0
3	3	Totals:	-.667	4.643	0			
4	3	COG (ft):	X: 0	Y: 11.111	Z: 0			







Code Check	
Black	No Calc
Red	> 1.0
Purple	.90-1.0
Green	.75-.90
Cyan	.50-.75
Blue	0-.50



CENTEK Engineering, INC.  
tjl, cfc  
16071.40 /AT&T CT5013


Structure # 489S Mast  
Unity Check

Nov 22, 2016 at 8:42 AM  
TIA.r3d



Loads: LC 1, 1.2D + 1.6W

CENTEK Engineering, INC.	Structure # 489S Mast LC #1 Loads	
tjl, cfc		Nov 22, 2016 at 8:42 AM
16071.40 /AT&T CT5013		TIA.r3d



Code Check	
Black	No Calc
Red	> 1.0
Magenta	.90-1.0
Green	.75-.90
Cyan	.50-.75
Blue	0-.50

TOP-MAST

TOP-BRACE  
1  
-5.5

2.9  
BOTTOM-BRACE  
0.1

BOTTOM-MAST

CEN TEK Engineering, INC.



tjl, cfc

16071.40 /AT&T CT5013

Structure # 489S Mast  
LC #1 Reactions and Deflected Shape


Nov 22, 2016 at 8:43 AM

TIA.r3d



Loads: LC 2, 0.9D + 1.6W

CENTEK Engineering, INC.	Structure # 489S Mast LC #2 Loads	Nov 22, 2016 at 8:42 AM
tjl, cfc		TIA.r3d
16071.40 /AT&T CT5013		



Code Check	
Black	No Calc
Red	> 1.0
Magenta	.90-1.0
Green	.75-.90
Cyan	.50-.75
Blue	0-.50

TOP-MAST

TOP-BRACE  
0.7 -5.5

BOTTOM-BRACE  
2.9 0.1

BOTTOM-MAST

CEN TEK Engineering, INC.

tjl, cfc



16071.40 /AT&T CT5013

Structure # 489S Mast  
LC #2 Reactions and Deflected Shape

Nov 22, 2016 at 8:44 AM


TIA.r3d






Loads: LC 3, 1.2D + 1.0Di + 1.0Wi

CEN TEK Engineering, INC.	Structure # 489S Mast LC #3 Loads	Nov 22, 2016 at 8:42 AM
tjl, cfc		TIA.r3d
16071.40 /AT&T CT5013		



Code Check	
Black	No Calc
Red	> 1.0
Magenta	.90-1.0
Green	.75-.90
Cyan	.50-.75
Blue	0-.50



CENTEK Engineering, INC.  
tjl, cfc  
16071.40 /AT&T CT5013

Structure # 489S Mast  
LC #3 Reactions and Deflected Shape

Nov 22, 2016 at 8:44 AM  
TIA.r3d

**Mast Connection to Tower:**

Reactions:

Moment = Moment := 0-kips (Input From Risa-3D)  
 Vertical = Vertical := 1.0-kips (Input From Risa-3D)  
 Horizontal x-dir = Horizontal := 5.5-kips (Input From Risa-3D)

Bolt Data:

Bolt Type = ASTMA36 (User Input)  
 Bolt Diameter = D := 0.75-in (User Input)  
 Number of Bolts =  $N_b := 4$  (2 U-Bolts) (User Input)  
 Bolt Ultimate Strength =  $F_u := 58$ -ksi (User Input)  
 Bolt Yield Strength =  $F_y := 36$ -ksi (User Input)  
 Resistance Factor =  $\phi := 0.75$  (User Input)

Nominal Bolt Area =  $A_b := \frac{1}{4} \cdot \pi \cdot D^2 = 0.442$ -in<sup>2</sup>  
 Design Tensile Strength =  $F_{nt} := \phi \cdot 0.75 \cdot F_u \cdot A_b = 14.4$ -kips  
 Design Shear Strength =  $F_{nv} := \phi \cdot 0.45 \cdot F_u \cdot A_b = 8.6$ -kips

Shear Force =  $f_v := \frac{\sqrt{\text{Horizontal}^2 + \text{Vertical}^2}}{N_b} = 1.4$ -kips  
 Bolt Shear % of Capacity =  $\frac{f_v}{F_{nv}} = 16.16$ %  
 Check Bolt Shear = Bolt\_Shear := if  $\left( \frac{f_v}{F_{nv}} \leq 1.00, \text{"OK"}, \text{"Overstressed"} \right)$   
 Bolt\_Shear = "OK"

Tension Force =  $f_t := \frac{\text{Horizontal}}{N_b} = 1.4$ -kips  
 Bolt Tension % of Capacity =  $\frac{f_t}{F_{nt}} = 9.54$ %  
 Check Bolt Tension = Bolt\_Tension := if  $\left( \frac{f_t}{F_{nt}} \leq 1.00, \text{"OK"}, \text{"Overstressed"} \right)$   
 Bolt\_Tension = "OK"

**Basic Components**

Heavy Wind Pressure =	p := 4.00	psf	(User Input NESC 2007 Figure 250-1 & Table 250-1)
Basic Windspeed =	V := 110	mph	(User Input NESC 2007 Figure 250-2(e) )
Radial Ice Thickness =	Ir := 0.50	in	(User Input)
Radial Ice Density =	Id := 56.0	pcf	(User Input)

**Factors for Extreme Wind Calculation**

Elevation of Top of Mast Above Grade =	TME := 106	ft	(User Input)
Multiplier Gust Response Factor =	m := 1.25		(User Input - Only for NESC Extreme wind case)
NESC Factor =	kv := 1.43		(User Input from NESC 2007 Table 250-3 equation)
Importance Factor =	I := 1.0		(User Input from NESC 2007 Section 250.C.2)

Velocity Pressure Coefficient = 
$$Kz := 2.01 \cdot \left( \frac{TME}{900} \right)^{\frac{2}{9.5}} = 1.281$$
 (NESC 2007 Table 250-2)

Exposure Factor = 
$$Es := 0.346 \left[ \frac{33}{(0.67 \cdot TME)} \right]^{\frac{1}{7}} = 0.31$$
 (NESC 2007 Table 250-3)

Response Term = 
$$Bs := \frac{1}{\left( 1 + 0.375 \cdot \frac{TME}{220} \right)} = 0.847$$
 (NESC 2007 Table 250-3)

Gust Response Factor = 
$$Grf := \frac{\left[ 1 + \left( 2.7 \cdot Es \cdot Bs \cdot \frac{1}{2} \right) \right]}{kv^2} = 0.866$$
 (NESC 2007 Table 250-3)

Wind Pressure = 
$$qz := 0.00256 \cdot Kz \cdot V^2 \cdot Grf \cdot I = 34.4$$
 psf (NESC 2007 Section 250.C.2)

**Shape Factors**

NUS Design Criteria Issued April 12, 2007

Shape Factor for Round Members =	Cd <sub>R</sub> := 1.3	(User Input)
Shape Factor for Flat Members =	Cd <sub>F</sub> := 1.6	(User Input)
Shape Factor for Coax Cables Attached to Outside of P de =	Cd <sub>coax</sub> := 1.45	(User Input)

**Overload Factors**

NU Design Criteria Table

**Overload Factors for Wind Loads:**

NESC Heavy Loading =	2.5	(User Input)	Apply in Risa-3D Analysis
NESC Extreme Loading =	1.0	(User Input)	Apply in Risa-3D Analysis

**Overload Factors for Vertical Loads:**

NESC Heavy Loading =	1.5	(User Input)	Apply in Risa-3D Analysis
NESC Extreme Loading =	1.0	(User Input)	Apply in Risa-3D Analysis

**Development of Wind & Ice Load on Mast**

**Mast Data:**

(Pipe 5" Sch. 80)

Mast Shape =	Round	(User Input)
Mast Diameter =	$D_{mast} := 5.56$ in	(User Input)
Mast Length =	$L_{mast} := 19$ ft	(User Input)
Mast Thickness =	$t_{mast} := 0.375$ in	(User Input)

**Wind Load (NESE Extreme)**

Mast Projected Surface Area =  $A_{mast} := \frac{D_{mast}}{12} = 0.463$  sf/ft

Total Mast Wind Force (Above NU Structure) =  $qz \cdot C_d R \cdot A_{mast} \cdot m = 26$  plf **BLC 5**

Total Mast Wind Force (Below NU Structure) =  $qz \cdot C_d R \cdot A_{mast} = 21$  plf **BLC 5**

**Wind Load (NESE Heavy)**

Mast Projected Surface Area w/ Ice =  $A_{ICE_{mast}} := \frac{(D_{mast} + 2 \cdot Ir)}{12} = 0.547$  sf/ft

Total Mast Wind Force w/ Ice =  $p \cdot C_d R \cdot A_{ICE_{mast}} = 3$  plf **BLC 4**

**Gravity Loads (without ice)**

Weight of the mast = Self Weight (Computed internally by Risa-3D) plf **BLC 1**

**Gravity Loads (ice only)**

Ice Area per Linear Foot =  $A_{i_{mast}} := \frac{\pi}{4} [(D_{mast} + Ir \cdot 2)^2 - D_{mast}^2] = 9.5$  sq in

Weight of Ice on Mast =  $W_{ICE_{mast}} := Id \cdot \frac{A_{i_{mast}}}{144} = 4$  plf **BLC 3**



Subject:

Load Analysis of AT&T Equipment on Structure #489S

Location:

Norwalk, CT

Rev. 0: 11/22/16

Prepared by: T.J.L Checked by: C.F.C.  
 Job No. 16071.40

**Development of Wind & Ice Load on Antennas**

**Antenna Data:**

Antenna Model =	CCI HPA-65F-BUU-H2	
Antenna Shape =	Flat	(User Input)
Antenna Height =	$L_{ant} := 21.4$	in (User Input)
Antenna Width =	$W_{ant} := 14.4$	in (User Input)
Antenna Thickness =	$T_{ant} := 7.3$	in (User Input)
Antenna Weight =	$WT_{ant} := 15$	lbs (User Input)
Number of Antennas =	$N_{ant} := 3$	(User Input)

**Wind Load (NESC Extreme)**

*Assumes Maximum Possible Wind Pressure Applied to all Antennas Simultaneously*

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot W_{ant}}{144} = 2.1$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 6.4$	sf

**Total Antenna Wind Force =**  $F_{ant} := qz \cdot C_d \cdot F \cdot A_{ant} = 441$  lbs **BLC 5**

**Wind Load (NESC Heavy)**

*Assumes Maximum Possible Wind Pressure Applied to all Antennas Simultaneously*

Surface Area for One Antenna w/ Ice =	$SA_{ICEant} := \frac{(L_{ant} + 1) \cdot (W_{ant} + 1)}{144} = 2.4$	sf
Antenna Projected Surface Area w/ Ice =	$A_{ICEant} := SA_{ICEant} \cdot N_{ant} = 7.2$	sf

**Total Antenna Wind Force w/ Ice =**  $F_{i_{ant}} := p \cdot C_d \cdot F \cdot A_{ICEant} = 46$  lbs **BLC 4**

**Gravity Load (without ice)**

**Weight of All Antennas =**  $WT_{ant} \cdot N_{ant} = 45$  lbs **BLC 2**

**Gravity Load (ice only)**

Volume of Each Antenna =	$V_{ant} := L_{ant} \cdot W_{ant} \cdot T_{ant} = 2250$	cu in
Volume of Ice on Each Antenna =	$V_{ice} := (L_{ant} + 1) \cdot (W_{ant} + 1) \cdot (T_{ant} + 1) - V_{ant} = 614$	cu in
Weight of Ice on Each Antenna =	$W_{ICEant} := \frac{V_{ice}}{1728} \cdot \rho_{ice} = 20$	lbs
<b>Weight of Ice on All Antennas =</b>	<b><math>W_{ICEant} \cdot N_{ant} = 60</math></b>	lbs <b>BLC 3</b>

**Development of Wind & Ice Load on TMA's**

**TMA Data:**

TMA Model =	Kaelus TMA2117F00V1-1
TMA Shape =	Flat (User Input)
TMA Height =	$L_{TMA} := 8.46$ in (User Input)
TMA Width =	$W_{TMA} := 11.81$ in (User Input)
TMA Thickness =	$T_{TMA} := 4.21$ in (User Input)
TMA Weight =	$W_{TMA} := 18$ lbs (User Input)
Number of TMA's =	$N_{TMA} := 6$ (User Input)

**Wind Load (NESC Extreme)**

Surface Area for One TMA =	$SA_{TMA} := \frac{L_{TMA} \cdot W_{TMA}}{144} = 0.7$	sf
TMA Projected Surface Area =	$A_{TMA} := SA_{TMA} \cdot N_{TMA} = 4.2$	sf
<b>Total TMA Wind Force =</b>	<b><math>F_{TMA} := qz \cdot C_d \cdot A_{TMA} \cdot m = 286</math></b>	lbs <b>BLC 5</b>

**Wind Load (NESC Heavy)**

Surface Area for One TMA w/ Ice =	$SA_{ICETMA} := \frac{(L_{TMA} + 1) \cdot (W_{TMA} + 1)}{144} = 0.8$	sf
TMA Projected Surface Area w/ Ice =	$A_{ICETMA} := SA_{ICETMA} \cdot N_{TMA} = 5$	sf
<b>Total TMA Wind Force w/ Ice =</b>	<b><math>F_{iTMA} := p \cdot C_d \cdot A_{ICETMA} = 32</math></b>	lbs <b>BLC 4</b>

**Gravity Load (without ice)**

<b>Weight of All TMA's =</b>	<b><math>W_{TMA} \cdot N_{TMA} = 108</math></b>	lbs <b>BLC 2</b>
------------------------------	---	------------------

**Gravity Load (ice only)**

Volume of Each TMA =	$V_{TMA} := L_{TMA} \cdot W_{TMA} \cdot T_{TMA} = 421$	cu in
Volume of Ice on Each TMA =	$V_{ice} := (L_{TMA} + 1)(W_{TMA} + 1)(T_{TMA} + 1) - V_{TMA} = 211$	cu in
Weight of Ice on Each TMA =	$W_{ICETMA} := \frac{V_{ice}}{1728} \cdot \rho_d = 7$	lbs
<b>Weight of Ice on All TMA's</b>	<b><math>W_{ICETMA} \cdot N_{TMA} = 41</math></b>	lbs <b>BLC 3</b>

**Development of Wind & Ice Load on Antenna Mounts**

**Mount Data:**

Mount Type =	Pipe Mounts	
Mount Shape =	Round	(User Input)
Pipe Mount Length =	$L_{mnt} := 60$	in (User Input)
2 inch Pipe Mount Linear Weight =	$W_{mnt} := 3.66$	plf (User Input)
Pipe Mount Outside Diameter =	$D_{mnt} := 2.375$	in (User Input)
Number of Mounting Pipes =	$N_{mnt} := 3$	(User Input)
Tri Sector Chain Mount Weight =	$W_{tsc.mnt} := 101$	lbs (User Input)

**Wind Load (NESC Extreme)**

**Assumes Mount is Shielded by Antenna**

Mount Projected Surface Area =  $A_{mnt} := 0.0$  sf

Total Mount Wind Force =  $F_{mnt} := qz \cdot C_d \cdot A_{mnt} \cdot m = 0$  lbs **BLC 5**

**Wind Load (NESC Heavy)**

**Assumes Mount is Shielded by Antenna**

Mount Projected Surface Area w/ Ice =  $A_{ICEmnt} := 0.0$  sf

Total Mount Wind Force =  $F_{mnt} := p \cdot C_d \cdot A_{ICEmnt} = 0$  lbs **BLC 4**

**Gravity Loads (without ice)**

Weight Each Pipe Mount =  $W_{Tmnt} := W_{mnt} \cdot \frac{L_{mnt}}{12} = 18$  lbs

Weight of All Mounts =  $W_{Tmnt} \cdot N_{mnt} + W_{tsc.mnt} = 156$  lbs **BLC 2**

**Gravity Load (ice only)**

Volume of Each Pipe =  $V_{mnt} := \frac{\pi}{4} \cdot D_{mnt}^2 \cdot L_{mnt} = 266$  cu in

Volume of Ice on Each Pipe =  $V_{ice} := \left[ \frac{\pi}{4} \cdot \left[ (D_{mnt} + 1)^2 \right] \cdot (L_{mnt} + 1) \right] - V_{mnt} = 280$  cu in

Weight of Ice each mount (incl. hardware) =  $W_{ICEmnt} := \frac{V_{ice}}{1728} \cdot \rho_d = 9$  lbs

Weight of Ice on All Mounts =  $W_{ICEmnt} \cdot N_{mnt} + 5 = 32$  lbs **BLC 3**

**Development of Wind & Ice Load on Coax Cables**

**Coax Cable Data:**

Coax Type =	HELIAX 1-5/8"	
Shape =	Round	(User Input)
Coax Outside Diameter =	$D_{\text{coax}} := 1.98$	in (User Input)
Coax Cable Length =	$L_{\text{coax}} := 8$	ft (User Input)
Weight of Coax per foot =	$Wt_{\text{coax}} := 1.04$	plf (User Input)
Total Number of Coax =	$N_{\text{coax}} := 12$	(User Input)
No. of Coax Projecting Outside Face of Mast =	$NP_{\text{coax}} := 2$	(User Input)

**Wind Load (NESC Extreme)**

Coax projected surface area =  $A_{\text{coax}} := \frac{(NP_{\text{coax}} D_{\text{coax}})}{12} = 0.3$  ft

Total Coax Wind Force (Above NU Structure) =  $F_{\text{coax}} := qz \cdot Cd_{\text{coax}} \cdot A_{\text{coax}} \cdot m = 21$  plf **BLC 5**

**Wind Load (NESC Heavy)**

Coax projected surface area w/ Ice =  $A_{\text{ICE}_{\text{coax}}} := \frac{(NP_{\text{coax}} D_{\text{coax}} + 2 \cdot lr)}{12} = 0.4$  ft

Total Coax Wind Force w/ Ice =  $F_{\text{ICE}_{\text{coax}}} := p \cdot Cd_{\text{coax}} \cdot A_{\text{ICE}_{\text{coax}}} = 2$  plf **BLC 4**

**Gravity Loads (without ice)**

Weight of all cables w/o ice  $WT_{\text{coax}} := Wt_{\text{coax}} \cdot N_{\text{coax}} = 12$  plf **BLC 2**

**Gravity Load (ice only)**

Ice Area per Linear Foot =  $A_{\text{ice}_{\text{coax}}} := \frac{\pi}{4} \left[ (D_{\text{coax}} + 2 \cdot lr)^2 - D_{\text{coax}}^2 \right] = 3.9$  sq in

Ice Weight All Coax per foot =  $WT_{\text{ice}_{\text{coax}}} := N_{\text{coax}} \cdot ld \cdot \frac{A_{\text{ice}_{\text{coax}}}}{144} = 18$  plf **BLC 3**

**CEN TEK engineering, INC.**  
**Consulting Engineers**  
63-2 North Branford Road  
Branford, CT 06405

Ph. 203-488-0580 / Fax. 203-488-8587

Subject: **Analysis of NESC Heavy Wind and NESC Extreme Wind  
for Obtaining Reactions Applied to Utility Pole  
Tabulated Load Cases**

Location: **Norwalk, CT**

Date: 11/22/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16071.40

Load Case

Description

- |   |                         |
|---|-------------------------|
| 1 | Self Weight (Mast)      |
| 2 | Weight of Appurtenances |
| 3 | Weight of Ice Only      |
| 4 | NESC Heavy Wind         |
| 5 | NESC Extreme Wind       |

Footnotes:

**CEN TEK engineering, INC.**  
**Consulting Engineers**  
 63-2 North Branford Road  
 Branford, CT 06405  
 Ph. 203-488-0580 / Fax. 203-488-8587

Subject: **Analysis of NESC Heavy Wind and NESC Extreme Wind  
 for Obtaining Reactions Applied to Utility Pole  
 Load Combinations Table**

Location: **Norwalk, CT**

Date: 11/22/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16071.40

Load Combination	Description	Envelope Soultion	Wind Factor	P-Delta	BLC Factor	BLC Factor	BLC Factor	BLC Factor	BLC Factor	BLC Factor	BLC Factor	
1	NESC Heavy Wind		1		1	1.5	2	1.5	3	1.5	4	2.5
2	NESC Extreme Wind		1		1	1	2	1	5	1		

Footnotes:  
 (1) BLC = Basic Load Case



**Global**

Display Sections for Member Calcs	5
Max Internal Sections for Member Calcs	97
Include Shear Deformation?	Yes
Include Warping?	Yes
Trans Load Btwn Intersecting Wood Wall?	Yes
Increase Nailing Capacity for Wind?	Yes
Area Load Mesh (in^2)	144
Merge Tolerance (in)	.12
P-Delta Analysis Tolerance	0.50%
Include P-Delta for Walls?	Yes
Automaticly Iterate Stiffness for Walls?	No
Maximum Iteration Number for Wall Stiffness	3
Gravity Acceleration (ft/sec^2)	32.2
Wall Mesh Size (in)	12
Eigensolution Convergence Tol. (1.E-)	4
Vertical Axis	Y
Global Member Orientation Plane	XZ
Static Solver	Sparse Accelerated
Dynamic Solver	Accelerated Solver

Hot Rolled Steel Code	AISC 9th: ASD
RISAConnection Code	AISC 14th(360-10): ASD
Cold Formed Steel Code	AISI 1999: ASD
Wood Code	AF&PA NDS-97: ASD
Wood Temperature	< 100F
Concrete Code	ACI 318-02
Masonry Code	ACI 530-05: ASD
Aluminum Code	AA ADM1-05: ASD - Building

Number of Shear Regions	4
Region Spacing Increment (in)	4
Biaxial Column Method	PCA Load Contour
Parme Beta Factor (PCA)	.65
Concrete Stress Block	Rectangular
Use Cracked Sections?	Yes
Use Cracked Sections Slab?	Yes
Bad Framing Warnings?	No
Unused Force Warnings?	Yes
Min 1 Bar Diam. Spacing?	No
Concrete Rebar Set	REBAR_SET_ASTMA615
Min % Steel for Column	1
Max % Steel for Column	8



**Global, Continued**

Seismic Code	UBC 1997
Seismic Base Elevation (ft)	Not Entered
Add Base Weight?	No
Ct Z	.035
Ct X	.035
T Z (sec)	Not Entered
T X (sec)	Not Entered
R Z	8.5
R X	8.5
Ca	.36
Cv	.54
Nv	1
Occupancy Category	4
Seismic Zone	3
Seismic Detailing Code	ASCE 7-05
Om Z	1
Om X	1
Rho Z	1
Rho X	1

Footing Overturning Safety Factor	1.5
Check Concrete Bearing	No
Footing Concrete Weight (k/ft^3)	0
Footing Concrete f'c (ksi)	3
Footing Concrete Ec (ksi)	4000
Lamda	1
Footing Steel fy (ksi)	60
Minimum Steel	0.0018
Maximum Steel	0.0075
Footing Top Bar	#3
Footing Top Bar Cover (in)	3.5
Footing Bottom Bar	#3
Footing Bottom Bar Cover (in)	3.5
Pedestal Bar	#3
Pedestal Bar Cover (in)	1.5
Pedestal Ties	#3

**Hot Rolled Steel Properties**

	Label	E [ksi]	G [ksi]	Nu	Therm (1...	Density[k/ft^3]	Yield[ksi]	Ry	Fu[ksi]	Rt
1	A36 Gr.36	29000	11154	.3	.65	.49	36	1.5	58	1.2
2	A572 Gr.50	29000	11154	.3	.65	.49	50	1.1	58	1.2
3	A992	29000	11154	.3	.65	.49	50	1.1	58	1.2
4	A500 Gr.42	29000	11154	.3	.65	.49	42	1.3	58	1.1
5	A500 Gr.46	29000	11154	.3	.65	.49	46	1.2	58	1.1
6	A53 Gr. B	29000	11154	.3	.65	.49	35	1.5	58	1.2



**Hot Rolled Steel Design Parameters**

Label	Shape	Leng...	Lbby[ft]	Lbzz[ft]	Lcomp ...	Lcomp ...	Kyy	Kzz	Com...Cm...	Cb	y s...	z s...	Functi...
1	M1	Mast	19										Lateral

**Hot Rolled Steel Section Sets**

Label	Shape	Type	Design List	Material	Design ...	A [in2]	Iyy [in4]	Izz [in4]	J [in4]	
1	Mast	PIPE 5.0X	Column	Pipe	A53 Gr. B	Typical	5.73	19.5	19.5	39

**Member Primary Data**

Label	I Joint	J Joint	K Joint	Rotate(d...	Section/Shape	Type	Design List	Material	Design R...
1	M1	BOTTO...	TOP-M...		Mast	Column	Pipe	A53 Gr. B	Typical

**Joint Coordinates and Temperatures**

Label	X [ft]	Y [ft]	Z [ft]	Temp [F]	Detach From ...
1	BOTTOM-MAST	0	0	0	
2	BOTTOM-BRACE	0	1	0	
3	TOP-BRACE	0	6	0	
4	TOP-MAST	0	19	0	

**Joint Boundary Conditions**

Joint Label	X [k/in]	Y [k/in]	Z [k/in]	X Rot.[k-ft/rad]	Y Rot.[k-ft/rad]	Z Rot.[k-ft/rad]	Footing
1	BOTTOM-BRACE	Reaction	Reaction	Reaction	Reaction	Reaction	
2	TOP-BRACE	Reaction	Reaction	Reaction	Reaction	Reaction	

**Member Point Loads (BLC 2 : Weight of Appurtenances)**

Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	Y	-045 16
2	M1	Y	-108 14
3	M1	Y	-156 16

**Member Point Loads (BLC 3 : Weight of Ice Only)**

Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	Y	-06 16
2	M1	Y	-041 14
3	M1	Y	-032 16

**Member Point Loads (BLC 4 : NESC Heavy Wind)**

Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	X	.046 16
2	M1	X	.032 14

**Member Point Loads (BLC 5 : NESC Extreme Wind)**

Member Label	Direction	Magnitude[k,k-ft]	Location[ft,%]
1	M1	X	.441 16
2	M1	X	.286 14



### Joint Loads and Enforced Displacements

Joint Label	L,D,M	Direction	Magnitude[(k,k-ft), (in,rad), (k*s^2/ft, k*s^2*ft)]
No Data to Print ...			

### Member Distributed Loads (BLC 2 : Weight of Appurtenances)

Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1 M1	Y	-0.012	-0.012	8	14

### Member Distributed Loads (BLC 3 : Weight of Ice Only)

Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1 M1	Y	-0.004	-0.004	0	0
2 M1	Y	-0.018	-0.018	8	14

### Member Distributed Loads (BLC 4 : NESC Heavy Wind)

Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1 M1	X	.003	.003	8	14
2 M1	X	.002	.002	8	14

### Member Distributed Loads (BLC 5 : NESC Extreme Wind)

Member Label	Direction	Start Magnitude[k/ft,F]	End Magnitude[k/ft,F]	Start Location[ft,%]	End Location[ft,%]
1 M1	X	.026	.026	8	14
2 M1	X	.021	.021	8	14

### Basic Load Cases

BLC Description	Category	X Gra...	Y Gravity	Z Gra...	Joint	Point	Distrib..	Area(...	Surfa...
1 Self Weight	None		-1						
2 Weight of Appurtenances	None					3	1		
3 Weight of Ice Only	None					3	2		
4 NESC Heavy Wind	None					2	2		
5 NESC Extreme Wind	None					2	2		

### Load Combinations

Description	Sol...	PDelta	SR...	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..	BLC Fact..
1 NESC Heavy Wind on PC...	Yes			1	1.5	2	1.5	3	1.5	4	2.5
2 NESC Extreme Wind on P...	Yes			1	1	2	1	5	1		
3 Self Weight				1	1						

### Envelope Joint Reactions

Joint	X [k]	LC	Y [k]	LC	Z [k]	LC	MX [k-ft]	LC	MY [k-ft]	LC	MZ [k-ft]	LC
1 BOTTOM-BR...max	1.622	2	.123	1	0	1	0	1	0	1	0	1
2 min	.433	1	.068	2	0	1	0	1	0	1	0	1
3 TOP-BRACE max	-.703	1	1.479	1	0	1	0	1	0	1	0	1
4 min	-2.631	2	.683	2	0	1	0	1	0	1	0	1
5 Totals: max	-.27	1	1.603	1	0	1						
6 min	-1.009	2	.751	2	0	1						



Company : Centek Engineering  
Designer : tjf, cfc  
Job Number : 16071.40 / AT&T CT5013  
Model Name : Structure # 489S Mast

Nov 22, 2016

Checked By: \_\_\_\_\_

### Joint Reactions

	LC	Joint Label	X [k]	Y [k]	Z [k]	MX [k-ft]	MY [k-ft]	MZ [k-ft]
1	1	BOTTOM-BRACE	.433	.123	0	0	0	0
2	1	TOP-BRACE	-.703	1.479	0	0	0	0
3	1	Totals:	-.27	1.603	0			
4	1	COG (ft):	X: 0	Y: 12.163	Z: 0			





Company : Centek Engineering  
Designer : tjf, cfc  
Job Number : 16071.40 / AT&T CT5013  
Model Name : Structure # 489S Mast

Nov 22, 2016

Checked By: \_\_\_\_\_

### Joint Reactions



	LC	Joint Label	X [k]	Y [k]	Z [k]	MX [k-ft]	MY [k-ft]	MZ [k-ft]
1	2	BOTTOM-BRACE	1.622	.068	0	0	0	0
2	2	TOP-BRACE	-2.631	.683	0	0	0	0
3	2	Totals:	-1.009	.751	0			
4	2	COG (ft):	X: 0	Y: 12.029	Z: 0			



Loads: LC 1, NESC Heavy Wind on PCS Structure



Centek Engineering	Structure # 489S Mast LC #1 Loads	Nov 22, 2016 at 1:48 PM
tjl, cfc		NESC.r3d
16071.40 / AT&T CT5013		







Results for LC 1, NESC Heavy Wind on PCS Structure  
Z-direction Reaction Units are k and k-ft

Centek Engineering	Structure # 489S Mast LC #1 Reactions	Nov 22, 2016 at 1:50 PM
tjl, cfc		NESC.r3d
16071.40 / AT&T CT5013		



Loads: LC 2, NESC Extreme Wind on PCS Structure

Centek Engineering	Structure # 489S Mast LC #2 Loads	Nov 22, 2016 at 1:48 PM
tjl, cfc		NESC.r3d
16071.40 / AT&T CT5013		



Results for LC 2, NESC Extreme Wind on PCS Structure  
Z-direction Reaction Units are k and k-ft

Centek Engineering	Structure # 489S Mast LC #2 Reactions	Nov 22, 2016 at 1:50 PM
tjl, cfc		NESC.r3d
16071.40 / AT&T CT5013		

Title Block Line 1  
 You can changes this area  
 using the "Settings" menu item  
 and then using the "Printing &  
 Title Block" selection.  
 Title Block Line 6

Title : CT5013 - Rowayton  
 Dsgnr:  
 Project Desc.: Section Properties - Wf14x87 Reinforced  
 Project Notes :

Printed: 5 JUL 2011, 2:42PM

## General Section Properties

ENERCALC, INC. 1983-2008, Ver: 6.0.19, N:33918


Lic. # : KW-06007028

License Owner : NATCOMM LLC






Description : WF14x87 Reinforced

### Final Section Properties

Total Area : 40.0 in<sup>2</sup>  
 Calculated final C.G. distance from Datum :  
 X cg Dist. : 0.0 in  
 Y cg Dist. : 0.0 in  
 Edge Distances from CG. :  
 +X : 8.980 in  
 -X : -8.980 in  
 +Y : 7.3680 in  
 -Y : -7.3680 in  
 Ixx = 1,584.29 in<sup>4</sup>  
 Iyy = 1,121.0 in<sup>4</sup>  
 Sxx : -X : 215.023 in<sup>3</sup>  
 Sxx : +X : 215.023 in<sup>3</sup>  
 Syy : -Y : 124.833 in<sup>3</sup>  
 Syy : +Y : 124.833 in<sup>3</sup>  
 r<sub>xx</sub> : 6.2934 in  
 r<sub>yy</sub> : 5.2939 in



### Steel Shapes

	WF14x87 : 1	Ixx = 966.900 in <sup>4</sup> Iyy = 349.700 in <sup>4</sup> Sxx = 138.129 in <sup>3</sup> Syy = 48.234 in <sup>3</sup>	Rotation = 0 dec CCW Xcg = 0.000 in Ycg = 0.000 in
	L6X4X3/8 : 2	Ixx = 4.860 in <sup>4</sup> Iyy = 13.400 in <sup>4</sup> Sxx = 14.362 in <sup>3</sup> Syy = 2.518 in <sup>3</sup>	Rotation = 270 dec CCW Xcg = -7.050 in Ycg = 6.435 in
	L6X4X3/8 : 3	Ixx = 4.860 in <sup>4</sup> Iyy = 13.400 in <sup>4</sup> Sxx = 14.362 in <sup>3</sup> Syy = 2.518 in <sup>3</sup>	Rotation = 90 dec CCW Xcg = 7.050 in Ycg = 6.435 in
	L6X4X3/8 : 4	Ixx = 4.860 in <sup>4</sup> Iyy = 13.400 in <sup>4</sup> Sxx = 14.362 in <sup>3</sup> Syy = 2.518 in <sup>3</sup>	Rotation = 270 dec CCW Xcg = -7.050 in Ycg = -6.435 in
	L6X4X3/8 : 5	Ixx = 4.860 in <sup>4</sup> Iyy = 13.400 in <sup>4</sup> Sxx = 14.362 in <sup>3</sup> Syy = 2.518 in <sup>3</sup>	Rotation = 90 dec CCW Xcg = 7.050 in Ycg = -6.435 in

**Basic Components**

Heavy Wind Pressure =	p := 4.00	psf	(User Input NESC 2007 Figure 250-1 & Table 250-1)
Basic Windspeed =	V := 110	mph	(User Input NESC 2007 Figure 250-2(e) )
Radial Ice Thickness =	Ir := 0.50	in	(User Input)
Radial Ice Density =	Id := 56.0	pcf	(User Input)

**Factors for Extreme Wind Calculation**

Elevation of Top of Pole Above Grade =	TME := 95	ft	(User Input)
Multiplier Gust Response Factor =	m := 1.25		(User Input - Only for NESC Extreme wind case)
NESC Factor =	kv := 1.43		(User Input from NESC 2007 Table 250-3 equation)
Importance Factor =	I := 1.0		(User Input from NESC 2007 Section 250.C.2)
Velocity Pressure Coefficient =	$Kz := 2.01 \cdot \left( \frac{0.67 TME}{900} \right)^{\frac{2}{9.5}}$	= 1.151	(NESC 2007 Table 250-2)
Exposure Factor =	$Es := 0.346 \left[ \frac{33}{(0.67 \cdot TME)} \right]^{\frac{1}{7}}$	= 0.315	(NESC 2007 Table 250-3)
Response Term =	$Bs := \frac{1}{\left( 1 + 0.375 \cdot \frac{TME}{220} \right)}$	= 0.861	(NESC 2007 Table 250-3)
Gust Response Factor =	$Grf := \frac{\left[ 1 + \left( 2.7 \cdot Es \cdot Bs \cdot \frac{1}{2} \right) \right]}{kv^2}$	= 0.875	(NESC 2007 Table 250-3)
Wind Pressure =	$qz := 0.00256 \cdot Kz \cdot V^2 \cdot Grf \cdot I$	= 31.2	psf (NESC 2007 Section 250.C.2)

**Shape Factors**

Shape Factor for Round Members =	Cd <sub>R</sub> := 1.3	(User Input)
Shape Factor for Flat Members =	Cd <sub>F</sub> := 1.6	(User Input)
Shape Factor for Coax Cables Attached to Outside of Pole =	Cd <sub>coax</sub> := 1.45	(User Input)

NUS Design Criteria Issued April 12, 2007

**Overload Factors**

NU Design Criteria Table

**Overload Factors for Wind Loads:**

NESC Heavy Loading =	2.5	(User Input)	Apply in Risa-3D Analysis
NESC Extreme Loading =	1.0	(User Input)	Apply in Risa-3D Analysis

**Overload Factors for Vertical Loads:**

NESC Heavy Loading =	1.5	(User Input)	Apply in Risa-3D Analysis
NESC Extreme Loading =	1.0	(User Input)	Apply in Risa-3D Analysis


**Development of Wind & Ice Load on CL&P Pole:**

(0' - 59' AGL)

**Existing Pole Data:**

W14x87 + (4) L 6x4x3/8

Pole Shape =	Flat	(User Input)
Pole Width Exposed to Wind =	$W_{pole} := 18.0$ in	(User Input)
Pole Section Length =	$L_{pole} := 59.0$ ft	(User Input)
<u>Wide Flange Beam Dimension:</u>		
Flange Width =	$bf := 14.5$ in	(User Input)
Beam Depth "d" =	$d := 14.0$ in	(User Input)
Flange Thickness =	$tf := 0.688$ in	(User Input)
Web Thickness =	$tw := 0.420$ in	(User Input)
<u>Angle Dimensions:</u>		
Length of 1 Leg =	$L1 := 6$ in	(User Input)
Length of Other Leg =	$L2 := 4$ in	(User Input)
Angle Thickness =	$Ta := 0.375$ in	(User Input)
Number of Angles =	$Na := 4$ in	(User Input)



**Wind Load (NESC Extreme)**

Pole Projected Surface Area =  $A_{pole} := \frac{W_{pole}}{12} = 1.5$  sf/ft

Total Pole Wind Force =  $qz \cdot Cd_F \cdot A_{pole} = 75$  plf **BLC 5**

**Wind Load (NESE Heavy)**

Pole Projected Surface Area w/ Ice =  $A_{ICE_{pole}} := \frac{(W_{pole} + 2 \cdot Ir)}{12} = 1.583$  sf/ft

Total Pole Wind Force w/ Ice =  $p \cdot Cd_F \cdot A_{ICE_{pole}} = 10$  plf **BLC 4**

**Gravity Loads (without ice)**

Weight of the built-up pole = **Self Weight** (Computed internally by Risa-3D) plf **BLC 1**

**Gravity Loads (ice only)**

Cross Sectional Area of WF =	$As := 2 \cdot bf \cdot tf + (d - 2 \cdot tf) \cdot tw = 25.254$	sq in
Area of 1 Angle =	$Aa := L1 \cdot Ta + (L2 - Ta) \cdot Ta = 3.609$	sq in
Cross Sectional Area of WF + Ice =	$Asi := 2 \cdot [(bf + 2 \cdot Ir) \cdot (tf + 2 \cdot Ir)] + [d - 2 \cdot (tf + Ir)] \cdot (tw + 2 \cdot Ir) = 68.834$	sq in
Area of 1 Angle + Ice =	$Aai := (L1 + 2 \cdot Ir) \cdot (Ta + 2 \cdot Ir) + (L2 - Ta - Ir) \cdot (Ta + 2 \cdot Ir) = 13.922$	sq in
Ice Area per Linear Foot =	$Ai_{ICE_{pole}} := Asi - As + 4 \cdot (Aai - Aa) = 84.8$	sq in


Weight of Ice on Pole =  $W_{ICE_{pole}} := Id \cdot \frac{Ai_{ICE_{pole}}}{144} = 33$  plf **BLC 3**

**Development of Wind & Ice Load on CL&P Pole:**

(59' - 95' AGL)

**Existing Pole Data:**

	W14x87		
Pole Shape =	Flat		(User Input)
Pole Width Exposed to Wind =	$W_{pole} := 14.5$	in	(User Input)
Pole Section Length =	$L_{pole} := 36.0$	ft	(User Input)
Flange Width =	$bf := 14.5$	in	(User Input)
Beam Depth "d" =	$d := 14.0$	in	(User Input)
Flange Thickness =	$tf := 0.688$	in	(User Input)
Web Thickness =	$tw := 0.420$	in	(User Input)



**Wind Load (NESE Extreme)**

Pole Projected Surface Area (per LF) =  $A_{pole} := \frac{W_{pole}}{12} = 1.208$  sfft

Total Pole Wind Force =  $qz \cdot C_dF \cdot A_{pole} = 60$  plf **BLC 5**

**Wind Load (NESE Heavy)**

Pole Projected Surface Area w/ Ice =  $A_{ICEpole} := \frac{(W_{pole} + 2 \cdot lr)}{12} = 1.292$  sfft

Total Pole Wind Force w/ Ice =  $p \cdot C_dF \cdot A_{ICEpole} = 8$  plf **BLC 4**

**Gravity Loads (without ice)**

Weight of the built-up pole = Self Weight (Computed internally by Risa-3D) plf **BLC 1**

**Gravity Loads (ice only)**

Cross Sectional Area of Steel =  $A_s := 2 \cdot bf \cdot tf + (d - 2 \cdot tf) \cdot tw = 25.254$  sq in

Cross Sectional Area of Steel + Ice =  $A_{si} := 2 \cdot [(bf + 2 \cdot lr) \cdot (tf + 2 \cdot lr)] + [d - 2 \cdot (tf + lr)] \cdot (tw + 2 \cdot lr) = 68.834$

Ice Area per Linear Foot =  $A_{iICEpole} := A_{si} - A_s = 43.6$  sq in


Weight of Ice on Pole =  $W_{ICEpole} := Id \cdot \frac{A_{iICEpole}}{144} = 17$  plf **BLC 3**



**Development of Wind & Ice Load on Coax Cables**

**Coax Cable Data:**

Coax Type =	HELIAX 1-5/8"	
Shape =	Round	(User Input)
Coax Outside Diameter =	$D_{coax} := 1.98$ in	(User Input)
Coax Cable Length =	$L_{coax} := 95$ ft	(User Input)
Weight of Coax per foot =	$Wt_{coax} := 1.04$ plf	(User Input)
Total Number of Coax =	$N_{coax} := 12$	(User Input)
No. of Coax Projecting Outside Face of Pole =	$NP_{coax} := 2$	(User Input)



**Wind Load (NESC Extreme)**

Coax projected surface area =

$$A_{coax} := \frac{(NP_{coax} \cdot D_{coax})}{12} = 0.3 \quad \text{sf/ft}$$

Total Coax Wind Force (Below NU Structure) =

$$F_{coax} := qz \cdot Cd_{coax} \cdot A_{coax} = 15 \quad \text{plf} \quad \text{BLC 5}$$

**Wind Load (NESC Heavy)**

Coax projected surface area w/ Ice =

$$A_{ICE_{coax}} := \frac{(NP_{coax} \cdot D_{coax} + 2 \cdot Ir)}{12} = 0.4 \quad \text{sf/ft}$$

Total Coax Wind Force w/ Ice =

$$F_{i_{coax}} := p \cdot Cd_{coax} \cdot A_{ICE_{coax}} = 2 \quad \text{plf} \quad \text{BLC 4}$$

**Gravity Loads (without ice)**

Weight of all cables w/o ice

$$WT_{coax} := Wt_{coax} \cdot N_{coax} = 12 \quad \text{plf} \quad \text{BLC 2}$$



**Gravity Load (ice only)**

Ice Area per Linear Foot =

$$A_{i_{coax}} := \frac{\pi}{4} \left[ (D_{coax} + 2 \cdot Ir)^2 - D_{coax}^2 \right] = 3.9 \quad \text{sq in}$$

Ice Weight All Coax per foot =

$$WT_{i_{coax}} := N_{coax} \cdot Id \cdot \frac{A_{i_{coax}}}{144} = 18 \quad \text{plf} \quad \text{BLC 3}$$



Loads: LC 1, NESC Heavy Wind on CL&P Pole

CENTEK Engineering, INC.		
tjl, cfc	Pole # 489S	Nov 22, 2016 at 1:59 PM
16071.40 /AT&T CT5013	LC #1 Loads	Pole Analysis Using NESC Loading.r...

Beam: **M1**

Shape: **W14x87 Reinforced**

Material: **A36 Gr.36**

Length: **59 ft**










I Joint: **N1**

J Joint: **N2**

**LC 1: NESG Heavy Wind on CL&P Pole**

Code Check: **0.236 (bending)**

Report Based On 97 Sections



**AISC 9th: ASD Code Check**

Max Bending Check **0.236**  
 Location **59 ft**  
 Equation **H1-3**

Max Shear Check **0.029 (y)**  
 Location **0 ft**  
 Max Defl Ratio **L/868**

**Compact**

Fy **36 ksi**  
 Fa **7.758 ksi**  
 Ft **21.6 ksi**  
 Fby **27 ksi**  
 Fbz **21.6 ksi**  
 Fvy **14.4 ksi**  
 Fvz **14.4 ksi**  
 Cb **2.217**

	y-y	z-z
Cm	<b>.6</b>	<b>.85</b>
Lb	<b>59 ft</b>	<b>59 ft</b>
KL/r	<b>138.739</b>	<b>109.879</b>
Sway	<b>No</b>	<b>No</b>
L Comp Flange	<b>59 ft</b>	
Warp Length	<b>95 ft</b>	

Beam: **M2**

Shape: **W14x87**

Material: **A36 Gr.36**

Length: **36 ft**









I Joint: **N2**

J Joint: **N6**

**LC 1: NESG Heavy Wind on CL&P Pole**

Code Check: **0.356 (bending)**

Report Based On 97 Sections



**AISC 9th: ASD Code Check**



Max Bending Check **0.356**  
 Location **7.875 ft**  
 Equation **H1-1**

Max Shear Check **0.020 (y)**  
 Location **18.75 ft**  
 Max Defl Ratio **L/99**

**Compact**

Fy **36 ksi**  
 Fa **10.859 ksi**  
 Ft **21.6 ksi**  
 Fby **27 ksi**  
 Fbz **20.053 ksi**  
 Fvy **14.4 ksi**  
 Fvz **14.4 ksi**  
 Cb **1**

y-y      z-z  
 Cm **.6**      **.85**  
 Lb **36 ft**      **36 ft**  
 KL/r **115.926**      **70.228**  
 Sway **No**      **No**  
 L Comp Flange **36 ft**  
 Warp Length **95 ft**



Loads: LC 2, NESC Extreme Wind on CL&P Pole

CENTEK Engineering, INC.		
tjl, cfc	Pole # 489S	Nov 22, 2016 at 1:59 PM
16071.40 /AT&T CT5013	LC #2 Loads	Pole Analysis Using NESC Loading.r...

Beam: **M1**

Shape: **W14x87 Reinforced**

Material: **A36 Gr.36**

Length: **59 ft**










I Joint: **N1**

J Joint: **N2**

**LC 2: NESC Extreme Wind on CL&P Pole**

Code Check: **1.352 (bending)**

Report Based On 97 Sections



**AISC 9th: ASD Code Check**

Max Bending Check **1.352**  
 Location **0 ft**  
 Equation **H1-3**

Max Shear Check **0.116 (y)**  
 Location **0 ft**  
 Max Defl Ratio **L/34**

**Compact**









Fy **36 ksi**  
 Fa **7.758 ksi**  
 Ft **21.6 ksi**  
 Fby **27 ksi**  
 Fbz **19.56 ksi**  
 Fvy **14.4 ksi**  
 Fvz **14.4 ksi**  
 Cb **1.599**

	y-y	z-z
Cm	<b>.6</b>	<b>.85</b>
Lb	<b>59 ft</b>	<b>59 ft</b>
KL/r	<b>138.739</b>	<b>109.879</b>
Sway	<b>No</b>	<b>No</b>
L Comp Flange	<b>59 ft</b>	
Warp Length	<b>95 ft</b>	

Beam: **M2**  
 Shape: **W14x87**  
 Material: **A36 Gr.36**  
 Length: **36 ft**  
 I Joint: **N2**  
 J Joint: **N6**

**LC 2: NESC Extreme Wind on CL&P Pole**

Code Check: **0.320 (bending)**  
 Report Based On 97 Sections





**AISC 9th: ASD Code Check**

Max Bending Check	<b>0.320</b>	Max Shear Check	<b>0.053 (y)</b>
Location	<b>0 ft</b>	Location	<b>0 ft</b>
Equation	<b>H1-2</b>	Max Defl Ratio	<b>L/20</b>

**Compact**

Fy	<b>36 ksi</b>	y-y	<b>.6</b>	z-z	<b>.85</b>
Fa	<b>10.859 ksi</b>	Cm	<b>.6</b>	Lb	<b>36 ft</b>
Ft	<b>21.6 ksi</b>	Lb	<b>36 ft</b>	KL/r	<b>115.926</b>
Fby	<b>27 ksi</b>	KL/r	<b>115.926</b>	Sway	<b>No</b>
Fbz	<b>21.6 ksi</b>	Sway	<b>No</b>	L Comp Flange	<b>36 ft</b>
Fvy	<b>14.4 ksi</b>	L Comp Flange	<b>36 ft</b>	Warp Length	<b>95 ft</b>
Fvz	<b>14.4 ksi</b>	Warp Length	<b>95 ft</b>		
Cb	<b>1.758</b>				





Loads: LC 3, NESC Heavy Wind on CL&P Pole

CENTEK Engineering, INC.

tjl, cfc

16071.40 /AT&T CT5013

Pole # 489S

LC #3 Loads

Nov 22, 2016 at 1:59 PM

Pole Analysis Using NESC Loading.r...

Beam: **M1**

Shape: **W14x87 Reinforced**

Material: **A36 Gr.36**

Length: **59 ft**











I Joint: **N1**

J Joint: **N2**

**LC 3: NESC Heavy Wind on CL&P Pole**

Code Check: **0.659 (bending)**

Report Based On 97 Sections



**AISC 9th: ASD Code Check**

Max Bending Check **0.659**  
 Location **56.542 ft**  
 Equation **H1-1**

Max Shear Check **0.024 (y)**  
 Location **59 ft**  
 Max Defl Ratio **L/137**









**Compact**

Fy **36 ksi**  
 Fa **7.758 ksi**  
 Ft **21.6 ksi**  
 Fby **27 ksi**  
 Fbz **12.235 ksi**  
 Fvy **14.4 ksi**  
 Fvz **14.4 ksi**  
 Cb **1**

	y-y	z-z
Cm	<b>.6</b>	<b>.85</b>
Lb	<b>59 ft</b>	<b>59 ft</b>
KL/r	<b>138.739</b>	<b>109.879</b>
Sway	<b>No</b>	<b>No</b>
L Comp Flange	<b>59 ft</b>	
Warp Length	<b>95 ft</b>	

Beam: **M2**  
 Shape: **W14x87**  
 Material: **A36 Gr.36**  
 Length: **36 ft**  
 I Joint: **N2**  
 J Joint: **N6**

**LC 3: NESC Heavy Wind on CL&P Pole**  
 Code Check: **0.754 (bending)**  
 Report Based On 97 Sections





**AISC 9th: ASD Code Check**

Max Bending Check	<b>0.754</b>	Max Shear Check	<b>0.075 (y)</b>
Location	<b>7.875 ft</b>	Location	<b>10.5 ft</b>
Equation	<b>H1-1</b>	Max Defl Ratio	<b>L/37</b>

**Compact**

Fy	<b>36 ksi</b>	y-y	<b>.6</b>	z-z	<b>.85</b>
Fa	<b>10.859 ksi</b>	Cm	<b>.6</b>	Lb	<b>36 ft</b>
Ft	<b>21.6 ksi</b>	Lb	<b>36 ft</b>	KL/r	<b>115.926</b>
Fby	<b>27 ksi</b>	KL/r	<b>115.926</b>	Sway	<b>No</b>
Fbz	<b>20.053 ksi</b>	Sway	<b>No</b>	L Comp Flange	<b>36 ft</b>
Fvy	<b>14.4 ksi</b>	L Comp Flange	<b>36 ft</b>	Warp Length	<b>95 ft</b>
Fvz	<b>14.4 ksi</b>	Warp Length	<b>95 ft</b>		
Cb	<b>1</b>				



Loads: LC 4, NESC Extreme Wind on CL&P Pole

CENTEK Engineering, INC.		
tjl, cfc	Pole # 489S	Nov 22, 2016 at 1:59 PM
16071.40 /AT&T CT5013	LC #4 Loads	Pole Analysis Using NESC Loading.r...

Beam: **M1**

Shape: **W14x87 Reinforced**

Material: **A36 Gr.36**

Length: **59 ft**











I Joint: **N1**

J Joint: **N2**

**LC 4: NESC Extreme Wind on CL&SP Pole**

Code Check: **0.688 (bending)**

Report Based On 97 Sections



**AISC 9th: ASD Code Check**

Max Bending Check **0.688**  
 Location **0 ft**  
 Equation **H1-1**

Max Shear Check **0.033 (y)**  
 Location **0 ft**  
 Max Defl Ratio **L/108**










**Compact**

Fy **36 ksi**  
 Fa **7.758 ksi**  
 Ft **21.6 ksi**  
 Fby **27 ksi**  
 Fbz **12.235 ksi**  
 Fvy **14.4 ksi**  
 Fvz **14.4 ksi**  
 Cb **1**

y-y      z-z  
 Cm **.6**      **.85**  
 Lb **59 ft**      **59 ft**  
 KL/r **138.739**      **109.879**  
 Sway **No**      **No**  
 L Comp Flange **59 ft**  
 Warp Length **95 ft**

Beam: **M2**  
 Shape: **W14x87**  
 Material: **A36 Gr.36**  
 Length: **36 ft**  
 I Joint: **N2**  
 J Joint: **N6**

**LC 4: NESC Extreme Wind on CL&SP Pole**  
 Code Check: **0.729 (bending)**  
 Report Based On 97 Sections




**AISC 9th: ASD Code Check**

Max Bending Check	<b>0.729</b>	Max Shear Check	<b>0.087 (y)</b>
Location	<b>10.125 ft</b>	Location	<b>10.5 ft</b>
Equation	<b>H1-1</b>	Max Defl Ratio	<b>L/35</b>

**Compact**

Fy	<b>36 ksi</b>	y-y	<b>.6</b>	z-z	<b>.85</b>
Fa	<b>10.859 ksi</b>	Cm	<b>.6</b>	Lb	<b>36 ft</b>
Ft	<b>21.6 ksi</b>	Lb	<b>36 ft</b>	KL/r	<b>115.926</b>
Fby	<b>27 ksi</b>	Sway	<b>No</b>		<b>70.228</b>
Fbz	<b>20.053 ksi</b>				<b>No</b>
Fvy	<b>14.4 ksi</b>	L Comp Flange	<b>36 ft</b>		
Fvz	<b>14.4 ksi</b>	Warp Length	<b>95 ft</b>		
Cb	<b>1</b>				

**CL&P Pole Analysis:**



**General Pole Properties:**

Length of Pole =	$L_{pole} := 95\text{-ft}$	(User Input)
Yield Stress =	$F_y := 36\text{-ksi}$	(User Input)
Modulus of Elasticity =	$E := 29000\text{-ksi}$	(User Input)
Bending Stress Coefficient =	$C_b := 1.75$	(User Input)
Bending Term Coefficient =	$C_m := 0.85$	(User Input)
Column Slenderness Ratio =	$C_c := \pi \cdot \sqrt{\frac{2 \cdot E}{F_y}} = 126.1$	(EQ. 3.6.3)

**Section Properties Top Section**

Moment of Inertia x-axis =	$I_{x,top} := 966.9 \cdot \text{in}^4$	(User Input from Enercalc)
Moment of Inertia y-axis =	$I_{y,top} := 349.7 \cdot \text{in}^4$	(User Input from Enercalc)
Section Modulus x-axis =	$S_{x,top} := 138.1 \cdot \text{in}^3$	(User Input from Enercalc)
Area =	$A_{top} := 25.6 \cdot \text{in}^2$	(User Input from Enercalc)
Radius of Gyration x-axis =	$r_{x,top} := 6.15 \cdot \text{in}$	(User Input from Enercalc)
Radius of Gyration y-axis =	$r_{y,top} := 3.7 \cdot \text{in}$	(User Input from Enercalc)
Warping Constant =	$C_{w,top} := 15492 \cdot \text{in}^6$	(User Input from Enercalc)
Torsional Constant =	$J_{w,top} := 3.55 \cdot \text{in}^4$	(User Input from Enercalc)
Unbraced Length =	$KL_{top} := 432 \cdot \text{in}$	(User Input)
	$KL_x := \frac{KL_{top}}{r_{x,top}} = 70.244$	
	$KL_y := \frac{KL_{top}}{r_{y,top}} = 116.757$	
	$KL_r := \begin{cases} KL_x & \text{if } KL_x > KL_y \\ KL_y & \text{otherwise} \end{cases} = 116.757$	
Design Compressive Stress =	$F_{a,top} := \begin{cases} \left[ 1 - \frac{1}{2} \left( \frac{KL_r}{C_c} \right)^2 \right] \cdot F_y & \text{if } KL_r \leq C_c \\ \frac{\pi^2 \cdot E}{(KL_r)^2} & \text{otherwise} \end{cases} = 20.6 \cdot \text{ksi}$	(EQ 3.6-1)
		(EQ 3.6-2)
	$r := \sqrt{\frac{C_b \cdot \sqrt{I_{y,top}}}{S_{x,top}} \cdot \sqrt{C_{w,top} + 0.04 \cdot J_{w,top} \cdot (KL_{top})^2}} = 7 \cdot \text{in}$	(EQ 3.14-1)
	$KL_{rb} := \frac{KL_{top}}{r} = 62$	
Design Bending Stress =	$F_{b,top} := \begin{cases} \left[ 1 - \frac{1}{2} \left( \frac{KL_{rb}}{C_c} \right)^2 \right] \cdot F_y & \text{if } KL_{rb} \leq C_c \\ \frac{\pi^2 \cdot E}{(KL_{rb})^2} & \text{otherwise} \end{cases} = 31.6 \cdot \text{ksi}$	(EQ 3.6-1)
		(EQ 3.6-2)
Design Axial Compression =	$P_{a,top} := F_{a,top} \cdot A_{top} = 526.6 \cdot \text{kip}$	
Allowable Moment =	$M_{a,top} := F_{b,top} \cdot S_{x,top} = 364 \cdot \text{kip} \cdot \text{ft}$	
Euler Buckling Load =	$P_{e,top} := \frac{(\pi^2 \cdot E \cdot I_{x,top})}{(KL_{top})^2} = 1483 \cdot \text{kip}$	



**Section Properties Bottom Section**

Moment of Inertia x-axis =	$I_{xbot} := 1584.3 \cdot \text{in}^4$	(User Input from Enercalc)
Moment of Inertia y-axis =	$I_{ybot} := 1121.0 \cdot \text{in}^4$	(User Input from Enercalc)
Section Modulus x-axis =	$S_{xbot} := 215 \cdot \text{in}^3$	(User Input from Enercalc)
Area =	$A_{bot} := 40 \cdot \text{in}^2$	(User Input from Enercalc)
Radius of Gyration x-axis =	$r_{xbot} := 6.29 \cdot \text{in}$	(User Input from Enercalc)
Radius of Gyration y-axis =	$r_{ybot} := 5.29 \cdot \text{in}$	(User Input from Enercalc)
Warping Constant =	$C_{wbot} := 15493 \cdot \text{in}^6$	(User Input from Enercalc)
Torsional Constant =	$J_{wbot} := 4.26 \cdot \text{in}^4$	(User Input from Enercalc)
Unbraced Length =	$KL_{bot} := 708 \cdot \text{in}$	(User Input)

$$KL_x := \frac{KL_{bot}}{r_{xbot}} = 112.56$$

$$KL_y := \frac{KL_{bot}}{r_{ybot}} = 133.837$$

$$KL_r := \begin{cases} KL_x & \text{if } KL_x > KL_y \\ KL_y & \text{otherwise} \end{cases} = 133.837$$

Design Compressive Stress =	$Fa_{bot} := \begin{cases} \left[ 1 - \frac{1}{2} \left( \frac{KL_r}{C_c} \right)^2 \right] \cdot F_y & \text{if } KL_r \leq C_c \\ \frac{\pi^2 \cdot E}{(KL_r)^2} & \text{otherwise} \end{cases} = 16 \cdot \text{ksi}$	(EQ 3.6-1)
		(EQ 3.6-2)

$$r := \sqrt{\frac{C_b \cdot \sqrt{I_{ybot}}}{S_{xbot}} \cdot \sqrt{C_{wbot} + 0.04 \cdot J_{wbot} \cdot (KL_{bot})^2}} = 9.3 \cdot \text{in} \quad \text{(EQ 3.14-1)}$$

$$KL_{rb} := \frac{KL_{bot}}{r} = 76.1$$

Design Bending Stress =	$Fb_{bot} := \begin{cases} \left[ 1 - \frac{1}{2} \left( \frac{KL_{rb}}{C_c} \right)^2 \right] \cdot F_y & \text{if } KL_{rb} \leq C_c \\ \frac{\pi^2 \cdot E}{(KL_{rb})^2} & \text{otherwise} \end{cases} = 29.4 \cdot \text{ksi}$	(EQ 3.6-1)
		(EQ 3.6-2)


Design Axial Compression =  $Pa_{bot} := Fa_{bot} \cdot A_{bot} = 639.1 \cdot \text{kip}$

Allowable Moment =  $Ma_{bot} := Fb_{bot} \cdot S_{xbot} = 528 \cdot \text{kip} \cdot \text{ft}$

Euler Buckling Load =  $Pe_{bot} := \frac{(\pi^2 \cdot E \cdot I_{xbot})}{(KL_{bot})^2} = 905 \cdot \text{kip}$

**Load Combination # 1:**

*NESC Heavy Wind - Towards of Guy Wires*



Max Bending Moment Unreinforced Pole =  $M_{x_{top}} := 72.2\text{-kip-ft}$  (From Risa-3D)

Max Axial Force Unreinforced Pole =  $P_{top} := 24.2\text{ kip}$  (From Risa-3D)

Max Bending Moment Reinforced Pole =  $M_{x_{bot}} := 67.4\text{-kip-ft}$  (From Risa-3D)

Max Axial Force Reinforced Pole =  $P_{bot} := 41.8\text{ kip}$  (From Risa-3D)

Combined Axial and Bending Stress Unreinforced Pole:

$$\text{Stress} := \frac{P_{top}}{P_{e_{top}}} + \frac{C_m \cdot M_{x_{top}}}{M_{a_{top}}} \cdot \left[ \frac{1}{1 - \frac{P_{top}}{P_{e_{top}}}} \right] = 18.8\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

$$\text{Stress} := \frac{P_{top}}{P_{e_{top}}} + \frac{M_{x_{top}}}{M_{a_{top}}} = 21.5\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

Combined Axial and Bending Stress Reinforced Pole:

$$\text{Stress} := \frac{P_{bot}}{P_{e_{bot}}} + \frac{C_m \cdot M_{x_{bot}}}{M_{a_{bot}}} \cdot \left[ \frac{1}{1 - \frac{P_{bot}}{P_{e_{bot}}}} \right] = 16\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"


$$\text{Stress} := \frac{P_{bot}}{P_{e_{bot}}} + \frac{M_{x_{bot}}}{M_{a_{bot}}} = 17.4\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

**Load Combination # 2:**

*NESC Extreme Wind - Towards of Guy Wires*



Max Bending Moment Unreinforced Pole =  $M_{x\text{top}} := 75.1 \cdot \text{kip-ft}$  (From Risa-3D)

Max Axial Force Unreinforced Pole =  $P_{\text{top}} := 9.5 \cdot \text{kip}$  (From Risa-3D)

Max Bending Moment Reinforced Pole =  $M_{x\text{bot}} := 498.6 \cdot \text{kip-ft}$  (From Risa-3D)

Max Axial Force Reinforced Pole =  $P_{\text{bot}} := 18.2 \cdot \text{kip}$  (From Risa-3D)

Combined Axial and Bending Stress Unreinforced Pole:

$$\text{Stress} := \frac{P_{\text{top}}}{P_{e_{\text{top}}}} + \frac{C_m \cdot M_{x\text{top}}}{M_{a_{\text{top}}}} \cdot \left[ \frac{1}{\left( 1 - \frac{P_{\text{top}}}{P_{e_{\text{top}}}} \right)} \right] = 18.3\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

$$\text{Stress} := \frac{P_{\text{top}}}{P_{e_{\text{top}}}} + \frac{M_{x\text{top}}}{M_{a_{\text{top}}}} = 21.3\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

Combined Axial and Bending Stress Reinforced Pole:

$$\text{Stress} := \frac{P_{\text{bot}}}{P_{e_{\text{bot}}}} + \frac{C_m \cdot M_{x\text{bot}}}{M_{a_{\text{bot}}}} \cdot \left[ \frac{1}{\left( 1 - \frac{P_{\text{bot}}}{P_{e_{\text{bot}}}} \right)} \right] = 84\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"


$$\text{Stress} := \frac{P_{\text{bot}}}{P_{e_{\text{bot}}}} + \frac{M_{x\text{bot}}}{M_{a_{\text{bot}}}} = 96.5\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

**Load Combination # 3:**

*NESC Heavy Wind - Away from Guy Wires*



Max Bending Moment Unreinforced Pole =  $M_{x_{top}} := 152.1 \text{ kip-ft}$  (From Risa-3D)

Max Axial Force Unreinforced Pole =  $P_{top} := 45.7 \text{ kip}$  (From Risa-3D)

Max Bending Moment Reinforced Pole =  $M_{x_{bot}} := 135.5 \text{ kip-ft}$  (From Risa-3D)

Max Axial Force Reinforced Pole =  $P_{bot} := 63.3 \text{ kip}$  (From Risa-3D)

Combined Axial and Bending Stress Unreinforced Pole:

$$\text{Stress} := \frac{P_{top}}{P_{e_{top}}} + \frac{C_m \cdot M_{x_{top}}}{M_{a_{top}}} \left[ \frac{1}{1 - \frac{P_{top}}{P_{e_{top}}}} \right] = 39.7\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

$$\text{Stress} := \frac{P_{top}}{P_{e_{top}}} + \frac{M_{x_{top}}}{M_{a_{top}}} = 44.8\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

Combined Axial and Bending Stress Reinforced Pole:

$$\text{Stress} := \frac{P_{bot}}{P_{e_{bot}}} + \frac{C_m \cdot M_{x_{bot}}}{M_{a_{bot}}} \left[ \frac{1}{1 - \frac{P_{bot}}{P_{e_{bot}}}} \right] = 30.5\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"


$$\text{Stress} := \frac{P_{bot}}{P_{e_{bot}}} + \frac{M_{x_{bot}}}{M_{a_{bot}}} = 32.7\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

**Load Combination # 4:**

*NESC Extreme Wind - Away from Guy Wires*



Max Bending Moment Unreinforced Pole =  $M_{x\text{top}} := 150.3\text{-kip-ft}$  (From Risa-3D)

Max Axial Force Unreinforced Pole =  $P_{\text{top}} := 42.3\text{-kip}$  (From Risa-3D)

Max Bending Moment Reinforced Pole =  $M_{x\text{bot}} := 133.0\text{-kip-ft}$  (From Risa-3D)

Max Axial Force Reinforced Pole =  $P_{\text{bot}} := 51.1\text{-kip}$  (From Risa-3D)

Combined Axial and Bending Stress Unreinforced Pole:

$$\text{Stress} := \frac{P_{\text{top}}}{P_{e_{\text{top}}}} + \frac{C_m \cdot M_{x\text{top}}}{M_{a_{\text{top}}}} \left[ \frac{1}{1 - \frac{P_{\text{top}}}{P_{e_{\text{top}}}}} \right] = 39.0\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

$$\text{Stress} := \frac{P_{\text{top}}}{P_{e_{\text{top}}}} + \frac{M_{x\text{top}}}{M_{a_{\text{top}}}} = 44.1\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

Combined Axial and Bending Stress Reinforced Pole:

$$\text{Stress} := \frac{P_{\text{bot}}}{P_{e_{\text{bot}}}} + \frac{C_m \cdot M_{x\text{bot}}}{M_{a_{\text{bot}}}} \left[ \frac{1}{1 - \frac{P_{\text{bot}}}{P_{e_{\text{bot}}}}} \right] = 28.4\% \quad (\text{EQ 3.12-1})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

$$\text{Stress} := \frac{P_{\text{bot}}}{P_{e_{\text{bot}}}} + \frac{M_{x\text{bot}}}{M_{a_{\text{bot}}}} = 30.9\% \quad (\text{EQ 3.12-2})$$

Stress\_Check := if(Stress < 1.0, "OK", "NG")

Stress\_Check = "OK"

WIND DIRECTION	LOAD CASE	COMPONENT	Mmax	Pmax	% STRESSED
TOWARDS GUY WIRE	NESC HEAVY	WF14X87	72.2 ft-k	24.2 k	21.5 %
		WF14X87 W/ (4) L6X4X3/8	67.4 ft-k	41.8 k	17.4 %
	NESC EXTREME	WF14X87	75.1 ft-k	9.5 k	21.3 %
		WF14X87 W/ (4) L6X4X3/8	498.6 ft-k	18.2 k	96.5 %
AWAY FROM GUY WIRE	NESC HEAVY	WF14X87	152.1 ft-k	45.7 k	44.8 %
		WF14X87 W/ (4) L6X4X3/8	135.5 ft-k	63.3 k	32.7 %
	NESC EXTREME	WF14X87	150.3 ft-k	42.3 k	44.1 %
		WF14X87 W/ (4) L6X4X3/8	133.0 ft-k	51.1 k	30.9 %

**Anchor Bolt Analysis:**

**Input Data:**

Bolt Force:

Moment = Moment := 498.6·k·ft (User Input from Risa3D)

Axial = Axial := 18.2·k (User Input from Risa3D)

Anchor Bolt Data:

Use ASTM A36

Number of Anchor Bolts = N := 4 (User Input)

Distance Between Bolts = d := 23·in (User Input)

Bolt "Column" Distance = l := 3.0·in (User Input)

Bolt Ultimate Strength =  $F_u := 58·\text{ksi}$  (User Input)

Bolt Yield Strength =  $F_y := 36·\text{ksi}$  (User Input)

Bolt Modulus = E := 29000·ksi (User Input)

Diameter of Anchor Bolts = D := 2.5·in (User Input)

Threads per Inch = n := 4 (User Input)

**Anchor Bolt Analysis:**

Calculated Anchor Bolt Properties:

Net Area of Bolt = 
$$A_n := \frac{\pi}{4} \cdot \left( D - \frac{0.9743 \cdot \text{in}}{n} \right)^2 = 3.999 \cdot \text{in}^2$$

Bolt Tension Check:

Maximum Tensile Force = 
$$T_{\text{Max}} := \frac{\text{Moment}}{d \cdot \left( \frac{N}{2} \right)} - \frac{\text{Axial}}{N} = 125.5 \cdot \text{k}$$

Allowable Tensile Force (Net Area) = 
$$T_{\text{ALL,Net}} := 1.0 \cdot (A_n \cdot F_y) = 143.957 \cdot \text{kips}$$

Bolt Tension % of Capacity = 
$$\frac{T_{\text{Max}}}{T_{\text{ALL,Net}}} = 87.19 \cdot \%$$

Condition1 = 
$$\text{Condition1} := \text{if} \left( \frac{T_{\text{Max}}}{T_{\text{ALL,Net}}} \leq 1.00, \text{"OK"}, \text{"Overstressed"} \right)$$

Condition1 = "OK"

**Caisson Foundation:**

Input Data:

Shear Force =	$S := 9.8k \cdot 1.1 = 10.8\text{-kips}$	<i>USER INPUT-FROM PLS-Pole</i>
Overturing Moment =	$M := 498.6ft \cdot k \cdot 1.1 = 548\text{-ft} \cdot k$	<i>USER INPUT-FROM PLS-Pole</i>
Applied Axial Load =	$A1 := 18.2k \cdot 1.1 = 20\text{-kips}$	<i>USER INPUT-FROM PLS-Pole</i>
Bending Moment =	$Mu := 603.7ft \cdot k$	<i>USER INPUT-FROM LPILE</i>
Moment Capacity =	$Mn := 1767.6ft \cdot k$	<i>USER INPUT-FROM LPILE</i>
Foundation Diameter =	$d := 4ft$	<i>USER INPUT</i>
Overall Length of Caisson =	$L_c := 23ft$	<i>USER INPUT</i>
Depth From Top of Caisson to Grade =	$L_{pag} := 3ft$	<i>USER INPUT</i>
Number of Rebar =	$n := 30$	<i>USER INPUT</i>
Area of Rebar =	$Ar := 0.6in^2$	<i>USER INPUT</i>
Rebar Yield Strength =	$fy := 60ksi$	<i>USER INPUT</i>
Concrete Comp Strength =	$fc := 4ksi$	<i>USER INPUT</i>

Check Moment Capacity:

Factor of Safety =	$FS := \frac{0.9Mn}{Mu} = 2.6$
Factor of Safety Required =	$FS_{reqd} := 1.0$
	$FOSCheck := \text{if}(FS \geq FS_{reqd}, "OK", "NO GOOD")$
	<b>FOSCheck = "OK"</b>



Caisson Analysis.lpo

=====

LPILE Plus for Windows, Version 5.0 (5.0.47)

Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method

(c) 1985-2010 by Ensoft, Inc.  
All Rights Reserved

=====

This program is licensed to:

TJL  
Centek Engineering

-----

Files Used for Analysis

-----

Path to file locations: J:\Jobs\1607100.WI\40\_Norwalk CT  
CT5013\04\_Structural\Backup Documentation\Calcs\L-Pile\  
Name of input data file: Caisson Analysis.lpd  
Name of output file: Caisson Analysis.lpo  
Name of plot output file: Caisson Analysis.lpp  
Name of runtime file: Caisson Analysis.lpr

-----

Time and Date of Analysis

-----

Date: November 22, 2016 Time: 14:46:25

-----

Problem Title

-----

16071.40 / CT5013 - Rowayton / CL&P # 489s

-----

Program Options

-----

Units Used in Computations - US Customary Units: Inches, Pounds

Caisson Analysis.lpo

Basic Program Options:

Analysis Type 3:

- Computation of Nonlinear Bending Stiffness and Ultimate Bending Moment Capacity with Pile Response Computed Using Nonlinear EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis for fixed-length pile or shaft only
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- Additional p-y curves computed at specified depths

Solution Control Parameters:

- Number of pile increments = 100
- Maximum number of iterations allowed = 250
- Deflection tolerance for convergence = 1.0000E-04 in
- Maximum allowable deflection = 1.0000E+02 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing Increment (spacing of output points) = 0

-----  
Pile Structural Properties and Geometry  
-----

- Pile Length = 276.00 in
- Depth of ground surface below top of pile = 36.00 in
- Slope angle of ground surface = 0.00 deg.

Structural properties of pile defined using 2 points

Point No.	Point Depth in	Pile Diameter in	Moment of Inertia in**4	Pile Area Sq.in	Modulus of Elasticity lbs/Sq.in
1	0.0000	48.00000000	260576.0000	1809.6000	3300000.
2	276.0000	48.00000000	260576.0000	1809.6000	3300000.

Please note that because this analysis makes computations of ultimate moment capacity and pile response using nonlinear bending stiffness

Caisson Analysis.lpo

that the above values of moment of inertia and modulus of are not used for any computations other than total stress due to combined axial loading and bending.

-----  
Soil and Rock Layering Information  
-----

The soil profile is modelled using 1 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974

Distance from top of pile to top of layer = 36.000 in  
Distance from top of pile to bottom of layer = 276.000 in  
p-y subgrade modulus k for top of soil layer = 20.000 lbs/in\*\*3  
p-y subgrade modulus k for bottom of layer = 20.000 lbs/in\*\*3

(Depth of lowest layer extends 0.00 in below pile tip)

-----  
Effective Unit Weight of Soil vs. Depth  
-----

Effective unit weight of soil with depth defined using 2 points

Point No.	Depth X in	Eff. Unit Weight lbs/in**3
1	36.00	0.05800
2	276.00	0.05800

-----  
Shear Strength of Soils  
-----

Shear strength parameters with depth defined using 2 points

Point No.	Depth X in	Cohesion c lbs/in**2	Angle of Friction Deg.	E50 or k_rm	RQD %
1	36.000	0.00000	30.00	-----	-----
2	276.000	0.00000	30.00	-----	-----

Notes:

Caisson Analysis.lpo

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>rm</sub> are reported only for weak rock strata.

-----  
Loading Type  
-----

Static loading criteria was used for computation of p-y curves.

-----  
Pile-head Loading and Pile-head Fixity Conditions  
-----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Shear and Moment (BC Type 1)

Shear force at pile head = 10800.000 lbs

Bending moment at pile head = 6576000.000 in-lbs

Axial load at pile head = 20000.000 lbs

Non-zero moment at pile head for this load case indicates the pile-head may rotate under the applied pile-head loading, but is not a free-head (zero moment) condition.

-----  
Output of p-y Curves at Specified Depths  
-----

p-y curves are generated and printed for verification at 1 depths.

Depth No.	Depth Below Pile Head in	Depth Below Ground Surface in
1	144.000	108.000

Caisson Analysis.lpo

Depth of ground surface below top of pile = 36.00 in

-----  
Computations of Nominal Moment Capacity and Nonlinear Bending Stiffness  
-----

Number of sections = 1

Pile Section No. 1

The sectional shape is a circular drilled shaft (bored pile).

Outside Diameter = 48.0000 in

Material Properties:

Compressive Strength of Concrete = 4.000 kip/in\*\*2  
Yield Stress of Reinforcement = 60. kip/in\*\*2  
Modulus of Elasticity of Reinforcement = 29000. kip/in\*\*2  
Number of Reinforcing Bars = 30  
Area of Single Bar = 0.60000 in\*\*2  
Number of Rows of Reinforcing Bars = 15  
Area of Steel = 18.000 in\*\*2  
Area of Shaft = 1809.557 in\*\*2  
Percentage of Steel Reinforcement = 0.995 percent  
Cover Thickness (edge to bar center) = 3.000 in

Unfactored Axial Squash Load Capacity = 7171.30 kip

Distribution and Area of Steel Reinforcement

Row Number	Area of Reinforcement in**2	Distance to Centroidal Axis in
1	1.200	20.885
2	1.200	19.972
3	1.200	18.187
4	1.200	15.606
5	1.200	12.343
6	1.200	8.541
7	1.200	4.366
8	1.200	0.000
9	1.200	-4.366
10	1.200	-8.541

Caisson Analysis.lpo

11	1.200	-12.343
12	1.200	-15.606
13	1.200	-18.187
14	1.200	-19.972
15	1.200	-20.885

Axial Thrust Force = 20000.00 lbs

Bending Max. Steel Moment Stress in-lbs psi	Bending Stiffness lb-in <sup>2</sup>	Bending Curvature rad/in	Maximum Strain in/in	Neutral Axis Position inches	Max. Concrete Stress psi
1324987. 842.82568	1.059990E+12	0.00000125	0.00003296	26.36540365	117.00847
2636922. 1603.26061	1.054769E+12	0.00000250	0.00006307	25.22897959	221.98712
3935784. 2363.09567	1.049542E+12	0.00000375	0.00009317	24.84465551	325.18842
5222215. 3125.30801	1.044443E+12	0.00000500	0.00012334	24.66888857	426.96508
5222215. 5629.52709	8.355544E+11	0.00000625	0.00008641	13.82550001	298.29981
5222215. 6805.67479	6.962953E+11	0.00000750	0.00010196	13.59450102	350.35252
5222215. 7988.77275	5.968245E+11	0.00000875	0.00011727	13.40211153	401.14626
5222215. 9171.30009	5.222215E+11	0.00001000	0.00013260	13.25978708	451.58008
5222215. 10353.25214	4.641969E+11	0.00001125	0.00014795	13.15085363	501.65282
5222215. 11534.62547	4.177772E+11	0.00001250	0.00016332	13.06530333	551.36314
5222215. 12715.41553	3.797974E+11	0.00001375	0.00017871	12.99677038	600.70984
5222215. 13895.61982	3.481476E+11	0.00001500	0.00019412	12.94100618	649.69144
5222215. 15075.23171	3.213671E+11	0.00001625	0.00020955	12.89507818	698.30694
5222215. 16254.24871	2.984123E+11	0.00001750	0.00022500	12.85688353	746.55484
5222215. 17432.66677	2.785181E+11	0.00001875	0.00024047	12.82488298	794.43377
5222215. 18609.27630	2.611107E+11	0.00002000	0.00025600	12.80000067	842.07351

Caisson Analysis.lpo

5259564.	2.475089E+11	0.00002125	0.00027200	12.80000067	890.73148
19772.35607					
5539490.	2.461996E+11	0.00002250	0.00028758	12.78131819	937.62143
20947.62615					
5830224.	2.454831E+11	0.00002375	0.00030314	12.76380873	984.01136
22123.44280					
6120579.	2.448231E+11	0.00002500	0.00031872	12.74896860	1030.02985
23298.59362					
6410553.	2.442116E+11	0.00002625	0.00033433	12.73642588	1075.67563
24473.07145					
6700146.	2.436417E+11	0.00002750	0.00034996	12.72587442	1120.94724
25646.87059					
6989354.	2.431080E+11	0.00002875	0.00036562	12.71705961	1165.84303
26819.98678					
7278173.	2.426058E+11	0.00003000	0.00038129	12.70976973	1210.36141
27992.41537					
7566603.	2.421313E+11	0.00003125	0.00039699	12.70383024	1254.50103
29164.14866					
7854639.	2.416812E+11	0.00003250	0.00041272	12.69908953	1298.26016
30335.18273					
8142280.	2.412527E+11	0.00003375	0.00042847	12.69542170	1341.63735
31505.51042					
8429524.	2.408435E+11	0.00003500	0.00044425	12.69271803	1384.63104
32675.12540					
8716366.	2.404515E+11	0.00003625	0.00046004	12.69088125	1427.23930
33844.02508					
9002806.	2.400748E+11	0.00003750	0.00047587	12.68983412	1469.46089
35012.19918					
9288840.	2.397120E+11	0.00003875	0.00049172	12.68950510	1511.29410
36179.64222					
9574464.	2.393616E+11	0.00004000	0.00050759	12.68982840	1552.73681
37346.35243					
9859676.	2.390224E+11	0.00004125	0.00052349	12.69075251	1593.78762
38512.32048					
10144474.	2.386935E+11	0.00004250	0.00053942	12.69223166	1634.44505
39677.53744					
10428855.	2.383738E+11	0.00004375	0.00055537	12.69422007	1674.70695
40842.00104					
10712813.	2.380625E+11	0.00004500	0.00057135	12.69668055	1714.57159
42005.70443					
10996349.	2.377589E+11	0.00004625	0.00058736	12.69958162	1754.03740
43168.63848					
11279460.	2.374623E+11	0.00004750	0.00060339	12.70289469	1793.10272
44330.79470					
11562140.	2.371721E+11	0.00004875	0.00061945	12.70658827	1831.76514
45492.17276					
12126198.	2.366087E+11	0.00005125	0.00065165	12.71503401	1907.87503
47812.55221					
12688500.	2.360651E+11	0.00005375	0.00068396	12.72475576	1982.35204

Caisson Analysis.lpo

50129.71805						
13249018.	2.355381E+11	0.00005625	0.00071638	12.73561907	2055.18051	
52443.61207						
13807726.	2.350251E+11	0.00005875	0.00074892	12.74751520	2126.34460	
54754.17124						
14364596.	2.345240E+11	0.00006125	0.00078157	12.76035261	2195.82777	
57061.33352						
14919596.	2.340329E+11	0.00006375	0.00081435	12.77405405	2263.61289	
59365.03701						
15407432.	2.325650E+11	0.00006625	0.00084591	12.76846075	2326.96434	
60000.00000						
15781782.	2.295532E+11	0.00006875	0.00087524	12.73069239	2384.05091	
60000.00000						
16117798.	2.262147E+11	0.00007125	0.00090381	12.68510485	2438.13481	
60000.00000						
16404909.	2.224394E+11	0.00007375	0.00093139	12.62903166	2488.85554	
60000.00000						
16691086.	2.188995E+11	0.00007625	0.00095904	12.57757902	2538.33424	
60000.00000						
16911509.	2.147493E+11	0.00007875	0.00098515	12.50981569	2583.68682	
60000.00000						
17122953.	2.107440E+11	0.00008125	0.00101111	12.44444132	2627.56255	
60000.00000						
17333672.	2.069692E+11	0.00008375	0.00103713	12.38369894	2670.32923	
60000.00000						
17541375.	2.033783E+11	0.00008625	0.00106316	12.32643843	2711.87248	
60000.00000						
17690342.	1.993278E+11	0.00008875	0.00108758	12.25442362	2749.66268	
60000.00000						
17838739.	1.954930E+11	0.00009125	0.00111206	12.18692064	2786.46546	
60000.00000						
17986561.	1.918567E+11	0.00009375	0.00113659	12.12357473	2822.27461	
60000.00000						
18133800.	1.884031E+11	0.00009625	0.00116117	12.06406546	2857.08347	
60000.00000						
18280449.	1.851185E+11	0.00009875	0.00118580	12.00810671	2890.88554	
60000.00000						
18425671.	1.819819E+11	0.00010125	0.00121378	11.98793364	2928.14179	
60000.00000						
18522971.	1.785347E+11	0.00010375	0.00123634	11.91657114	2956.90636	
60000.00000						
18619843.	1.752456E+11	0.00010625	0.00125895	11.84898806	2984.82327	
60000.00000						
18716298.	1.721039E+11	0.00010875	0.00128161	11.78493547	3011.88845	
60000.00000						
18812317.	1.690995E+11	0.00011125	0.00130431	11.72417021	3038.09538	
60000.00000						
18907912.	1.662234E+11	0.00011375	0.00132706	11.66648912	3063.44010	
60000.00000						



Caisson Analysis.lpo

19003066. 60000.00000	1.634672E+11	0.00011625	0.00134986	11.61168909	3087.91610
19097780. 60000.00000	1.608234E+11	0.00011875	0.00137270	11.55959558	3111.51840
19192047. 60000.00000	1.582849E+11	0.00012125	0.00139559	11.51004267	3134.24115
19270026. 60000.00000	1.557174E+11	0.00012375	0.00141779	11.45685911	3155.35241
19330162. 60000.00000	1.531102E+11	0.00012625	0.00143920	11.39960718	3174.86119
19389961. 60000.00000	1.506016E+11	0.00012875	0.00146066	11.34490156	3193.59674
19449404. 60000.00000	1.481859E+11	0.00013125	0.00148215	11.29259062	3211.55340
19508506. 60000.00000	1.458580E+11	0.00013375	0.00150369	11.24255133	3228.72753
19508506. 60000.00000	1.431817E+11	0.00013625	0.00152600	11.19999933	3245.67835
19639723. 60000.00000	1.415476E+11	0.00013875	0.00155287	11.19184828	3265.07011
19696102. 60000.00000	1.394414E+11	0.00014125	0.00157390	11.14266729	3279.19277
19752150. 60000.00000	1.374063E+11	0.00014375	0.00159498	11.09548903	3292.56208
19807873. 60000.00000	1.354384E+11	0.00014625	0.00161609	11.05021906	3305.17385
19863262. 60000.00000	1.335345E+11	0.00014875	0.00163726	11.00676012	3317.02293
19973033. 60000.00000	1.299059E+11	0.00015375	0.00167971	10.92493773	3338.41394
20070939. 60000.00000	1.264311E+11	0.00015875	0.00172160	10.84469461	3356.38878
20134736. 60000.00000	1.229602E+11	0.00016375	0.00176131	10.75606298	3370.53750
20197469. 60000.00000	1.196887E+11	0.00016875	0.00180117	10.67358828	3381.96101
20259136. 60000.00000	1.165993E+11	0.00017375	0.00184119	10.59676123	3390.62632
20319705. 60000.00000	1.136767E+11	0.00017875	0.00188136	10.52511549	3396.49887
20379166. 60000.00000	1.109070E+11	0.00018375	0.00192170	10.45824766	3399.54364
20447417. 60000.00000	1.083307E+11	0.00018875	0.00196300	10.40000010	3395.34143
20507756. 60000.00000	1.058465E+11	0.00019375	0.00201290	10.38916826	3392.21642
20560711. 60000.00000	1.034501E+11	0.00019875	0.00205242	10.32665205	3396.95639
20613048.	1.011683E+11	0.00020375	0.00209212	10.26805544	3399.51858

Caisson Analysis.lpo

60000.00000						
20664517.	9.899170E+10	0.00020875	0.00213204	10.21335554	3396.91679	
60000.00000						
20715000.	9.691228E+10	0.00021375	0.00217221	10.16240072	3387.88665	
60000.00000						
20759360.	9.489993E+10	0.00021875	0.00221183	10.11123133	3391.12450	
60000.00000						
20784660.	9.289234E+10	0.00022375	0.00224925	10.05251455	3395.48792	
60000.00000						
20809642.	9.097111E+10	0.00022875	0.00228679	9.99691057	3398.39914	
60000.00000						
20834293.	8.913066E+10	0.00023375	0.00232446	9.94422483	3399.83812	
60000.00000						
20858292.	8.736457E+10	0.00023875	0.00236235	9.89465761	3396.04178	
60000.00000						
20881759.	8.566875E+10	0.00024375	0.00240042	9.84786558	3388.62542	
60000.00000						
20905012.	8.404025E+10	0.00024875	0.00243858	9.80335093	3384.12133	
60000.00000						
20928042.	8.247504E+10	0.00025375	0.00247685	9.76098204	3389.57932	
60000.00000						
20950849.	8.096946E+10	0.00025875	0.00251522	9.72064161	3393.90772	
60000.00000						
20973418.	7.952007E+10	0.00026375	0.00255368	9.68221521	3397.09218	
60000.00000						
20995756.	7.812374E+10	0.00026875	0.00259226	9.64560556	3399.11836	
60000.00000						
21017858.	7.677756E+10	0.00027375	0.00263093	9.61071825	3399.97138	
60000.00000						
21100251.	7.569597E+10	0.00027875	0.00267600	9.60000086	3393.22753	
60000.00000						
21209126.	7.474582E+10	0.00028375	0.00272400	9.60000086	3384.24368	
60000.00000						
21209126.	7.345152E+10	0.00028875	0.00276749	9.58436823	3380.42459	
60000.00000						
21209126.	7.220128E+10	0.00029375	0.00280536	9.55015612	3385.52407	
60000.00000						
21209126.	7.099289E+10	0.00029875	0.00284331	9.51734591	3389.87077	
60000.00000						
21209126.	6.982428E+10	0.00030375	0.00288133	9.48587179	3393.45591	
60000.00000						
21209126.	6.869353E+10	0.00030875	0.00291944	9.45566797	3396.27039	
60000.00000						
21209126.	6.759881E+10	0.00031375	0.00295762	9.42668009	3398.30528	
60000.00000						
21212444.	6.654884E+10	0.00031875	0.00299589	9.39885664	3399.55130	
60000.00000						
21231293.	6.557928E+10	0.00032375	0.00303423	9.37214613	3399.99884	
60000.00000						

Caisson Analysis.lpo					
21249603.	6.463758E+10	0.00032875	0.00307286	9.34711218	3394.84914
60000.00000					
21267298.	6.372224E+10	0.00033375	0.00311179	9.32372332	3389.31891
60000.00000					
21277159.	6.281080E+10	0.00033875	0.00315107	9.30205107	3383.69684
60000.00000					
21281086.	6.190861E+10	0.00034375	0.00318855	9.27578688	3378.54911
60000.00000					
21284968.	6.103217E+10	0.00034875	0.00322609	9.25042963	3373.38721
60000.00000					
21292559.	5.935208E+10	0.00035875	0.00330132	9.20227575	3378.97202
60000.00000					
21299932.	5.776253E+10	0.00036875	0.00337676	9.15732336	3387.00395
60000.00000					
21307088.	5.625634E+10	0.00037875	0.00345243	9.11533499	3393.14919
60000.00000					
21314014.	5.482704E+10	0.00038875	0.00352833	9.07609320	3397.36688
60000.00000					
21320697.	5.346883E+10	0.00039875	0.00360446	9.03940344	3399.61475
60000.00000					
21326906.	5.217592E+10	0.00040875	0.00368102	9.00555182	3396.65749
60000.00000					
21332228.	5.094263E+10	0.00041875	0.00375829	8.97502184	3387.86624
60000.00000					
21332399.	4.975487E+10	0.00042875	0.00383927	8.95457125	3378.09446
60000.00000					

Unfactored (Nominal) Moment Capacity at Concrete Strain of 0.003 = 21214.46658 in-kip

p-y Curve in Sand Computed Using Reese Criteria for Static Loading Conditions

Soil Layer Number	=	1
Depth below pile head	=	144.000 in
Depth below ground surface	=	108.000 in
Equivalent Depth (see note)	=	108.000 in
Pile Diameter	=	48.000 in
Angle of Friction	=	30.000 deg.
Avg. Eff. Unit Weight	=	0.05800 pci
k	=	20.000 pci
A (static)	=	1.3550
B (static)	=	0.9550
Pst	=	2095.083 lbs/in
Psd	=	8642.855 lbs/in
Ps	=	2095.083 lbs/in
Cbar	=	2156.1406

Caisson Analysis.lpo

n = 2.9844  
 m = 838.0332  
 yk = 0.9973 in  
 pm = 2000.804 lbs/in  
 ym = 0.8000 in  
 pu = 2838.838 lbs/in  
 yu = 1.8000 in  
 p-multiplier = 1.00000  
 y-multiplier = 1.00000

This p-y curve is computed using the equivalent depth.

y, in	p, lbs/in	
0.0000	0.0000	
0.0666667	144.0000	*
0.1333333	288.0000	*
0.2000000	432.0000	*
0.2666667	576.0000	*
0.3333333	720.0000	*
0.4000000	864.0000	*
0.4666667	1008.0000	*
0.5333333	1152.0000	*
0.6000000	1296.0000	*
0.6666667	1440.0000	*
0.7333333	1584.0000	*
0.8000000	1728.0000	*
1.3000	2419.8209	
1.8000	2838.8376	
49.8000	2838.8376	
97.8000	2838.8376	

\* p value(s) computed using  $p = k * \text{Eff} * y$

-----  
 Computed Values of Load Distribution and Deflection  
 for Lateral Loading for Load Case Number 1  
 -----

Pile-head boundary conditions are Shear and Moment (Pile-head Condition Type 1)  
 Specified shear force at pile head = 10800.000 lbs  
 Specified moment at pile head = 6576000.000 in-lbs  
 Specified axial load at pile head = 20000.000 lbs

Caisson Analysis.lpo

Depth Es*h	Deflect. X	Moment M	Shear V	Slope S	Total Stress	Flx. Rig. EI	Soil Res. p
F/L	in	lbs-in	lbs	Rad.	lbs/in**2	lbs-in**2	lbs/in
0.000 0.000	1.231	6.58E+06	10800.	-0.008909	616.726	2.44E+11	0.000

Please note that because this analysis makes computations of ultimate moment capacity and pile response using nonlinear bending stiffness that the above values of total stress due to combined axial stress and bending may not be representative of actual conditions.

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

Pile-head deflection = 1.23096277 in  
 Computed slope at pile head = -0.00890910  
 Maximum bending moment = 7244822. lbs-in  
 Maximum shear force = -57275.06102 lbs  
 Depth of maximum bending moment = 74.52000000 in  
 Depth of maximum shear force = 198.72000 in  
 Number of iterations = 30  
 Number of zero deflection points = 1

Summary of Pile Response(s)

Definition of Symbols for Pile-Head Loading Conditions:


Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = Pile-head Moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = Pile-head Shear Force lbs  
 Type 4 = Deflection and Moment, S = Pile-head Slope, radians  
 Type 5 = Deflection and Slope, R = Rot. Stiffness of Pile-head in-lbs/rad

Caisson Analysis.lpo


Load Type	Pile-Head Condition 1	Pile-Head Condition 2	Axial Load lbs	Pile-Head Deflection in	Maximum Moment in-lbs	Maximum Shear lbs
1	V= 10800.	M= 6.58E+06	20000.0000	1.2310	7244822.	-57275.0610

The analysis ended normally.

Lateral Deflection (in)




Bending Moment (in-kips)





Shear Force (kips)



▽ Case 1

**Job :** AT&T - CT5013 Rowayton  
**Address:** 310 Rowayton Ave., Norwalk, CT  
**Description:** Guy Anchor Evaluation

**Project No.** 16071.40  
**Computed by** TJL  
**Checked by** CFC

**Page** of  
**Sheet** 1 of 2  
**Date** 11/22/16  
**Date**


**CHECK UPLIFT RESISTANCE**

**RESULTS FROM COMPUTER ANALYSIS:**

Uplift = 16.5 kips  
 Sliding = 6 kips

**CONCRETE PARAMETERS:**

$\gamma_{conc}$  = 150 pcf  
 w = 4 ft  
 h = 1.83 ft  
 d = 6.5 ft  
 Vol. = 47.58 ft<sup>3</sup>  
 Wc = 7.14 kips



**Foundation Section**


**SOIL PARAMETERS:**

$\gamma_{soil}$  = 90 pcf  
 $h_{soil}$  = 11.17 ft  
 x = 6.45 ft

**Soil Weight (Wr):**

(1) = 26.14 kips  
 (2) = 42.14 kips  
 (3) = 25.93 kips  
 (4) = 43.78 kips

\* (5) Anchor Reinf. = 0 kips  
**Total = 137.99 kips**



**Foundation Plan View**

**CHECK UPLIFT**

$W_r + W_c > \text{UPLIFT}$

145.13 > 18.15 OK

→ **GUY ANCHORS AGAINST UPLIFT ARE ADEQUATE**

**Job :** AT&T - CT5013 Rowayton  
**Address:** 310 Rowayton Ave., Norwalk, CT  
**Description:** Guy Anchor Evaluation

**Project No.** 16071.40  
**Computed by** TJL  
**Checked by** CFC

**Page** of  
**Sheet** 2 of 2  
**Date** 11/22/16  
**Date**


**CHECK SLIDING RESISTANCE**

**SOIL PARAMETERS**

$\gamma_{soil} = 90$  pcf  
 $\gamma_{soil2} = 27.6$  pcf  
 $h_{soil} = 11.17$  ft  
 $h = 1.83$  ft  
 $\phi = 30$  degrees

**ANCHOR PARAMETERS**

$w = 4.0$  ft  
 $h = 1.8$  ft  
 $d = 6.5$  ft



**Foundation Elevation View**

$K_a = 0.33$

$K_p = 3.00$

$\Delta = 2.67$

**HORIZONTAL FORCES**

1 = 31.89 k  
 2 = 0.80 k  
**RESIST TO SLIDING =** 32.69 k

**SOIL & CONCRETE WEIGHT =**  $W_r + W_c = 145.13$  k  
**UPLIFT REACTIONS =** -16.5 k  
**SUM =** 128.63 k

**COEF. OF FRICTION, (0.45) =** 57.88 k  
**RESIST TO SLIDING =** 32.69 k  
**SUM =** 90.57 k

**CHECK SLIDING**

**90.6 > 6.6 OK**

→ **GUY ANCHORS AGAINST SLIDING ARE ADEQUATE**

Section 1 - RFDS GENERAL INFORMATION

<b>RFDS NAME:</b>	CT5013	<b>DATE:</b>	09/11/2015	<b>RF DESIGN ENG:</b>	Bayani Del Moro	<b>RF PERF ENG:</b>		<b>RFDS PROGRAM TYPE:</b>	2016 LTE Multi Carrier
<b>ISSUE:</b>	Bronze	<b>Approved? (Y/N):</b>	Yes	<b>RF DESIGN PHONE:</b>	(401)834-5095	<b>RF PERF PHONE:</b>		<b>RFDS TECHNOLOGY:</b>	1xBBU RRH Add
<b>REVISION:</b>	Preliminary	<b>RF MANAGER:</b>	Cameron Syme	<b>RF DESIGN EMAIL:</b>	bd250h@att.com	<b>RF PERF EMAIL:</b>		<b>Status:</b>	Final
<b>INITIATIVE /PROJECT:</b>	New RFDS (RRUS32, add XMU, 2nd CPRI from RRUS32)				<b>TRIDENT:</b>		<b>Status:</b>	RF Approval	
		<b>GSM FREQUENCY:</b>	850	<b>RFDS ID:</b>	1090396				
		<b>UMTS FREQUENCY:</b>	850, 1900	<b>RFDS Version:</b>	1.00				
		<b>LTE FREQUENCY:</b>	700, 1900	<b>Created By:</b>	om636a				
				<b>Date Created:</b>	2/25/2016 11:29:14 AM				
				<b>Date Updated:</b>	2/25/2016 3:24:38 PM				
				<b>Updated By:</b>	om636a				
		<b>I-PLAN JOB # 1:</b>	NER-RCTB-16-00605	<b>IPLAN PRD GRP    SUB GRP #1:</b>	LTE Multi Carrier    LTE BWE				
		<b>I-PLAN JOB # 2:</b>		<b>IPLAN PRD GRP    SUB GRP #2:</b>					
		<b>I-PLAN JOB # 3:</b>		<b>IPLAN PRD GRP    SUB GRP #3:</b>					
		<b>I-PLAN JOB # 4:</b>		<b>IPLAN PRD GRP    SUB GRP #4:</b>					

Section 2 - LOCATION INFORMATION

<b>USID:</b>	46002	<b>FA LOCATION CODE:</b>	10071190	<b>LOCATION NAME:</b>	ROWAYTON	<b>ORACLE PTN # 1:</b>		<b>PACE JOB # 1:</b>	MRCTB018025
<b>REGION:</b>	NORTHEAST	<b>MARKET CLUSTER:</b>	NEW ENGLAND	<b>MARKET:</b>	CONNECTICUT	<b>ORACLE PTN # 2:</b>		<b>PACE JOB # 2:</b>	
<b>ADDRESS:</b>	310 ROWAYTON AVENUE	<b>CITY:</b>	NORWALK	<b>STATE:</b>	CT	<b>ORACLE PTN # 3:</b>		<b>PACE JOB # 3:</b>	
<b>ZIP CODE:</b>	06853	<b>COUNTY:</b>	FAIRFIELD	<b>MSA / RSA:</b>		<b>ORACLE PTN # 4:</b>		<b>PACE JOB # 4:</b>	
<b>LATITUDE (D-M-S):</b>	41d 4m38.97084s	<b>LONGITUDE (D-M-S):</b>	-73d -26m -32.99604s	<b>LAT (DEC. DEG.):</b>	41.0774919	<b>SEARCH RING NAME:</b>			
<b>DIRECTIONS, ACCESS AND EQUIPMENT LOCATION:</b>	<p>5013 ROWAYTON</p> <p>I-95 NORTH NEW ENGLAND THRUWAY GET OFF AT EXIT 12 MAKE RIGHT AT END OF RAMP ONTO ROUTE 136 NORTH.TAKE THIS 1.1 MILES.MAKE LEFT AT TRAFFIC LIGHT ONTO ROWAYTON AVE.TAKE THIS TO STOP SIGN.MAKE RIGHT ONTO BELMONT PLACE AND THEN FIRST LEFT INTO ROWAYTON TRAIN STATION OUR MODULAR IS LOCATED AT THE BACK OF THE LOT.ANTENNAS ARE MOUNTED AT TOP OF LATTICE POWER TOWER. DEMARC IN GRAY BOX OUTSIDE SITE.</p> <p>ADDRESS: 310 ROWAYTON AVE.NORWALK, CONNECTICUT 06853</p> <p>CONTACT: DAVE WILLARD 203 337-3606 METRO NORT/H : VINNIE COLENERO 860 865-6633 NORTHEST UTILITIES FOR ANTENNA REPAIRS.</p> <p>METER # : 02-489-852</p> <p>GENERATOR PLUG #: AR20033RS</p> <p>SECURITY: NONE</p> <p>ACCESS: 24/7 GATE ACCESS 8899 COMBO</p> <p>TRACESS: 7083664</p> <p>POWER COMPANY: NORTHEAST UTILITIES 800-286-2000</p> <p>FIRE: 203 853-9411 ROWAYTON FIRE DEPT.</p> <p>POLICE: 203 655-9239 DARIEN POLICE DEPT.</p> <p>T-1 CIRCUIT NUMBERS TDMA: HCGS 675232 AND HCGS 675233</p> <p>GSM : HCGS691039</p> <p>VERIZON COMMUNICATIONS</p>				<b>SEARCH RING ID:</b>		<b>CASPR INITIATIVE # 1:</b>		
						<b>BTA:</b>		<b>CASPR INITIATIVE # 2:</b>	
						<b>LONG (DEC. DEG.):</b>	-73.4424989	<b>CASPR INITIATIVE # 3:</b>	
		<b>BORDER CELL WITH CONTOUR COORD:</b>		<b>CASPR INITIATIVE # 4:</b>					
		<b>AM STUDY REQ'D (Y/N):</b>	No						
		<b>FREQ COORD:</b>							

Section 3 - LICENSE COVERAGE/FILING INFORMATION

<b>CGSA - NO FILING TRIGGERED (Yes/No):</b>	No	<b>CGSA LOSS:</b>		<b>PCS REDUCED - UPS ZIP:</b>		<b>CGSA CALL SIGNS:</b>	KNKA256,KNKA256,KNKA256
<b>CGSA - MINOR FILING NEEDED (Yes/No):</b>	No	<b>CGSA EXT AGMT NEEDED:</b>		<b>PCS POPS REDUCED:</b>			
<b>CGSA - MAJOR FILING NEEDED (Yes/No):</b>	Yes	<b>CGSA SCORECARD UPDATED:</b>					

Section 4 - TOWER/REGULATORY INFORMATION

<b>STRUCTURE AT&amp;T OWNED?:</b>	Yes	<b>GROUND ELEVATION (ft):</b>		<b>STRUCTURE TYPE:</b>	UTILITY	<b>MARKET LOCATION 700 MHz Band:</b>	
<b>ADDITIONAL REGULATORY?:</b>	Yes	<b>HEIGHT OVERALL (ft):</b>	0.00	<b>FCC ASR NUMBER:</b>	NR	<b>MARKET LOCATION 850 MHz Band:</b>	
<b>SUB-LEASE RIGHTS?:</b>	Yes	<b>STRUCTURE HEIGHT (ft):</b>	95.00			<b>MARKET LOCATION 1900 MHz Band:</b>	
<b>LIGHTING TYPE:</b>	NOT REQUIRED					<b>MARKET LOCATION AWS Band:</b>	
						<b>MARKET LOCATION WCS Band:</b>	
						<b>MARKET LOCATION Future Band:</b>	

Section 5 - E-911 INFORMATION - existing



Section 6 - RBS GENERAL INFORMATION - existing

	GSM 1ST RBS	UMTS 1ST RBS	UMTS 2ND RBS	UMTS 3RD RBS	LTE 1ST RBS							
<b>RBS ID:</b>	469109	172503	222793	401757	360162							
<b>CTS COMMON ID:</b>	321G5013	CTU5013	CTV5013	CTU4013	CTL05013							
<b>CELL ID / BCF:</b>	321G5013	CTU5013	CTU5013	CTU4013	CTL05013							
<b>BTA/TID:</b>	321M	321V	321U	321W	321L							
<b>4-DIGIT SITE ID:</b>	5013	5013	5013	04013	5013							
<b>COW OR TOY?:</b>	No	No	No	No	No							
<b>CELL SITE TYPE:</b>	SECTORIZED	SECTORIZED	SECTORIZED	SECTORIZED	SECTORIZED							
<b>SITE TYPE:</b>	BTS-CONVENTIONAL	MACRO-CONVENTIONAL	MACRO-CONVENTIONAL	MACRO-CONVENTIONAL	MACRO-CONVENTIONAL							
<b>BTS LOCATION ID:</b>	GROUND	INTERNAL	GROUND	INTERNAL	INTERNAL							
<b>ORIGINATING CO:</b>	CINGULAR	CINGULAR	CINGULAR	CINGULAR	CINGULAR							
<b>CELLULAR NETWORK:</b>	GOLD	GOLD	GOLD	GOLD	GOLD							
<b>OPS DISTRICT:</b>	CT-South	CT SOUTH-WEST	CT SOUTH-WEST	CT-SOUTH	CT SOUTH-WEST							
<b>RF DISTRICT:</b>	NPO Triage	NPO TRIAGE	BRIDGEPORT	NPO TRIAGE	NPO TRIAGE							
<b>OPS ZONE:</b>	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS							
<b>RF ZONE:</b>	Hotseat	HOTSEAT	BBP02	HOTSEAT	HOTSEAT							
<b>BASE STATION TYPE:</b>	BASE	BASE	OVERLAY	OVERLAY	BASE							
<b>EQUIPMENT NAME:</b>	ROWAYTON	ROWAYTON	ROWAYTON	ROWAYTON	ROWAYTON							
<b>DISASTER PRIORITY:</b>	0	2	0	0	3							

Section 6 - RBS GENERAL INFORMATION - final

	GSM 1ST RBS	UMTS 1ST RBS	UMTS 2ND RBS	UMTS 3RD RBS	LTE 1ST RBS							
<b>RBS ID:</b>	469109	172503	222793	401757	360162							
<b>CTS COMMON ID:</b>	321G5013	CTU5013	CTV5013	CTU4013	CTL05013							
<b>CELL ID / BCF:</b>	321G5013	CTU5013	CTU5013	CTU4013	CTL05013							
<b>BTA/TID:</b>	321M	321V	321U	321W	321L							
<b>4-DIGIT SITE ID:</b>	5013	5013	5013	04013	5013							
<b>COW OR TOY?:</b>	No	No	No	No	No							
<b>CELL SITE TYPE:</b>	SECTORIZED	SECTORIZED	SECTORIZED	SECTORIZED	SECTORIZED							
<b>SITE TYPE:</b>	BTS-CONVENTIONAL	MACRO-CONVENTIONAL	MACRO-CONVENTIONAL	MACRO-CONVENTIONAL	MACRO-CONVENTIONAL							
<b>BTS LOCATION ID:</b>	GROUND	INTERNAL	GROUND	INTERNAL	INTERNAL							
<b>ORIGINATING CO:</b>	CINGULAR	CINGULAR	CINGULAR	CINGULAR	CINGULAR							
<b>CELLULAR NETWORK:</b>	GOLD	GOLD	GOLD	GOLD	GOLD							
<b>OPS DISTRICT:</b>	CT-South	CT-South	CT-South	CT-South	CT-South							
<b>RF DISTRICT:</b>	NPO Triage	NPO Triage	Bridgeport	NPO Triage	NPO Triage							
<b>OPS ZONE:</b>	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS	NE_CT_S_FRFD_SW_CS							
<b>RF ZONE:</b>	Hotseat	Hotseat	BBP02	Hotseat	Hotseat							
<b>BASE STATION TYPE:</b>	BASE	BASE	OVERLAY	OVERLAY	BASE							
<b>EQUIPMENT NAME:</b>	ROWAYTON	ROWAYTON	ROWAYTON	ROWAYTON	ROWAYTON							
<b>DISASTER PRIORITY:</b>	0	2	0	0	3							

Section 7 - RBS SPECIFIC INFORMATION - existing

	GSM 1ST RBS	UMTS 1ST RBS	UMTS 2ND RBS	UMTS 3RD RBS	LTE 1ST RBS						
<b>MSC:</b>											
<b>BSC/RNC/MME POOL ID:</b>	BRIDGEPORT BSC 02	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	FF01					
<b>LAC:</b>	05011	05989	05989	05989							
<b>RAC:</b>											
<b>EQUIPMENT VENDOR:</b>	NOKIA	ERICSSON	ERICSSON	ERICSSON	ERICSSON						
<b>EQUIPMENT TYPE:</b>	ULTRASITE 850	3206 INDOOR	3106 OUTDOOR	6601 MAIN UNIT UMTS	6601 INDOOR MU						
<b>BASEBAND CONFIGURATION:</b>											
<b>LOCATION:</b>											
<b>CABINET LOCATION:</b>											
<b>MARKET STATE CODE:</b>					CT						
<b>AGPS:</b>	Yes	Yes	Yes	Yes	Yes						
<b>NODE B NUMBER:</b>	0	0	0	0	5013						
<b>PARENT NAME:</b>	BRIDGEPORT BSC 02	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	FF01					

Section 7 - RBS SPECIFIC INFORMATION - final

	GSM 1ST RBS	UMTS 1ST RBS	UMTS 2ND RBS	UMTS 3RD RBS	LTE 1ST RBS						
<b>MSC:</b>											
<b>BSC/RNC/MME POOL ID:</b>	BRPTCTBSC02	BRPTCT04CRBR06	BRPTCT04CRBR06	BRPTCT04CRBR06	BRPTCT04CRBR06	FF01					
<b>LAC:</b>	05011	05989	05989	05989							
<b>RAC:</b>											
<b>EQUIPMENT VENDOR:</b>	NOKIA	ERICSSON	ERICSSON	ERICSSON	ERICSSON						
<b>EQUIPMENT TYPE:</b>	ULTRASITE 850	3206 INDOOR	3106 OUTDOOR	6601 MAIN UNIT UMTS	6601 INDOOR MU						
<b>BASEBAND CONFIGURATION:</b>											
<b>LOCATION:</b>											
<b>CABINET LOCATION:</b>											
<b>MARKET STATE CODE:</b>					CT						
<b>AGPS:</b>	Yes	Yes	Yes	Yes	Yes						
<b>NODE B NUMBER:</b>	0	0	0	0	5013						
<b>PARENT NAME:</b>	BRIDGEPORT BSC 02	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820	BRIDGEPORT RNC06 ERICSSON 3820						













Section 15A - CURRENT SECTOR/CELL INFORMATION - SECTOR A (OR OMNI)

ANTENNA COMMON FIELDS	ANTENNA POSITION 1	ANTENNA POSITION 2	ANTENNA POSITION 3	ANTENNA POSITION 4	ANTENNA POSITION 5	ANTENNA POSITION 6	ANTENNA POSITION 7
ANTENNA MAKE - MODEL	FX-X-CD-65-12-65-14-00T-ST						
ANTENNA VENDOR	KMW						
ANTENNA SIZE (H x W x D)	24X11.8X6						
ANTENNA WEIGHT	15.4						
AZIMUTH	30						
MAGNETIC DECLINATION							
RADIATION CENTER (feet)	103						
ANTENNA TIP HEIGHT	104						
MECHANICAL DOWNTILT	2						
FEEDER AMOUNT	2						
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)							
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)							
Antenna RET Motor (QTY/MODEL)							
SURGE ARRESTOR (QTY/MODEL)	4	Andrew APTDC-BDFDM-DBW Broadband					
DIPLEXER (QTY/MODEL)	2	TRIASX TBC0020F1V24-Triplexers					
DUPLEXER (QTY/MODEL)							
Antenna RET CONTROL UNIT (QTY/MODEL)							
DC BLOCK (QTY/MODEL)							
TMA/LNA (QTY/MODEL)							
CURRENT INJECTORS FOR TMA (QTY/MODEL)							
PDU FOR TMA (QTY/MODEL)							
FILTER (QTY/MODEL)							
SQUID (QTY/MODEL)							
FIBER TRUNK (QTY/MODEL)							
DC TRUNK (QTY/MODEL)							
RRH - 700 band (QTY/MODEL)	1	RRUS-11					
RRH - 850 band (QTY/MODEL)							
RRH - 1900 band (QTY/MODEL)	1	RRUS-12					
RRH - AWS band (QTY/MODEL)							
RRH - WCS band (QTY/MODEL)							
Additional RRH #1 - any band (QTY/MODEL)							
Additional RRH #2 - any band (QTY/MODEL)							
Additional Component 1 (QTY/MODEL)							
Additional Component 2 (QTY/MODEL)							
Additional Component 3 (QTY/MODEL)							
Local Market Note 1							
Local Market Note 2							
Local Market Note 3							

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 1		46002.A.850.3G.1	CTV50131	CTV50131		UMTS 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	30	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		1	
	PORT 2		46002.A.850.3G.2	CTV4013A	CTV4013A		UMTS 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	30	0	Bottom	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		1	
	PORT 3		46002.A.1900.3G.1	CTU50137	CTU50137		UMTS 1900	FX-X-CD-65-12-65-14-00T-ST_1930MHz_00DT	13.5	30	0	None	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC	NO		615		2	
	PORT 4		46002.A.1900.4G.111	CTL05013_9A_1	CTL05013_9A_1		LTE 1900	FX-X-CD-65-12-65-14-00T-ST_1930MHz_00DT	13.5	30	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		2	

	PORT 5		46002.A.700.4G.1	CTL05013_7A_1	CTL05013_7A_1		LTE 700	FX-X-CD-65-12-65-14-00T-ST_725MHz_00DT	12.69	30	0	Bottom	Andrew 1-5/8	175		0		NO		827		1	
	PORT 6		46002.A.850.25G.1	321G50131	321G50131		GSM 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	30	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		140		1	

Section 15B - CURRENT SECTOR/CELL INFORMATION - SECTOR B

ANTENNA COMMON FIELDS	ANTENNA POSITION 1	ANTENNA POSITION 2	ANTENNA POSITION 3	ANTENNA POSITION 4	ANTENNA POSITION 5	ANTENNA POSITION 6	ANTENNA POSITION 7
ANTENNA MAKE - MODEL	FX-X-CD-65-12-65-14-00T-ST						
ANTENNA VENDOR	KMW						
ANTENNA SIZE (H x W x D)	24X11.8X6						
ANTENNA WEIGHT	15.4						
AZIMUTH	150						
MAGNETIC DECLINATION							
RADIATION CENTER (feet)	103						
ANTENNA TIP HEIGHT	104						
MECHANICAL DOWNTILT	0						
FEEDER AMOUNT	2						
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)							
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)							
Antenna RET Motor (QTY/MODEL)							
SURGE ARRESTOR (QTY/MODEL)	4	Andrew APTDC-BDFDM-DBW Broadband					
DIPLEXER (QTY/MODEL)	2	TRIASX TBC0020F1V24-Triplexers					
DUPLEXER (QTY/MODEL)							
Antenna RET CONTROL UNIT (QTY/MODEL)							
DC BLOCK (QTY/MODEL)							
TMA/LNA (QTY/MODEL)							
CURRENT INJECTORS FOR TMA (QTY/MODEL)							
PDU FOR TMAS (QTY/MODEL)							
FILTER (QTY/MODEL)							
SQUID (QTY/MODEL)							
FIBER TRUNK (QTY/MODEL)							
DC TRUNK (QTY/MODEL)							
RRH - 700 band (QTY/MODEL)	1	RRUS-11					
RRH - 850 band (QTY/MODEL)							
RRH - 1900 band (QTY/MODEL)	1	RRUS-12					
RRH - AWS band (QTY/MODEL)							
RRH - WCS band (QTY/MODEL)							
Additional RRH #1 - any band (QTY/MODEL)							
Additional RRH #2 - any band (QTY/MODEL)							
Additional Component 1 (QTY/MODEL)							
Additional Component 2 (QTY/MODEL)							
Additional Component 3 (QTY/MODEL)							
Local Market Note 1							
Local Market Note 2							
Local Market Note 3							

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 1		46002.B.850.3G.1	CTV50132	CTV50132		UMTS 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	150	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		9	
	PORT 2		46002.B.850.3G.2	CTV4013B	CTV4013B		UMTS 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	150	0	Bottom	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		9	
	PORT 3		46002.B.1900.3G.1	CTU50138	CTU50138		UMTS 1900	FX-X-CD-65-12-65-14-00T-ST_1930MHz_00DT	13.5	150	0	None	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC	NO		615		10	
	PORT 4		46002.B.1900.4G.111	CTL05013_9B_1	CTL05013_9B_1		LTE 1900	FX-X-CD-65-12-65-14-00T-ST_1930MHz_00DT	13.5	150	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		10	

	PORT 5		46002.B.700.4G.1	CTL05013_7B_1	CTL05013_7B_1		LTE 700	FX-X-CD-65-12-65-14-00T-ST_725MHz_00DT	12.69	150	0	Bottom	Andrew 1-5/8	175		0		NO		827		9	
	PORT 6		46002.B.850.25G.1	321G50132	321G50132		GSM 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	150	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		140		9	



Section 15C - CURRENT SECTOR/CELL INFORMATION - SECTOR C

ANTENNA COMMON FIELDS	ANTENNA POSITION 1	ANTENNA POSITION 2	ANTENNA POSITION 3	ANTENNA POSITION 4	ANTENNA POSITION 5	ANTENNA POSITION 6	ANTENNA POSITION 7
ANTENNA MAKE - MODEL	FX-X-CD-65-12-65-14-00T-ST						
ANTENNA VENDOR	KMW						
ANTENNA SIZE (H x W x D)	24X11.8X6						
ANTENNA WEIGHT	15.4						
AZIMUTH	270						
MAGNETIC DECLINATION							
RADIATION CENTER (feet)	103						
ANTENNA TIP HEIGHT	104						
MECHANICAL DOWNTILT	0						
FEEDER AMOUNT	2						
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)							
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)							
Antenna RET Motor (QTY/MODEL)							
SURGE ARRESTOR (QTY/MODEL)	4	Andrew APTDC-BDFDM-DBW Broadband					
DIPLEXER (QTY/MODEL)	2	TRIASX TBC0020F1V24-Triplexers					
DUPLEXER (QTY/MODEL)							
Antenna RET CONTROL UNIT (QTY/MODEL)							
DC BLOCK (QTY/MODEL)							
TMA/LNA (QTY/MODEL)							
CURRENT INJECTORS FOR TMA (QTY/MODEL)							
PDU FOR TMAS (QTY/MODEL)							
FILTER (QTY/MODEL)							
SQUID (QTY/MODEL)							
FIBER TRUNK (QTY/MODEL)							
DC TRUNK (QTY/MODEL)							
RRH - 700 band (QTY/MODEL)	1	RRUS-11					
RRH - 850 band (QTY/MODEL)							
RRH - 1900 band (QTY/MODEL)	1	RRUS-12					
RRH - AWS band (QTY/MODEL)							
RRH - WCS band (QTY/MODEL)							
Additional RRH #1 - any band (QTY/MODEL)							
Additional RRH #2 - any band (QTY/MODEL)							
Additional Component 1 (QTY/MODEL)							
Additional Component 2 (QTY/MODEL)							
Additional Component 3 (QTY/MODEL)							
Local Market Note 1							
Local Market Note 2							
Local Market Note 3							

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 1		46002.C.850.3G.1	CTV50133	CTV50133		UMTS 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	270	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		17	
	PORT 2		46002.C.850.3G.2	CTV4013C	CTV4013C		UMTS 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	270	0	Bottom	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		17	
	PORT 3		46002.C.1900.3G.1	CTU50139	CTU50139		UMTS 1900	FX-X-CD-65-12-65-14-00T-ST_1930MHz_00DT	13.5	270	0	None	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC	NO		615		18	
	PORT 4		46002.C.1900.4G.111	CTL05013_9C_1	CTL05013_9C_1		LTE 1900	FX-X-CD-65-12-65-14-00T-ST_1930MHz_00DT	13.5	270	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		18	

	PORT 5		46002.C.700.4G.1	CTL05013_7C_1	CTL05013_7C_1		LTE 700	FX-X-CD-65-12-65-14-00T-ST_725MHz_00DT	12.69	270	0	Bottom	Andrew 1-5/8	175		0		NO		827		17	
	PORT 6		46002.C.850.25G.1	321G50133	321G50133		GSM 850	FX-X-CD-65-12-65-14-00T-ST_850MHz_00DT	12.39	270	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		140		17	

Section 16A - NEW/PROPOSED SECTOR/CELL INFORMATION - SECTOR A (OR OMNI)

ANTENNA COMMON FIELDS	ANTENNA POSITION 1	ANTENNA POSITION 2	ANTENNA POSITION 3	ANTENNA POSITION 4	ANTENNA POSITION 5	ANTENNA POSITION 6	ANTENNA POSITION 7
Existing Antenna?							
ANTENNA MAKE - MODEL	HPA-65F-BUU-H2-K						
ANTENNA VENDOR	CCI						
ANTENNA SIZE (H x W x D)	21.4X14.4X7.3						
ANTENNA WEIGHT	13.8						
AZIMUTH	30						
MAGNETIC DECLINATION							
RADIATION CENTER (feet)	103						
ANTENNA TIP HEIGHT	104						
MECHANICAL DOWNTILT							
FEEDER AMOUNT	2						
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)							
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)							
Antenna RET Motor (QTY/MODEL)							
SURGE ARRESTOR (QTY/MODEL)	2	Andrew APTDC-BDFDM-DBW Broadband					
DIPLEXER (QTY/MODEL)	4	CCI Pentaplexer 5PX-0726-O					
DUPLEXER (QTY/MODEL)							
Antenna RET CONTROL UNIT (QTY/MODEL)							
DC BLOCK (QTY/MODEL)							
TMA/LNA (QTY/MODEL)							
CURRENT INJECTORS FOR TMA (QTY/MODEL)	1	K SBT 782-10253					
PDU FOR TMA (QTY/MODEL)	1	KATHREIN 860-10006					
FILTER (QTY/MODEL)							
SQUID (QTY/MODEL)							
FIBER TRUNK (QTY/MODEL)							
DC TRUNK (QTY/MODEL)							
RRH - 700 band (QTY/MODEL)							
RRH - 850 band (QTY/MODEL)							
RRH - 1900 band (QTY/MODEL)	1	RRUS-32 B2					
RRH - AWS band (QTY/MODEL)							
RRH - WCS band (QTY/MODEL)							
Additional RRH #1 - any band (QTY/MODEL)							
Additional RRH #2 - any band (QTY/MODEL)							
Additional Component 1 (QTY/MODEL)							
Additional Component 2 (QTY/MODEL)							
Additional Component 3 (QTY/MODEL)							
Local Market Note 1	Swap existing antenna to Hex//Add 2 new Coax per sector//Add 4 pentaplexer per sector//Add 2 Twin-TMA at top per sector// Replace RRUS-12 to RRUS32 B2// Add XMU to existing DUS41 for BWE on LTE 2C 1900//Proposed UMTS1900 decom						
Local Market Note 2							
Local Market Note 3							

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 4		46002.A.1900.4G.111	CTL05013_9A_1	CTL05013_9A_1		LTE 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	30	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		2	

Section 16B - NEW/PROPOSED SECTOR/CELL INFORMATION - SECTOR B

ANTENNA COMMON FIELDS	ANTENNA POSITION 1	ANTENNA POSITION 2	ANTENNA POSITION 3	ANTENNA POSITION 4	ANTENNA POSITION 5	ANTENNA POSITION 6	ANTENNA POSITION 7
Existing Antenna?							
ANTENNA MAKE - MODEL	HPA-65F-BUU-H2-K						
ANTENNA VENDOR	CCI						
ANTENNA SIZE (H x W x D)	21.4X14.4X7.3						
ANTENNA WEIGHT	13.8						
AZIMUTH	150						
MAGNETIC DECLINATION							
RADIATION CENTER (feet)	103						
ANTENNA TIP HEIGHT	104						
MECHANICAL DOWNTILT							
FEEDER AMOUNT	2						
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)							
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)							
Antenna RET Motor (QTY/MODEL)							
SURGE ARRESTOR (QTY/MODEL)	2	Andrew APTDC-BDFDM-DBW Broadband					
DIPLEXER (QTY/MODEL)	4	CCI Pentaplexer 5PX-0726-O					
DUPLEXER (QTY/MODEL)							
Antenna RET CONTROL UNIT (QTY/MODEL)							
DC BLOCK (QTY/MODEL)							
TMA/LNA (QTY/MODEL)							
CURRENT INJECTORS FOR TMA (QTY/MODEL)	1	K SBT 782-10253					
PDU FOR TMA (QTY/MODEL)							
FILTER (QTY/MODEL)							
SQUID (QTY/MODEL)							
FIBER TRUNK (QTY/MODEL)							
DC TRUNK (QTY/MODEL)							
RRH - 700 band (QTY/MODEL)							
RRH - 850 band (QTY/MODEL)							
RRH - 1900 band (QTY/MODEL)	1	RRUS-32 B2					
RRH - AWS band (QTY/MODEL)							
RRH - WCS band (QTY/MODEL)							
Additional RRH #1 - any band (QTY/MODEL)							
Additional RRH #2 - any band (QTY/MODEL)							
Additional Component 1 (QTY/MODEL)							
Additional Component 2 (QTY/MODEL)							
Additional Component 3 (QTY/MODEL)							
Local Market Note 1	Swap existing antenna to Hex//Add 2 new Coax per sector//Add 4 pentaplexer per sector//Add 2 Twin-TMA at top per sector// Replace RRUS-12 to RRUS32 B2// Add XMU to existing DUS41 for BWE on LTE 2C 1900//Proposed UMTS1900 decom						
Local Market Note 2							
Local Market Note 3							

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 4		46002.B.1900.4G.111	CTL05013_9B_1	CTL05013_9B_1		LTE 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	150	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		10	

Section 16C - NEW/PROPOSED SECTOR/CELL INFORMATION - SECTOR C

ANTENNA COMMON FIELDS	ANTENNA POSITION 1	ANTENNA POSITION 2	ANTENNA POSITION 3	ANTENNA POSITION 4	ANTENNA POSITION 5	ANTENNA POSITION 6	ANTENNA POSITION 7
Existing Antenna?							
ANTENNA MAKE - MODEL	HPA-65F-BUU-H2-K						
ANTENNA VENDOR	CCI						
ANTENNA SIZE (H x W x D)	21.4X14.4X7.3						
ANTENNA WEIGHT	13.8						
AZIMUTH	270						
MAGNETIC DECLINATION							
RADIATION CENTER (feet)	103						
ANTENNA TIP HEIGHT	104						
MECHANICAL DOWNTILT							
FEEDER AMOUNT	2						
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)							
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)							
Antenna RET Motor (QTY/MODEL)							
SURGE ARRESTOR (QTY/MODEL)	2	Andrew APTDC-BDFDM-DBW Broadband					
DIPLEXER (QTY/MODEL)	4	CCI Pentaplexer 5PX-0726-O					
DUPLEXER (QTY/MODEL)							
Antenna RET CONTROL UNIT (QTY/MODEL)							
DC BLOCK (QTY/MODEL)							
TMA/LNA (QTY/MODEL)							
CURRENT INJECTORS FOR TMA (QTY/MODEL)	1	K SBT 782-10253					
PDU FOR TMA (QTY/MODEL)							
FILTER (QTY/MODEL)							
SQUID (QTY/MODEL)							
FIBER TRUNK (QTY/MODEL)							
DC TRUNK (QTY/MODEL)							
RRH - 700 band (QTY/MODEL)							
RRH - 850 band (QTY/MODEL)							
RRH - 1900 band (QTY/MODEL)	1	RRUS-32 B2					
RRH - AWS band (QTY/MODEL)							
RRH - WCS band (QTY/MODEL)							
Additional RRH #1 - any band (QTY/MODEL)							
Additional RRH #2 - any band (QTY/MODEL)							
Additional Component 1 (QTY/MODEL)							
Additional Component 2 (QTY/MODEL)							
Additional Component 3 (QTY/MODEL)							
Local Market Note 1	Swap existing antenna to Hex//Add 2 new Coax per sector//Add 4 pentaplexer per sector//Add 2 Twin-TMA at top per sector// Replace RRUS-12 to RRUS32 B2// Add XMU to existing DUS41 for BWE on LTE 2C 1900//Proposed UMTS1900 decom						
Local Market Note 2							
Local Market Note 3							

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 4		46002.C.1900.4G.111	CTL05013_9C_1	CTL05013_9C_1		LTE 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	270	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		18	

Section 17A - FINAL SECTOR/CELL INFORMATION - SECTOR A (OR OMNI)

ANTENNA COMMON FIELDS	ANTENNA POSITION 1		ANTENNA POSITION 2		ANTENNA POSITION 3		ANTENNA POSITION 4		ANTENNA POSITION 5		ANTENNA POSITION 6		ANTENNA POSITION 7	
ANTENNA MAKE - MODEL	HPA-65F-BUU-H2-K													
ANTENNA VENDOR	CCI													
ANTENNA SIZE (H x W x D)	21.4X14.4X7.3													
ANTENNA WEIGHT	13.8													
AZIMUTH	30													
MAGNETIC DECLINATION														
RADIATION CENTER (feet)	103													
ANTENNA TIP HEIGHT	104													
MECHANICAL DOWNTILT	2													
FEEDER AMOUNT	4													
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)														
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)														
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)														
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)														
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)														
Antenna RET Motor (QTY/MODEL)														
SURGE ARRESTOR (QTY/MODEL)	6		Andrew APTDC-BDFDM-DBW Broadband											
DIPLEXER (QTY/MODEL)	4		CCI Pentaplexer 5PX-0726-O											
DUPLEXER (QTY/MODEL)														
Antenna RET CONTROL UNIT (QTY/MODEL)														
DC BLOCK (QTY/MODEL)														
TMA/LNA (QTY/MODEL)														
CURRENT INJECTORS FOR TMA (QTY/MODEL)	2		K SBT 782-10253											
PDU FOR TMAS (QTY/MODEL)	1		KATHREIN 860-10006											
FILTER (QTY/MODEL)														
SQUID (QTY/MODEL)														
FIBER TRUNK (QTY/MODEL)														
DC TRUNK (QTY/MODEL)														
RRH - 700 band (QTY/MODEL)	1		RRUS-11											
RRH - 850 band (QTY/MODEL)														
RRH - 1900 band (QTY/MODEL)	1		RRUS-32 B2											
RRH - AWS band (QTY/MODEL)														
RRH - WCS band (QTY/MODEL)														
Additional RRH #1 - any band (QTY/MODEL)														
Additional RRH #2 - any band (QTY/MODEL)														
Additional Component 1 (QTY/MODEL)														
Additional Component 2 (QTY/MODEL)														
Additional Component 3 (QTY/MODEL)														
Local Market Note 1	Swap existing antenna to Hex//Add 2 new Coax per sector//Add 4 pentaplexer per sector//Add 2 Twin-TMA at top per sector// Replace RRUS-12 to RRUS32 B2// Add XMU to existing DUS41 for BWE on LTE 2C 1900.													
Local Market Note 2	PROPOSED UMTS1900 Decom													
Local Market Note 3	Baseband Config- 1 DUS + XMU DUS-1- 7A:7B:7C:X1P1:X1P2_ XMU-1- PA:PA2A: : :PB:PA2B:PC:PA2C: : : :D1E:D1D													

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 1	46002.A.850.3G.1	46002.A.850.3G.1	CTV50131	CTV50131		UMTS 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	30	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		1	
	PORT 2	46002.A.850.3G.2	46002.A.850.3G.2	CTV4013A	CTV4013A		UMTS 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	30	0	Bottom	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		1	
	PORT 3	46002.A.1900.3G.1	46002.A.1900.3G.1	CTU50137	CTU50137		UMTS 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	30	0	None	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC	NO		615		2	
	PORT 4	46002.A.1900.4G.1mp1	46002.A.1900.4G.111	CTL05013_9A_1	CTL05013_9A_1		LTE 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	30	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		2	
	PORT 5	46002.A.700.4G.1	46002.A.700.4G.1	CTL05013_7A_1	CTL05013_7A_1		LTE 700	HPA-65F-BUU-H2-K_725MHz_00DT	7.9	30	0	Bottom	Andrew 1-5/8	175				NO		827		1	

	PORT 6	46002.A.850.25G.2	46002.A.850.25G.1	321G50131	321G50131		GSM 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	30	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		140			1	
--	--------	-------------------	-------------------	-----------	-----------	--	---------	------------------------------	-----	----	---	------	--------------	-----	-----------	---	---------	----	--	-----	--	--	---	--

Section 17B - FINAL SECTOR/CELL INFORMATION - SECTOR B

ANTENNA COMMON FIELDS	ANTENNA POSITION 1		ANTENNA POSITION 2		ANTENNA POSITION 3		ANTENNA POSITION 4		ANTENNA POSITION 5		ANTENNA POSITION 6		ANTENNA POSITION 7	
ANTENNA MAKE - MODEL	HPA-65F-BUU-H2-K													
ANTENNA VENDOR	CCI													
ANTENNA SIZE (H x W x D)	21.4X14.4X7.3													
ANTENNA WEIGHT	13.8													
AZIMUTH	150													
MAGNETIC DECLINATION														
RADIATION CENTER (feet)	103													
ANTENNA TIP HEIGHT	104													
MECHANICAL DOWNTILT	0													
FEEDER AMOUNT	4													
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)														
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)														
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)														
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)														
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)														
Antenna RET Motor (QTY/MODEL)														
SURGE ARRESTOR (QTY/MODEL)	6		Andrew APTDC-BDFDM-DBW Broadband											
DIPLEXER (QTY/MODEL)	4		CCI Pentaplexer 5PX-0726-O											
DUPLEXER (QTY/MODEL)														
Antenna RET CONTROL UNIT (QTY/MODEL)														
DC BLOCK (QTY/MODEL)														
TMA/LNA (QTY/MODEL)														
CURRENT INJECTORS FOR TMA (QTY/MODEL)														
PDU FOR TMAS (QTY/MODEL)														
FILTER (QTY/MODEL)														
SQUID (QTY/MODEL)														
FIBER TRUNK (QTY/MODEL)														
DC TRUNK (QTY/MODEL)														
RRH - 700 band (QTY/MODEL)	1		RRUS-11											
RRH - 850 band (QTY/MODEL)														
RRH - 1900 band (QTY/MODEL)	1		RRUS-32 B2											
RRH - AWS band (QTY/MODEL)														
RRH - WCS band (QTY/MODEL)														
Additional RRH #1 - any band (QTY/MODEL)														
Additional RRH #2 - any band (QTY/MODEL)														
Additional Component 1 (QTY/MODEL)														
Additional Component 2 (QTY/MODEL)														
Additional Component 3 (QTY/MODEL)														
Local Market Note 1	Swap existing antenna to Hex//Add 2 new Coax per sector//Add 4 pentaplexer per sector//Add 2 Twin-TMA at top per sector// Replace RRUS-12 to RRUS32 B2// Add XMU to existing DUS41 for BWE on LTE 2C 1900.													
Local Market Note 2	PROPOSED UMTS1900 Decom													
Local Market Note 3	Baseband Config- 1 DUS + XMU DUS-1- 7A:7B:7C:X1P1:X1P2_ XMU-1- PA:PA2A: : :PB:PA2B:PC:PA2C: : : :D1E:D1D													

PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 1	46002.B.850.3G.1	46002.B.850.3G.1	CTV50132	CTV50132		UMTS 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	150	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		9	
	PORT 2	46002.B.850.3G.2	46002.B.850.3G.2	CTV4013B	CTV4013B		UMTS 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	150	0	Bottom	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		9	
	PORT 3	46002.B.1900.3G.1	46002.B.1900.3G.1	CTU50138	CTU50138		UMTS 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	150	0	None	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC	NO		615		10	
	PORT 4	46002.B.1900.4G.1mp1	46002.B.1900.4G.111	CTL05013_9B_1	CTL05013_9B_1		LTE 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	150	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		10	
	PORT 5	46002.B.700.4G.1	46002.B.700.4G.1	CTL05013_7B_1	CTL05013_7B_1		LTE 700	HPA-65F-BUU-H2-K_725MHz_00DT	7.9	150	0	Bottom	Andrew 1-5/8	175				NO		827		9	



	PORT 6	46002.B.850.25G.2	46002.B.850.25G.1	321G50132	321G50132		GSM 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	150	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		140			9	
--	--------	-------------------	-------------------	-----------	-----------	--	---------	------------------------------	-----	-----	---	------	--------------	-----	-----------	---	---------	----	--	-----	--	--	---	--


Section 17C - FINAL SECTOR/CELL INFORMATION - SECTOR C

ANTENNA COMMON FIELDS	ANTENNA POSITION 1	ANTENNA POSITION 2	ANTENNA POSITION 3	ANTENNA POSITION 4	ANTENNA POSITION 5	ANTENNA POSITION 6	ANTENNA POSITION 7
ANTENNA MAKE - MODEL	HPA-65F-BUU-H2-K						
ANTENNA VENDOR	CCI						
ANTENNA SIZE (H x W x D)	21.4X14.4X7.3						
ANTENNA WEIGHT	13.8						
AZIMUTH	270						
MAGNETIC DECLINATION							
RADIATION CENTER (feet)	103						
ANTENNA TIP HEIGHT	104						
MECHANICAL DOWNTILT	0						
FEEDER AMOUNT	4						
VERTICAL SEPARATION from ANTENNA ABOVE (TIP to TIP)							
VERTICAL SEPARATION from ANTENNA BELOW (TIP to TIP)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to LEFT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from CLOSEST ANTENNA to RIGHT (CENTERLINE to CENTERLINE)							
HORIZONTAL SEPARATION from ANOTHER ANTENNA (which antenna # / # of inches)							
Antenna RET Motor (QTY/MODEL)							
SURGE ARRESTOR (QTY/MODEL)	6	Andrew APTDC-BDFDM-DBW Broadband					
DIPLEXER (QTY/MODEL)	4	CCI Pentaplexer 5PX-0726-O					
DUPLEXER (QTY/MODEL)							
Antenna RET CONTROL UNIT (QTY/MODEL)							
DC BLOCK (QTY/MODEL)							
TMA/LNA (QTY/MODEL)							
CURRENT INJECTORS FOR TMA (QTY/MODEL)							
PDU FOR TMAS (QTY/MODEL)							
FILTER (QTY/MODEL)							
SQUID (QTY/MODEL)							
FIBER TRUNK (QTY/MODEL)							
DC TRUNK (QTY/MODEL)							
RRH - 700 band (QTY/MODEL)	1	RRUS-11					
RRH - 850 band (QTY/MODEL)							
RRH - 1900 band (QTY/MODEL)	1	RRUS-32 B2					
RRH - AWS band (QTY/MODEL)							
RRH - WCS band (QTY/MODEL)							
Additional RRH #1 - any band (QTY/MODEL)							
Additional RRH #2 - any band (QTY/MODEL)							
Additional Component 1 (QTY/MODEL)							
Additional Component 2 (QTY/MODEL)							
Additional Component 3 (QTY/MODEL)							
Local Market Note 1	Swap existing antenna to Hex//Add 2 new Coax per sector//Add 4 pentaplexer per sector//Add 2 Twin-TMA at top per sector// Replace RRUS-12 to RRUS32 B2// Add XMU to existing DUS41 for BWE on LTE 2C 1900.						
Local Market Note 2	PROPOSED UMTS1900 DECOM						
Local Market Note 3	Baseband Config- 1 DUS + XMU DUS-1- 7A:7B:7C:X1P1:X1P2_ XMU-1- PA:PA2A: : :PB:PA2B:PC:PA2C: : : :D1E:D1D						


PORT SPECIFIC FIELDS	PORT NUMBER	USEID (CSSng)	USEID (Atoll)	ATOLL TXID	ATOLL CELL ID	TX/RX ?	TECHNOLOGY/FREQUENCY	ANTENNA ATOLL	ANTENNA GAIN	ELECTRICAL AZIMUTH	ELECTRICAL TILT	RRH LOCATION (Top/Bottom/Integrated/None)	FEEDERS TYPE	FEEDER LENGTH (feet)	RXAIT KIT MODULE?	TRIPLEXER or LLC (QTY)	TRIPLEXER or LLC (MODEL)	SCPA/MCPA MODULE?	HATCHPLATE POWER (Watts)	ERP (Watts)	Antenna RET Name	CABLE NUMBER	CABLE ID (CSSNG)
ANTENNA POSITION 1	PORT 1	46002.C.850.3G.1	46002.C.850.3G.1	CTV50133	CTV50133		UMTS 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	270	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		17	
	PORT 2	46002.C.850.3G.2	46002.C.850.3G.2	CTV4013C	CTV4013C		UMTS 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	270	0	Bottom	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		309		17	
	PORT 3	46002.C.1900.3G.1	46002.C.1900.3G.1	CTU50139	CTU50139		UMTS 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	270	0	None	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC	NO		615		18	
	PORT 4	46002.C.1900.4G.1mp1	46002.C.1900.4G.111	CTL05013_9C_1	CTL05013_9C_1		LTE 1900	HPA-65F-BUU-H2-K_1930MHz_00DT	12.8	270	0	BOTTOM	Andrew 1-5/8	175	RXAIT 1900	1	1900 LLC			3200		18	
	PORT 5	46002.C.700.4G.1	46002.C.700.4G.1	CTL05013_7C_1	CTL05013_7C_1		LTE 700	HPA-65F-BUU-H2-K_725MHz_00DT	7.9	270	0	Bottom	Andrew 1-5/8	175				NO		827		17	

	PORT 6	46002.C.850.25G.2	46002.C.850.25G.1	321G50133	321G50133		GSM 850	HPA-65F-BUU-H2-K_850MHz_00DT	8.4	270	0	None	Andrew 1-5/8	175	RXAIT 850	1	850 LLC	NO		140			17	
--	--------	-------------------	-------------------	-----------	-----------	--	---------	------------------------------	-----	-----	---	------	--------------	-----	-----------	---	---------	----	--	-----	--	--	----	--


Comments:



Comments:



Comments:




## NOTES

Date Time (Central)	Version	ATTUID	Note
2/25/2016 3:26:14 PM	1.00	om636a	Added XMU to existing DUS, RRUS12 swapped to RRUS32, CPRI for RRUS added, Pentaplexer/TMA and Coax added, UMTS1900 decom proposed,DUS port assignments in section-17 local market note-3

WORKFLOW SUMMARY

Date	FROM State / Status	FROM ATTUI D	TO State / Status	TO ATTUI D	Operatio n	Comments
02/25/2016	Preliminary / In Progress	om636 a	Preliminary / Submitted for Approval	AB014 M	Promote	LTE 2C BWE, XMU added, Dus port assignment, RRUS swap from RRUs-12 to RRUS32, Antenna swap to hex
06/06/2016	Preliminary / Submitted for Approval	AB014 M	Preliminary / Approved	BG144 B	Promote	
10/13/2016	Preliminary / Approved	BG144 B	Final / RF Approval	OM636 A	Promote	Needs final





- High Band Ports include WCS Band
- Four High Band ports with two Low Band ports in one antenna
- Sharp elevation beam
- Excellent elevation side-lobe performance
- Excellent MIMO performance due to array spacing
- Excellent PIM Performance
- A multi-network solution in one radome
- Reduces tower loading
- Frees up space for tower mounted E-nodes
- Single radome with six ports

### Overview

The CCI Hexport Multi-Band Antenna Array has four high band ports and two low band ports, our hexport antenna is ready for 4X4 high band MIMO. Modern networks demand high performance, consequently CCI has incorporated several new and innovative design techniques to provide an antenna with excellent side-lobe performance, sharp elevation beams, and high front to back ratio.

Multiple networks can now be connected to a single antenna, reducing tower loading and leasing expense, while decreasing deployment time and installation cost.

Full band capability for SMR800 and PCS 1900 MHz coverage in a single enclosure.

CCI antennas are designed and produced to ISO 9001 standards for reliability and quality in our state-of-the-art manufacturing facilities.

### Applications

- 4x4 MIMO for the high band and 2x2 MIMO for the low band
- Adding additional capacity without adding additional antennas
- Adding WCS Band without increasing antenna count



SPECIFICATIONS

HexPort Dual-Band Antenna

HPA-65F-BUU-H2

Electrical

Ports	2 x Low Band Ports which cover the full range from 698-894 MHz		4 x High Band Ports which cover the full range from 1710-2360 MHz			
Frequency Range	698-806 MHz	824-894 MHz	1850-1990 MHz	1710-1755/2110-2170 MHz	2305-2360 MHz	
Gain	10.0 dBi	10.5 dBi	12.8 dBi	12.6 dBi	13.6 dBi	14.0 dBi
Azimuth Beamwidth (-3dB)	65°	62°	64°	66°	60°	59°
Elevation Beamwidth (-3dB)	40.0°	35.8°	17.5°	17.8°	15.8°	14.3°
Electrical Downtilt	4°	4°	3°	3°	3°	3°
Elevation Sidelobes (1st Upper)	< -15 dB	< -13 dB	< -13 dB	< -17 dB	< -13 dB	< -17 dB
Front-to-Back Ratio @180°	> 28 dB	> 28 dB	> 30 dB	> 30 dB	> 30 dB	> 30 dB
Cross-Polar Port-to-Port Isolation	> 20 dB	> 20 dB	> 23 dB	> 23 dB	> 23 dB	> 23 dB
Voltage Standing Wave Ratio (VSWR)	< 1.5:1	< 1.5:1	< 1.5:1	< 1.5:1	< 1.5:1	< 1.5:1
Passive Intermodulation (2x20W)	≤ -150 dBc	≤ -150 dBc	≤ -150 dBc	≤ -150 dBc	≤ -150 dBc	≤ -150 dBc
Input Power Continuous Wave (CW)	500 watts	500 watts	300 watts	300 watts	300 watts	300 watts
Polarization	Dual Pol 45°	Dual Pol 45°	Dual Pol 45°	Dual Pol 45°	Dual Pol 45°	Dual Pol 45°
Input Impedance	50 ohms	50 ohms	50 ohms	50 ohms	50 ohms	50 ohms
Lightning Protection	DC Ground	DC Ground	DC Ground	DC Ground	DC Ground	DC Ground

Mechanical

Dimensions (LxWxD)	21.4x14.4x7.3 in (544x366x185 mm)
Survival Wind Speed	> 150 mph (> 241 kph)
Front Wind Load	66 lbs (293 N) @ 100 mph (161 kph)
Side Wind Load	34 lbs (150 N) @ 100 mph (161 kph)
Equivalent Flat Plate Area	2.6 ft <sup>2</sup> (0.2 m <sup>2</sup> )
Weight *	15.2 lbs (6.9 kg)
Connector	6 x 7-16 DIN female long neck
Mounting Pole	2 to 5 in (5 to 12 cm)

\* Weight excludes mounting

# TMA2117F00V1-1

PCS / WCS Dual Band Twin TMA, with 700/850 bypass, AISG2.0

Designed to be deployed in co-located PCS & WCS systems with wideband antennas, the Kaelus TMA provides internal diplexing and gain in both bands while allowing 700/850 services to pass through to a separate antenna, thereby saving hardware costs.

## PRODUCT FEATURES

- Improved base station sensitivity through gain in PCS and WCS bands
- Hardware and software configuration using AISG “Personality” upload
- High Linearity and low noise performance; Bypass provided for 700/850MHz services
- Fail safe bypass mode with lightning protection

## TECHNICAL SPECIFICATIONS

Downlink Path, Band 1	PCS
Passband	1930 - 1990
Insertion Loss	0.5dB typ
Return Loss	18dB min
Max Average input power (W)	160
Max PEP Input Power (W)	2000
Intermodulation, 2 x 43dBm TX carriers (dBc)	-153dBc max
Uplink Path, Band 1	
Passband	1850 - 1910
Gain (dB)	3dB to 13dB in 1dB steps
Gain window	+/- 1dB max
Return Loss (Operating)	18dB min
Return Loss (Bypass)	12dB min
Noise Figure	1.4dB typ
Bypass Loss	2.5dB typ

## AISG MODE OF OPERATION (AUTO SELECTED ON VALID AISG 2.0 FRAMES)

AISG Version	2
AISG Supply Current	400mA @ 8.5V, 120mA @ 30V typical
AISG Connector	IEC60130-9, 8-pin female
AISG Connector Current rating	< 4A peak, 2A continuous, pin 6
Field firmware upgradable	Yes

## ENVIRONMENTAL

Temperature range	-40°C to +65°C   -40° to +149°F
Environmental sealing	IP67
Lightning protection	RF port: +/- 5kA max (8/20us), AISG port: +/- 2kA max (8/20us) IEC61312-1
MTBF	>1,000,000 hours
Compliance	EMC:EN301 489, Ingress ETSI EN 300 019 class 4.1, RoHS

## MECHANICAL

Connectors	DIN 4.3-10 (F) x 8 long shank, AISG (F) x 1
Dimensions, H x D x W	216 x 300 x 107mm   8.46 x 11.81 x 4.21in
Finish	Powder coated, light grey (RAL7035)
Weight	8 kg   17.6lbs est
Mounting	Pole / wall bracket supplied with two metal clamps for 45-178 mm diameter poles

## ELECTRICAL BLOCK DIAGRAM



# Radio Frequency Emissions Analysis Report

AT&T Existing Facility

Site ID: CT5013

Norwalk CT  
310 Rowayton Avenue  
Norwalk, CT 6853

**February 16, 2017**

**Centerline Communications Project Number: 950006-034**

Site Compliance Summary	
Compliance Status:	<b>COMPLIANT</b>
Site total MPE% of FCC general population allowable limit:	<b>2.42 %</b>



February 16, 2017

AT&T Mobility – New England  
Attn: John Benedetto, RF Manager  
550 Cochituate Road  
Suite 550 – 13&14  
Framingham, MA 06040

### Emissions Analysis for Site: **CT5013 – Norwalk CT**

Centerline Communications, LLC (“Centerline”) was directed to analyze the proposed AT&T facility located at **310 Rowayton Avenue, Norwalk, CT**, for the purpose of determining whether the emissions from the Proposed AT&T Antenna Installation located on this property are within specified federal limits.

All information used in this report was analyzed as a percentage of current Maximum Permissible Exposure (% MPE) as listed in the FCC OET Bulletin 65 Edition 97-01 and ANSI/IEEE Std C95.1. The FCC regulates Maximum Permissible Exposure in units of microwatts per square centimeter ( $\mu\text{W}/\text{cm}^2$ ). The number of  $\mu\text{W}/\text{cm}^2$  calculated at each sample point is called the power density. The exposure limit for power density varies depending upon the frequencies being utilized. Wireless Carriers and Paging Services use different frequency bands each with different exposure limits, therefore it is necessary to report results and limits in terms of percent MPE rather than power density.

All results were compared to the FCC (Federal Communications Commission) radio frequency exposure rules, 47 CFR 1.1307(b)(1) – (b)(3), to determine compliance with the Maximum Permissible Exposure (MPE) limits for General Population/Uncontrolled environments as defined below.

General population/uncontrolled exposure limits apply to situations in which the general population may be exposed or in which persons who are exposed as a consequence of their employment may not be made fully aware of the potential for exposure or cannot exercise control over their exposure. Therefore, members of the general population would always be considered under this category when exposure is not employment related, for example, in the case of a telecommunications tower that exposes persons in a nearby residential area.

Population exposure to radio frequencies is regulated and enforced in units of microwatts per square centimeter ( $\mu\text{W}/\text{cm}^2$ ). The general population exposure limits for the 700 and 850 MHz Bands are approximately  $467 \mu\text{W}/\text{cm}^2$  and  $567 \mu\text{W}/\text{cm}^2$  respectively. The general population exposure limit for the 1900 MHz (PCS), 2100 MHz (AWS) and 2300 MHz (WCS) bands is  $1000 \mu\text{W}/\text{cm}^2$ . Because each carrier will be using different frequency bands, and each frequency band has different exposure limits, it is necessary to report percent of MPE rather than power density.



Occupational/controlled exposure limits apply to situations in which persons are exposed as a consequence of their employment and in which those persons who are exposed have been made fully aware of the potential for exposure and can exercise control over their exposure. Occupational/controlled exposure limits also apply where exposure is of a transient nature as a result of incidental passage through a location where exposure levels may be above general population/uncontrolled limits (see below), as long as the exposed person has been made fully aware of the potential for exposure and can exercise control over his or her exposure by leaving the area or by some other appropriate means.

Additional details can be found in FCC OET 65.



## CALCULATIONS

Calculations were performed for the proposed AT&T Wireless antenna facility located at **310 Rowayton Avenue, Norwalk, CT**, using the equipment information listed below. All calculations were performed per the specifications under FCC OET 65. Since AT&T is proposing highly focused directional panel antennas, which project most of the emitted energy out toward the horizon, all calculations were performed assuming a lobe representing the maximum gain of the antenna per the antenna manufactures supplied specifications, minus 10 dB, was focused at the base of the tower. For this report the sample point is the top of a 6-foot person standing at the base of the tower.

Per FCC OET Bulletin No. 65 - Edition 97-01 recommendations to achieve the maximum anticipated value at each sample point, all power levels emitting from the proposed antenna installation are increased by a factor of 2.56 to account for possible in-phase reflections from the surrounding environment. All power values expressed and analyzed are maximum power levels expected to be used on all radios.

All emissions values for additional carriers were taken from the Connecticut Siting Council (CSC) active MPE database. Values in this database are provided by the individual carriers themselves

For each sector the following channel counts, frequency bands and power levels were utilized as shown in *Table 1*:

Technology	Frequency Band	Channel Count	Transmit Power per Channel (W)
UMTS	850 MHz	2	30
UMTS	1900 MHz (PCS)	2	30
LTE	1900 MHz (PCS)	2	60
LTE	700 MHz	2	60
GSM	850 MHz	2	30

*Table 1: Channel Data Table*





The following antennas listed in *Table 2* were used in the modeling for transmission in the 700 MHz, 850 MHz and 1900 MHz (PCS) frequency bands. This is based on feedback from the carrier with regards to anticipated antenna selection. Maximum gain values for all antennas are listed in the Inventory and Power Data table below. The maximum gain of the antenna per the antenna manufactures supplied specifications, minus 10 dB, was used for all calculations. This value is a very conservative estimate as gain reductions for these particular antennas are typically much higher in this direction.

Sector	Antenna Number	Antenna Make / Model	Antenna Centerline (ft)
A	1	CCI HPA-65F-BUU-H2-K	103
B	1	CCI HPA-65F-BUU-H2-K	103
C	1	CCI HPA-65F-BUU-H2-K	103

*Table 2: Antenna Data*

All calculations were done with respect to uncontrolled / general population threshold limits.

## RESULTS

Per the calculations completed for the proposed AT&T configurations *Table 3* shows resulting emissions power levels and percentages of the FCC’s allowable general population limit.

Antenna ID	Antenna Make / Model	Frequency Bands	Antenna Gain (dBd)	Channel Count	Total TX Power (W)	ERP (W)	MPE %
Antenna A1	CCI HPA-65F-BUU-H2-K	850 MHz / 1900 MHz (PCS) / 700 MHz	8.35 / 10.65/ 7.85	10	420	4,336.86	2.42
Sector A Composite MPE%							<b>2.42</b>
Antenna B1	CCI HPA-65F-BUU-H2-K	850 MHz / 1900 MHz (PCS) / 700 MHz	8.35 / 10.65/ 7.85	10	420	4,336.86	2.42
Sector B Composite MPE%							<b>2.42</b>
Antenna C1	CCI HPA-65F-BUU-H2-K	850 MHz / 1900 MHz (PCS) / 700 MHz	8.35 / 10.65/ 7.85	10	420	4,336.86	2.42
Sector C Composite MPE%							<b>2.42</b>

*Table 3: AT&T Emissions Levels*



The Following table (*table 4*) shows all additional carriers on site and their MPE% as recorded in the CSC active MPE database for this facility along with the newly calculated maximum AT&T MPE contributions per this report. FCC OET 65 specifies that for carriers utilizing directional antennas that the highest recorded sector value be used for composite site MPE values due to their greatly reduced emissions contributions in the directions of the adjacent sectors. For this site, all three sectors have the same configuration yielding the same results on all three sectors. *Table 5* below shows a summary for each AT&T Sector as well as the composite MPE value for the site.

<b>Site Composite MPE%</b>	
<b>Carrier</b>	<b>MPE%</b>
AT&T – Max Sector Value	<b>2.42 %</b>
No Additional Carriers per CSC Active MPE Database	NA
<b>Site Total MPE %:</b>	<b>2.42 %</b>

*Table 4: All Carrier MPE Contributions*

AT&T Sector A Total:	2.42 %
AT&T Sector B Total:	2.42 %
AT&T Sector C Total:	2.42 %
<b>Site Total:</b>	<b>2.42 %</b>

*Table 5: Site MPE Summary*



FCC OET 65 specifies that for carriers utilizing directional antennas that the highest recorded sector value be used for composite site MPE values due to their greatly reduced emissions contributions in the directions of the adjacent sectors. *Table 6* below details a breakdown by frequency band and technology for the MPE power values for the maximum calculated AT&T sector(s). For this site, all three sectors have the same configuration yielding the same results on all three sectors.

AT&T _ Frequency Band / Technology (All Sectors)	# Channels	Watts ERP (Per Channel)	Height (feet)	Total Power Density ( $\mu\text{W}/\text{cm}^2$ )	Frequency (MHz)	Allowable MPE ( $\mu\text{W}/\text{cm}^2$ )	Calculated % MPE
AT&T 850 MHz UMTS	2	205.17	103	1.57	850 MHz	567	0.28%
AT&T 1900 MHz (PCS) UMTS	2	348.43	103	2.66	1900 MHz (PCS)	1000	0.27%
AT&T 1900 MHz (PCS) LTE	2	696.87	103	5.33	1900 MHz (PCS)	1000	0.53%
AT&T 700 MHz LTE	2	365.72	103	2.79	700 MHz	467	0.60%
AT&T 850 MHz GSM	2	552.23	103	4.22	850 MHz	567	0.74%
						Total:	2.42%

*Table 6: AT&T Maximum Sector MPE Power Values*



## Summary

All calculations performed for this analysis yielded results that were **within** the allowable limits for general population exposure to RF Emissions.

The anticipated maximum composite contributions from the AT&T facility as well as the site composite emissions value with regards to compliance with FCC's allowable limits for general population exposure to RF Emissions are shown here:

AT&T Sector	Power Density Value (%)
Sector A:	2.42 %
Sector B:	2.42 %
Sector C:	2.42 %
AT&T Maximum Total (per sector):	2.42 %
Site Total:	2.42 %
Site Compliance Status:	<b>COMPLIANT</b>

The anticipated composite MPE value for this site assuming all carriers present is **2.42 %** of the allowable FCC established general population limit sampled at the ground level. This is based upon values listed in the Connecticut Siting Council database for existing carrier emissions.

FCC guidelines state that if a site is found to be out of compliance (over allowable thresholds), that carriers over a 5% contribution to the composite value will require measures to bring the site into compliance. For this facility, the composite values calculated were well within the allowable 100% threshold standard per the federal government.

A handwritten signature in black ink, appearing to read 'Scott Heffernan', is positioned above the printed name.

Scott Heffernan  
RF Engineering Director  
**Centerline Communications, LLC**  
95 Ryan Drive, Suite 1  
Raynham, MA 02767