

STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

JOINT APPLICATION OF THE CONNECTICUT
LIGHT AND POWER COMPANY AND THE
UNITED ILLUMINATING COMPANY FOR A
CERTIFICATE OF ENVIRONMENTAL
COMPATIBILITY AND PUBLIC NEED FOR A
345-KV ELECTRIC TRANSMISSION LINE
FACILITY AND ASSOCIATED FACILITIES
BETWEEN SCOVILL ROCK SWITCHING
STATION IN MIDDLETOWN AND NORWALK
SUBSTATION IN NORWALK

DOCKET NO. 272

JUNE 7, 2004

SUPPLEMENTAL PREFILED TESTIMONY OF ISO NEW ENGLAND INC.
BY STEPHEN G. WHITLEY

1 **I. Introduction**

2

3 *Q. Please state your name and business affiliation.*

4 A. My name is Stephen G. Whitley and I am Senior Vice President and Chief

5 Operating Officer of ISO New England Inc. (“ISO” or “ISO-NE”).

6 *Q. Will ISO-NE experience any pecuniary benefit if the Connecticut Siting Council*

7 *either approves or denies the Applicants’ request for a Certificate of*

8 *Environmental Compatibility and Public Need for the electric transmission line at*

9 *issue and the line is placed in service?*

10 A. No.

11 *Q. Have you or any other representative of ISO New England Inc. (“ISO”)*

12 *previously testified in this proceeding?*

13 A. Yes. I submitted pre-filed testimony on March 9, 2004, and Mr. Kowalski and I

14 appeared before the Siting Council for cross-examination on March 23, 2004.

15 **II. ISO's Responsibilities Regarding Applicant's Proposal**

16 *Q. Why are you submitting supplemental pre-filed testimony in this proceeding?*

17 A. ISO has expressed in its previous testimony certain reservations regarding
18 extensive use of underground 345kV cable, and we wanted to report on our
19 continuing evaluation of the Applicants' proposed Middletown-Norwalk
20 overhead/underground 345kV project (the "Project"). We also wanted to provide
21 the Siting Council with a context which might enable better understanding of the
22 ISO's responsibilities regarding ultimate evaluation of the Project.

23 *Q. What are the ISO's responsibilities with respect to the Project?*

24 A. ISO's responsibilities with respect to and authority over the Project arise within
25 our broader mission of assuring the reliable day-to-day operation of New
26 England's bulk power generation and transmission system ("bulk power system")
27 and conducting the planning of the bulk power system in accordance with Good
28 Utility Practice and national and regional reliability criteria. Pursuant to that
29 mission, Section 18.4 of the Restated NEPOOL Agreement calls for a review of
30 any proposed additions to the transmission system rated 69kV or above and a
31 determination that no such addition proposed by any NEPOOL Participants (such
32 as the Applicants in this Docket) shall have a significant adverse effect upon the
33 reliability or operating characteristics of its system or of the systems of one or
34 more other Participants in NEPOOL. If the Participant proposing the
35 transmission system receives a notice from the ISO that the proposed addition will
36 have a significant adverse effect upon the reliability or operating characteristics of
37 its system or the systems of one or more other Participants, that Participant may

38 not proceed with the proposed addition (save for preliminary engineering work)
39 unless it agrees to such mitigative measures as ISO may determine to be
40 necessary to avoid significant adverse system impacts.

41 *Q. What is Good Utility Practice?*

42 A. “Good Utility Practice” is defined in the NEPOOL Open Access Transmission
43 Tariff as follows:

44 Any of the practices, methods and acts engaged in or approved by a
45 significant portion of the electric utility industry during the relevant time
46 period, or any of the practices, methods and acts which, in the exercise of
47 reasonable judgment in light of the facts known at the time the decision
48 was made, could have been expected to accomplish the desired result at a
49 reasonable cost consistent with good business practices, reliability, safety
50 and expedition. Good Utility Practice is not intended to be limited to the
51 optimum practice, method, or act to the exclusion of all others, but rather
52 includes all acceptable practices, methods, or acts generally accepted in
53 the region.
54

55 *Q. Is ISO obligated in any way to follow Good Utility Practice?*

56 A. Yes. ISO’s highest priority is designing and operating a safe and reliable bulk
57 power system, and Good Utility Practice informs all of the ISO’s system design
58 and operating decisions. I should add that ISO’s decisions with regard to
59 designing and operating the bulk power system must comply with national and
60 regional reliability criteria, and that obligation is memorialized in ISO’s operating
61 documents.

62 For example, in addition to the responsibilities I’ve already described, the
63 NEPOOL Tariff also requires that in ISO’s assessment of the New England bulk
64 power system (the “Regional Transmission Expansion Plan” or “RTEP”), the ISO
65 must publish the RTEP to conform to Good Utility Practice, as well as applicable

66 reliability principles. The Tariff requires that all proposed transmission upgrades
67 must also meet the requirements of Good Utility Practice and applicable
68 reliability principles. In short, ISO has an obligation to assure that any proposed
69 major transmission upgrades, including the Project, conform to Good Utility
70 Practice.

71 *Q. Is Good Utility Practice related to reliability?*

72 A. Yes, and this is quite clear not only from the definition of Good Utility Practice
73 given above, but also from the definition of a Reliability Upgrade in the NEPOOL
74 Tariff, which states that “Good Utility Practice, applicable reliability principles,
75 guidelines, criteria, rules, procedures and standards of NERC and NPCC and any
76 of their successors, applicable publicly available local reliability criteria, and the
77 NEPOOL System Rules” will be used to define the system facilities required to
78 maintain reliability in evaluating proposed Reliability Upgrades. This indicates
79 that proposed Reliability Upgrades must conform to the requirements of Good
80 Utility Practice in order to qualify as Reliability Upgrades.

81 *Q. Didn't ISO include in prior RTEPs the full 345kV loop in Southwestern*
82 *Connecticut, including both the Phase I line from Bethel to Norwalk and the*
83 *Phase II line from Middletown to Norwalk, and if so, wouldn't this suggest that*
84 *ISO views the full loop, including the Middletown-Norwalk segment, as*
85 *conforming to Good Utility Practice?*

86 A. In prior RTEPs, the ISO has included the so-called “full loop” transmission
87 project, which would consist of a line from Bethel to Norwalk and a line from
88 Middletown to Norwalk. However, the full loop configuration included as part of

89 RTEP’s assessment of system needs was an overhead line configuration. The
90 RTEPs did not contemplate the substantial amount of underground cable in the
91 full loop that would result from the combination of underground cable required in
92 Docket No. 217 and the amount of underground cable included in the Project, as
93 proposed by the Applicants.

94 *Q. Does the concept of Good Utility Practice apply to ISO in any other way?*

95 A. Yes, it is one of the considerations we must apply, pursuant to Schedule 12C of
96 the NEPOOL Tariff, in determining what costs are eligible for regional cost
97 support and what costs must be localized. Schedule 12C requires ISO, in making
98 its determination of whether Localized Costs exist, to consider the reasonableness
99 of the proposed design and construction method with respect to (i) Good Utility
100 Practice, (ii) the current engineering design and construction practices in the area
101 in which the Transmission Upgrade is built, (iii) alternate feasible and practical
102 Transmission Upgrades and (iv) the relative costs, operation, timing of
103 implementation, efficiency and reliability of the proposed Transmission
104 Upgrades.

105 In that regard, FERC has recently given the ISO additional guidance on
106 how to implement Schedule 12C, directing the ISO that “[a]ny costs incurred
107 above these basic costs (which include the costs necessary to maintain a safe,
108 reliable and adequate transmission infrastructure) should be borne by the locality
109 that will benefit from them.”¹

110

¹ See *Patrick C. Lynch, Attorney General of the State of Rhode Island v. ISO New England Inc.*, “Order Dismissing Petition for Declaratory Order,” 107 FERC ¶ 61,272 at P.17 (Docket EL04-91) (2004).

111 **III. Evaluation of Underground Cable Aspects of the Project**

112 *Q. Can you summarize the conclusions to date resulting from your evaluation of the*
113 *underground aspects of the Project as presently designed?*

114 A. It is ISO's belief, as explained more fully below, that the Project, as proposed and
115 presently designed, will not operate reliably. The proposal would introduce too
116 much capacitance to a relatively weak system, resulting in low order harmonic
117 resonances. This phenomenon can cause system failures, including cascading
118 outages, and damage to equipment, including transformers. The driving factors
119 regarding capacitance are linked to the length and type of cable installed and the
120 strength of the system to which it is connected. We have not seen a plan that
121 would satisfactorily mitigate these problems.

122 *Q. Where does ISO stand with respect to its evaluation of the Project, as proposed by*
123 *the Applicants?*

124 A. ISO has participated with the Applicants in the Southwest Connecticut Working
125 Group and has reviewed various studies prepared for the Applicants by their
126 consultants (the "GE Studies"). We have also devoted substantial efforts toward
127 identifying and resolving problems associated with the extensive use of
128 underground cable in the Project, as proposed by the Applicants. Lastly, because
129 of concerns raised by the GE Studies, we asked our own consultant, PB Power of
130 Boston, Massachusetts ("PB Power"), to review GE's analysis and conclusions.

131 *Q. What concerns were raised by the GE Studies?*

132 A. The concerns generally relate to the extensive amount of underground cable
133 proposed for the Project, which creates too much capacitance. For example, in its

134 Connecticut Cable Transient and Harmonic Feasibility Study, Final Report,
135 March 2003, GE observed, as we knew, that a long-distance Extra High Voltage
136 AC transmission cable system is unprecedented, and that the large amount of
137 cable charging capacitance associated with the transmission distances involved in
138 the SWCT Full Loop, combined with moderate short-circuit strengths which
139 occur under credible operating conditions, relative to the cable charging currents,
140 created the possibility of system configurations which introduce the risk of
141 transient and harmonic problems occurring. That Report noted the potential for
142 low-order harmonic resonance issues which could result in amplification of
143 harmonic voltage and current distortion and severe transient and temporary
144 overvoltages. These phenomena could cause power quality problems and could
145 damage customer and utility equipment, which in turn may cause cascading
146 failures on the bulk power system, impacting the region as a whole.

147 *Q. In reviewing the GE Studies, did ISO draw any conclusions regarding a minimum*
148 *acceptable resonant frequency?*

149 A. In Connecticut Cable Transient and Harmonic Study for Middletown to
150 Norwalk Project, East Devon-Beseck 40-mile Cable Option (M/N-P1), Final
151 Report, November 2003, GE stated that designing a system configuration which
152 results in an impedance resonance at 2nd harmonic is potentially very risky, could
153 result in severe power system disturbances and is not recommended. With respect
154 to this proposal, GE also stated that attempts to avoid the 2nd harmonic resonance
155 by adding 2nd harmonic filters would not be practical. Designing such a system of
156 distributed filters would also be a significant challenge.

157 Q. Does ISO agree with GE's position regarding 2nd harmonic frequencies?
158 A. As noted, we consulted with PB Power regarding the GE Studies. PB Power
159 reviewed the Project and GE's analysis, and they concurred that the Project, as
160 proposed or including suggested alternatives involving *additional* lengths of
161 underground cable, could result in resonant frequencies at or below the 3rd
162 harmonic. PB Power also cautioned that such low order harmonics are difficult
163 to mitigate as they result in complex, large and costly filter design. In order to
164 limit the complexity of corrective measures it is desirable to shift the low
165 harmonic order resonant frequencies (2nd and 3rd) to values above the 3rd. PB
166 Power recommended that consideration be given to reducing the additional
167 connected capacitance by increasing the use of technologies such as overhead
168 line, taking into account the number of proposed transmission interconnections
169 necessary to satisfy the security criteria of the transmission network under all
170 credible operating conditions. Alternative system configurations or equipment
171 selection should be considered to reduce the capacitance on the system and
172 therefore increase the frequency at which resonance is likely to occur to higher
173 order harmonics at which, if necessary, more practical harmonic filters can be
174 applied. If harmonics such as the 4th, 5th, 7th and 11th harmonic are still
175 problematic, appropriate filters can be designed.

176 Q. What have you concluded from your consultation with PB Power with regard to
177 acceptable levels of harmonics on the bulk power system?

178 A. The objective is to design a bulk power system, which when operating under all
179 credible conditions, does not result unacceptable power quality at consumers'

180 substations or delivery points. Designing the bulk power system to require
181 operation with resonant frequencies at or below the 3rd harmonic, unless practical
182 control measures are available, is not in accordance with Good Utility Practice
183 because common switching events, like the opening and closing of circuits that
184 occur in the normal operation of the bulk power system, can cause amplification
185 of harmonic voltage and current distortion that could lead to unacceptable power
186 quality and failures on the bulk power system should essential components
187 become damaged by the transient overvoltages imposed. Equally importantly, it
188 does not appear that practical solutions (in the nature of further investment in
189 transmission equipment) to mitigate against the excitation of a system which
190 resonates at or below the 3rd harmonic would be completely effective under all
191 foreseeable disturbances and would in any case be counter-productive due to the
192 increase in complexity of the system from an operational standpoint.

193 *Q. Would the minimum resonance frequency in the Project, as proposed, always be*
194 *above the 3rd harmonic?*

195 *A.* It is my understanding that the Project as proposed would result in operation
196 below the 3rd harmonic being required for some credible system configurations
197 and operating scenarios. Other higher resonant frequencies may also occur. The
198 actual values at which resonance occurs are affected by the specific configuration
199 of the system at the time of a particular disturbance.

200 *Q. Aside from Southwestern Connecticut, are you aware of any other area in the*
201 *New England bulk power system where operations occur at or below the 3rd*
202 *harmonic?*

203 A. No.

204 Q. *Are you aware of any other Transmission Owner in New England proposing to*
205 *construct transmission facilities resulting in harmonic levels at or below the 3rd*
206 *harmonic?*

207 A. No.

208 Q. *You commented that PB Power suggested that other equipment selection could be*
209 *considered to increase the level of harmonics. Did PB Power offer any comment*
210 *on other cable technologies than HPFF?*

211 A. PB Power suggested that XLPE cables offer the best ratings and the minimum
212 capacitance, but noted that long length EHV XLPE cable circuits are still
213 considered to be a developing technology. As the quantity of cable required for
214 the Project, in the M/N-P1 or P2 forms, would make it the largest AC cable
215 project ever undertaken anywhere in the world by a considerable margin, PB
216 Power advised that it would therefore be difficult to present engineering
217 justification for the implementation of all of the cable circuits using XLPE
218 insulated cables, even if it reduced capacitance sufficiently to raise harmonics
219 above the 3rd harmonic.

220 Q. *So, if the Project were designed to achieve operations above the 3rd harmonic,*
221 *would your concerns be resolved?*

222 A. Not necessarily. At a minimum, what we understand from reviewing the Project
223 as proposed, and consulting with PB Power, is that operation of the bulk power
224 system at or below the 3rd harmonic, unless practical control measures are
225 available, is not in accordance with Good Utility Practice. There are other design

226 or operating concerns, such as issues associated with scheme complexity, voltage
227 control, stability, short circuit duty and thermal ratings, that may arise from some
228 other configuration of overhead lines and underground cables, and that may
229 further depend on the type of underground cable technology used. As we have
230 previously testified, the complexity of the system design itself also introduces
231 operating uncertainties and reliability risks. In order to receive approval for
232 construction, we believe that it will be necessary to demonstrate that the
233 underground sections used, whatever their length, will not cause the system to
234 operate at or below the 3rd harmonic frequency level.

235 In short, the Project, or any modification of the Project which would result
236 in additional underground cable or any different configuration, would need to
237 conform with the requirements of Good Utility Practice and applicable reliability
238 principles. The practices and methods to be used in the Project or any
239 modification thereof must be engaged in or approved by a significant portion of
240 the electric utility industry, or, in the exercise of reasonable judgment in light of
241 the facts known at the time, could be expected to accomplish the desired result at
242 a reasonable cost consistent with good business practices, reliability, safety and
243 expedition.

244 *Q. Has ISO reached a conclusion regarding the Project, as proposed?*

245 *A.* At this time, based on information available to us and taking into consideration
246 the full 345 kV loop, including both Phase I, as approved in Docket 217, and
247 Phase II, as proposed in this proceeding, ISO has not seen a plan which results in
248 an acceptable level of capacitance in the system. Because the proposed Project, in

249 conjunction with Phase I, would introduce too much capacitance into the system,
250 which in turn would create harmonics and resonance conditions which cannot be
251 satisfactorily mitigated and could damage customer and utility equipment and
252 lead to outages, we would not find it acceptable. In light of PB Power's
253 evaluation of the Project and our communications with PB Power, I am not
254 comfortable that the Project, as proposed by the Applicants, offers the needed
255 degree of reliability for the transmission system in Southwestern Connecticut, is
256 designed in accordance with Good Utility Practice, or could otherwise be operated
257 in an acceptable manner. PB Power has also suggested, however, the desirability
258 of further study and evaluation to determine the extent additional overhead line,
259 alternative cable technology, or some combination of the two could mitigate the
260 adverse impacts to the bulk power system associated with the low harmonics
261 caused by the Project as proposed.

262 *Q. Would ISO support more underground cable than proposed by the Applicants?*

263 A. No. For the reasons already indicated regarding the Project as proposed, ISO
264 does not believe that it would be technically feasible to add more underground
265 cable than proposed by the Applicants. It would have to be demonstrated, at a
266 minimum, that any additional cable would not cause the system to operate at or
267 below the 3rd harmonic frequency level or that simple, effective control measures
268 are available to prevent power quality and overvoltage problems. Studies to date
269 do not indicate that this standard can be reached if more cable is used than the
270 Applicants have proposed.

271 Q. *Does ISO continue to believe that the transmission system in Southwestern*
272 *Connecticut needs reinforcement?*

273 A. ISO certainly believes that a 345kV loop is needed to reinforce the transmission
274 system in Southwestern Connecticut, and we believe that the Applicants have
275 worked hard to propose an upgrade which would meet this need, but we have not
276 yet seen a plan that will satisfactorily address the reliability concerns outlined
277 above.

278 Q. *Does this conclude your testimony?*

279 A. Yes, thank you.