

Exhibit 2: Southwest Connecticut Generation Contingencies

	MW of Capacity	Cases 1 Dispatch	Cases 2 Dispatch	Cases 3 Dispatch	Cases 4 Dispatch
New Haven Harbor ¹	451	ON/OFF	ON/OFF	ON/OFF	ON/OFF
Wallingford #1	51	OFF	ON	ON	OFF
#2	51	OFF	ON	ON	OFF
#3	51	OFF	ON	ON	OFF
#4	51	OFF	ON	ON	OFF
#5	51	OFF	ON	ON	OFF
Milford #1	280	ON	ON	ON	ON
#2	280	OFF	ON	ON	OFF
Norwalk Harbor #1	161	OFF	OFF	ON	ON
#2	168	OFF	OFF	ON	ON
Devon #7	106	ON	ON	ON	OFF
#8	106	ON	ON	ON	OFF
Bridgeport Harbor #3	375	ON	ON	ON	ON
Total Unavailable SWCT Generation Capability – New Haven Harbor ON		864	329	0	747
Total Unavailable SWCT Generation Capability – New Haven Harbor OFF		1,315	780	451	1,198

¹ Each dispatch contingency was run separately with the New Haven Harbor generator on and then off.