



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

March 28, 2019

Kathleen M. Shanley
Manager – Transmission Siting
Eversource Energy
P.O. Box 270
Hartford, CT 06103

RE: **PETITION NO. 1061** – The Connecticut Light and Power Company d/b/a Eversource Energy declaratory ruling that no Certificate of Environmental Compatibility and Public Need is required for the replacement of one monopole double-circuit 115-kV transmission line structure with two monopole single circuit 115-kV transmission line structures near Washington Boulevard and Station Place, Stamford, Connecticut.

Dear Ms. Shanley:

The Connecticut Siting Council (Council) is in receipt of your correspondence dated March 26, 2019 regarding the minor project changes to the above-referenced declaratory ruling that was approved by the Council on June 5, 2013.

Pursuant to the Council's Decision on June 5, 2013, your request for modification including, but not limited to, the replacement of two existing 115-kilovolt double-circuit overhead transmission structures with four single-circuit riser structures, the installation of an approximately 500-foot long underground double-circuit transmission line, and associated access and staging areas is hereby approved.

This approval applies only to the minor project changes dated March 26, 2019. Any significant changes to the project require advance Council notification and approval.

Thank you for your attention and cooperation.

Sincerely,

Melanie A. Bachman
Executive Director

MB/MP/lm

c: Council Members