James R. Morrissey
Attorney

VIA ELECTRONIC MAIL AND FedEx

September 29, 2017

Mr. Robert Stein
Chairman
The Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

Re: **PETITION NO. 1199** –The United Illuminating Company Petition for a Declaratory Ruling that no Certificate of Environmental Compatibility and Public Need is Required for the Construction, Operation, and Maintenance of a 2.8 MW AC Fuel Cell to be Located at Amity Regional High School, 25 Newton Road, Woodbridge, Connecticut.

Dear Chairman Stein:

Only July 21, 2017 a pressure relief valve actuated at The United Illuminating Company's ("UI" or the "Company") fuel cell approved in the above captioned Petition. The pressure relief valve actuated because the fuel cell was not effectively controlling the amount of heat entering the heat recovery system.

The enclosed reports detail the type of mixture released when the pressure relief valve actuated (Propylene glycol and water), the extent of the release, FuelCell Energy Inc.'s response, and the corrective actions taken to prevent further releases.

Please do not hesitate to contact me with any questions or concerns.

Very truly yours,

James R. Morrissey
Attorney
UIL Holdings Corporation
Counsel for The United Illuminating Company

Enclosures

cc: Jennifer Arasimowicz, Fuel Cell Energy

157 Church Street, New Haven, CT 06510
Telephone 203.499.2864
www.uinet.com, james.morrissey@avangrid.com

An equal opportunity employer