

August 19, 2016

Melanie Bachman, Esq.
Acting Executive Director
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

Re: PETITION NO. 1247 — C-TEC Solar, LLC petition for a declaratory ruling that no Certificate of Environmental Compatibility and Public Need is required for the proposed construction, maintenance, and operation of a 3.75 MW solar photovoltaic electric generating facility located at 1 Ballard Road, Thompson, Connecticut

SUPPLEMENTAL RESPONSES TO INTERROGATORIES (SET ONE)

Dear Attorney Bachman:

C-TEC Solar LLC (C-TEC) files this Supplemental Response to the Siting Council Interrogatories as set forth below.

1. C-TEC Solar LLC's (C-TEC or Petitioner) proposed photovoltaic facility would have a power output of up to 3.75 megawatts (MW). Is this output based on direct current (DC) or alternating current (AC)? If this is based on DC MW, provide the number of MW based on AC.

Original Response: This system is proposed to be +/- 3.75 MW DC and +/- 2.70 MW AC.

Supplemental Response: The total amount of power output from the entire installation is proposed to be +/- 3.75 MW DC and +/- 2.70 MW AC. The installation consists of two (2) Agricultural Virtual Net Metering (AVNM) Facilities (as defined in Conn. Gen. Stat. §16-244u). The two AVNM Facilities will be installed simultaneously. From the Siting Council's perspective, the environmental impact being analyzed is from the combined installation of the two AVNM Facilities and the fact that the installation is technically two AVNM Facilities has no bearing on the Siting Council's review. As such, C-TEC filed the application for the Siting Council approval for the entire installation as a whole and did not seek individual approvals. However, C-TEC is bringing this to the attention of the Siting Council to make sure that the Siting Council record is clear and to prevent any confusion by the Siting Council or any other regulatory body that may review the Siting Council record.

Respectfully Submitted,


Brad N. Mondschein