



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

December 28, 2016

Dawn Mahoney, Esq.
General Counsel
Doosan Fuel Cell America Inc.
195 Governor's Highway
South Windsor, CT 06074

RE: **PETITION NO. 1266** - Doosan Fuel Cell America, Inc. petition for a declaratory ruling that no Certificate of Environmental Compatibility and Public Need is required for the construction, maintenance, and operation of a 1840-kilowatt customer-side fuel cell facility to be located at the Waterbury Water Pollution Control Plant, 210 Municipal Road, Waterbury, Connecticut.

Dear Attorney Mahoney:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than January 18, 2017. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as send a copy via electronic mail. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Yours very truly,

Melanie Bachman
Acting Executive Director

MB/CW

c: Council Members
Patricia Walker

Petition No. 1266
Doosan Fuel Cell America, Inc.
Waterbury Water Pollution Control Plant
210 Municipal Road
Waterbury, CT
Interrogatories – Set Two

28. In response to Council interrogatory number 12, it is unclear whether a fence would be constructed around the proposed facility. Please state whether a fence is proposed around the fuel cell facility. If a fence would be installed, please provide the fence design specifications as previously requested.
29. As the Council previously requested in Council interrogatory number 2, please provide a detailed site plan with a scale for the proposed facility, including but not limited to, the dimensions and location of the proposed fuel cell facility, cooling module, concrete pads, fence design and bollards (if applicable) and utility connections.
30. In response to Council interrogatory number 9, Doosan did not provide a noise analysis report for the proposed fuel cell facility; however, Doosan states it will perform site specific noise studies at host property boundaries to confirm compliance. Please provide such noise analysis report including the cumulative effects of all four fuel cell units proposed at the host property boundaries.
31. In response to Council interrogatory number 14, Doosan provided a black and white copy of a zoning map of the whole City of Waterbury. Please provide a color map with the host property of the proposed fuel cell facility identified.
32. In response to Council interrogatory number 16, Doosan provided a copy of the FEMA Flood Insurance Rate Map (FIRM) of the general area of the facility property. Please provide the FIRM map with the location of the proposed fuel cell facility depicted.