



Submitted by Email and Hardcopy

February 28, 2019

Melanie A. Bachman
Executive Director
State of Connecticut
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

Development and Management Plan Update No. 3
Updated Plant Design Drawings
PSEG Power Connecticut LLC
Bridgeport Harbor Station Unit 5 Combined Cycle Project
Petition No. 1218

Dear Ms. Bachman:

This Development and Management Plan Update No. 3 (D&MP Update No. 3) provides revised and updated plant design drawings prepared to reflect minor changes and updates to the final design plans. The revisions are submitted for review and approval by Connecticut Siting Council (CSC) staff.

As background, this project is the combined cycle generating facility designated by PSEG Power Connecticut LLC (PSEG) as Bridgeport Harbor Station Unit 5 (“BHS 5”, the “Project” or the “Facility”) as addressed in Petition No. 1218. An initial D&MP submittal (D&MP Phase 1) for construction support facilities was filed with the CSC on September 21, 2016. A second D&MP submittal for permanent plant facilities and features (D&MP Phase 2) was filed on October 31, 2016. Collectively, these two D&MP documents included the complete design and construction details of the Project as known at that time. The D&MPs were approved by the CSC on October 27, 2016 and December 22, 2016, respectively.

D&MP Update No. 1 was filed on June 29, 2017 addressing improvements in the site water balance and underground utility routings and alignments. The D&MP Update No. 1 was approved by the CSC on July 6, 2017.

D&MP Update No. 2 was filed on April 11, 2018 to address revisions to the design for several areas, including final grading, water balances, onsite and offsite utilities, etc. This D&MP Update No. 2 was approved by the CSC on April 16, 2018.

Since then, there have been no substantive revisions made excepting for minor refinements for constructability, vendor clarifications, and / or to address site construction interferences. This

D&MP Update No. 3 includes the design drawings and descriptions that have changed from prior submitted documentation. These changes are considered to be minor in nature, more accurately reflect certain systems and design features and involve minimal refinements in utility or structure location:

1. Revisions to the ammonia tank and unloading area containment to address construction interferences;
2. Water Balance Diagrams, including a zinc removal system necessary to assure compliance with anticipated discharge limits;
3. Grading / paving and on-site underground utility drawings to reflect minor changes made during construction; and
4. General Arrangement Drawing (for reference) and drawings showing the recycle sump foundation plans in the General Services area, and consolidated foundations under the Air Cooled Condenser.

The revisions included in this D&MP Update No. 3 do not result in any significant changes to the appearance or function of the new plant, and are consistent with the applicable City of Bridgeport Building Permits. They do not result in any re-arrangement of facilities or structures (excepting for the noted minor adjustments in plan location); any change to the height or location of the plant Heat Recovery Steam Generator stack or the auxiliary boiler stack; a change in the Project's Limit of Disturbance; additional or different environmental impacts; a change in EMF conclusions or values; changes to previously defined offsite impacts; an increase in the drainage area associated with the stormwater system; or a change in the stormwater outfall or flows.

Based on our assessment of the project at this time, the enclosed plant design drawings reflect the current and final design plans for the Facility and are provided to CSC staff for review and approval as D&MP Update No. 3.

If you have any questions or require clarification, please contact me at 973-856-0066 or the Project Senior Technical Director / Regulatory Lead, Jeff Pantazes at 609-440-0236.

Very truly yours,



David Hinchey, Jr.

Manager Environmental - Major Permits & Technical Services
PSEG Power LLC
Fossil Environmental, Health and Safety

Enclosure – D&MP Update No. 3

C Harold Blinderman, Esq
Leilani M. Holgado, Esq.
Arthur Mantell
Scott Matheson
Jeffrey Pantazes
Leonard Rodriguez, Esq. (United Illuminating Company)
Thomas Gill (City of Bridgeport)

**Connecticut Siting Council
Development and Management Plan Update No. 3
Combined Cycle Generating Facility
PE 1218**

**Bridgeport Harbor Station Unit 5
Bridgeport, Connecticut**



Final Design Refinements - Minor Drawing Revisions

PSEG POWER CONNECTICUT, LLC

February 28, 2019

Development and Management Plan Update No. 3 Summary:

This project is the combined cycle generating facility as addressed in Petition No. 1218.

This Development and Management Plan Update (D&MP Update No. 3) submittal to the Connecticut Siting Council (CSC) includes minor drawing revisions to the detailed design plans for PSEG Power Connecticut LLC (PSEG) Bridgeport Harbor Station Unit 5 (“BHS 5”, the “Project” or the “Facility”). The revisions are submitted for review and approval by Connecticut Siting Council (CSC) staff.

Background

The initial D&MP submittal (D&MP Phase 1) for construction support facilities was filed with the CSC on September 21, 2016 and approved on October 27, 2016. A second D&MP submittal for permanent plant facilities (D&MP Phase 2) was filed on October 31, 2016 and approved by the CSC on December 22, 2016.

D&MP Update No. 1 was filed on June 29, 2017 addressing improvements in the site water balance and underground utility routings and alignments (approved on July 6, 2017). D&MP Update No. 2 was filed on April 11, 2018 to address revisions to the design plans for several areas, including final grading, water balances, onsite utilities, and offsite utilities (approved on April 16, 2018).

This D&MP Update No. 3 includes design changes that are considered to be minor in nature, more accurately reflect certain system design details, or involve minimal refinements in utility or structure locations. This includes:

1. Revisions to the ammonia tank and unloading area containment to resolve construction interferences;
2. Water Balance Diagrams, including a zinc removal system necessary to assure compliance with anticipated discharge limits;
3. Paving / grading and on-site underground utility drawings to reflect minor changes made during construction (note that some of the underground utility drawings are the same as previously submitted, but the complete set is included for more convenient reference); and
4. General Arrangement (for reference - essentially no changes from prior submittal), drawings showing the recycle sump in the General Services area, and an updated foundation drawing (showing foundation consolidation under the Air Cooled Condenser).

Connecticut Siting Council – Development and Management Plan Update No. 3
PSEG Bridgeport Harbor Station Unit 5
Petition No. 1218 (Approved July 21, 2016)
February 28, 2019

The revisions included in this D&MP Update No. 3 do not result in any significant changes to the appearance or function of the new plant and are consistent with the applicable City of Bridgeport Building Permits. They do not result in:

- Any re-arrangement of facilities or structures excepting for minor adjustments in plan location to address construction requirements;
- Any change to the height or location of the plant Heat Recovery Steam Generator stack or the auxiliary boiler stack;
- A change in the Project's Limit of Disturbance;
- Additional or different environmental impacts;
- A change in EMF conclusions or values;
- Changes to previously defined offsite impacts;
- An increase in the drainage area associated with the stormwater system; or
- A change in the stormwater outfall or flows.

To summarize, based on our assessment of the project at this time, the enclosed plant design drawings substantially reflect the final design plans for the Facility and are provided to CSC staff for review and approval as D&MP Update No. 3.

Exhibits

1. **Ammonia Tank / Unloading Area Containment Design**
2. **Water Balance Diagram**
3. **Onsite Underground Utility Design and Site Finishing / Grading Plans**
4. **General Arrangement and Foundation Plan Update**

**Connecticut Siting Council – Development and Management Plan Update No. 3
PSEG Bridgeport Harbor Station Unit 5
Petition No. 1218 (Approved July 21, 2016)
February 28, 2019**

Exhibit 1 Ammonia Tank / Unloading Area Containment Design

The ammonia tank and unloading area containment design and drawing have been revised to avoid construction interferences with the temporary access ramp in the southwest corner of the site. As originally designed, the containment would have precluded safe use of the ramp. The changes reduce the footprint of portions of the containment to avoid the interferences, but retain the required containment capacity.

<u>Drawing No.</u>	<u>Rev.</u>	<u>Drawing Title</u>
644911 F031-S001	2	Ammonia Area – Pipe Elevation and Foundation Plan Sheet 1 of 4
644911 F031-S002	4	Ammonia Area – Ammonia Tank Foundation Sheet 2 of 4
644911 F031-S003	3	Ammonia Area – Ammonia Unloading Platform Fdn Sheet 3 of 4
644911 F031-S004	2	Ammonia Area – Ammonia Vault Foundation Sheet 4 of 4
644911 GA013-S001	0	Plant Layout Ammonia Storage Area General Arrangement


**Connecticut Siting Council – Development and Management Plan Update No. 3
PSEG Bridgeport Harbor Station Unit 5
Petition No. 1218 (Approved July 21, 2016)
February 28, 2019**

Exhibit 2 Water Balance Diagram

The BHS 5 Water Balance Diagram has been revised to:

1. Reflect sampling points anticipated to be required by the Connecticut Department of Energy and Environmental Protection's (CT DEEP) Individual Pre-Treatment Permit (i.e. Industrial Wastewater Discharge Permit No. SP0002474 authorizing discharges to the City of Bridgeport's Water Pollution Control Authority) when issued; and
2. Add zinc removal capability on the Reverse Osmosis reject water line to assure long-term compliance with the above referenced Individual Pre-Treatment Permit No. SP0002474.

<u>Drawing No.</u>	<u>Rev.</u>	<u>Drawing Title</u>
644911-FD002-S001	2	Water Mass Balance Water System Flow Diagram Sheet 1
644911-FD002-S002	2	Water Mass Balance Water System Flow Diagram Sheet 2
644911-FD002-S003	1	Water Mass Balance Water System Flow Diagram Sheet 3
644911-FD002-S004	1	Water Mass Balance Water System Flow Diagram Sheet 4
644911-FD002-S005	2	Water Mass Balance Water System Flow Diagram Sheet 5



GENERAL NOTES:

1. INDICATED FLOWS, RATES MAY NOT BALANCE DUE TO ROUNDING.
2. QUENCHED BLOWDOWN TEMPERATURE EQUAL OR LESS THAN 140 DEGREES F.
3. ASSUMED 85% RO RECOVERY, RO REJECT WILL BE TREATED WITH ZINC REMOVAL EXCHANGER WHEN THE PLANT RUNS ON FUEL OIL OPERATION. (LOW AMBIENT, CASE 3 & 6).
4. 6 CYCLES OF CONCENTRATION.

FOR WASTEWATER PERMIT APPLICATION									
Stream no.	Description	Unit	Low Ambient Case	CASE 1	CASE 2	CASE 3	CASE 4	CASE 5	CASE 6
	USLD, EC off, DF ON, 100% GT load	USLD, EC off, DF off, NG, EC ON, DF ON, 100% GT load	NG, EC ON, DF ON, 100% GT load	USLD, EC off, DF off, 100% GT load	NG, EC ON, DF ON, 100% GT load	USLD, EC off, DF ON, 100% GT load	NG, EC ON, DF ON, 100% GT load	USLD, EC off, DF ON, 100% GT load	NG, EC ON, DF ON, 100% GT load
1	Ambient temperature	0 F	59 F / 60% RH	90 F / 70% RH	35 F / 50% RH	90 F / 70% RH	59 F / 60% RH	35 F / 50% RH	35 F / 60% RH
	HRSG & Heat balance, Case no.	56 & CCA20146	Case 1 (HRSG) & Heat balance CCA20095	Case 2 (HRSG) & Heat balance CCA20081	Case 3 (HRSG) & Heat balance CCA20139	Case 4 (HRSG) & Heat balance CCA20081	Case 5 (HRSG) & Heat balance CCA2004	Case 6 (HRSG) & Heat balance CCA20138	
1	City water supply	gpm	583	120	168	616	170	143	621
2	Portable water network	gpm	2	2	2	2	2	2	2
3	Supply to Service/Fire water tank	gpm	551	118	166	614	168	141	619
4	Service water demand	gpm	616	118	166	645	168	141	655
5	Service water makeup to CT makeup	gpm	8	67	81	31	83	62	32
6	Service water for misc uses	gpm	7	7	7	7	7	7	7
7	Supply to CTG evap cooler	gpm	0	0	23	0	23	20	0
	Total steam rate	lb/h	1,072,600	821,700	1,032,100	812,500	1,028,000	993,100	1,002,500
11	Boiler makeup	gpm	38	29	36	28	36	35	35
12	Nox Water	gpm	493	0	0	509	0	0	509
10	Total demin water	gpm	531	29	36	537	36	35	544
13	Leased RO/D trailers, permeate	gpm	300	29	36	300	36	35	300
15	Supplement DI trailer, min flow	gpm	231	0	0	237	0	0	244
16	Leased RO/D trailers, feed	gpm	353	34	42	353	42	41	353
18	Supplement DI trailer, feed	gpm	237	0	0	244	0	0	251
19	Water pretreatment backwash	gpm	1	1	1	1	1	1	1
20	Total supply to water treatment	gpm	591	35	43	598	43	42	605
21	CT evaporation	gpm	46	86	105	68	105	86	68
	CT makeup from all sources	gpm	64	100	124	87	126	103	89
	CT Cycles of concentration	-	3.5	7.0	6.5	4.5	6.0	6.0	4.3
22	CT Drift	gpm	0.1	0.1	0.1	0.1	0.1	0.1	0.1
23	CTG evap cooler evaporation	gpm	0	0	19	0	19	17	0
27	Misc losses from w/s cycle	gpm	11.8	8.0	11.2	7.9	11.1	10.6	10.7
28	HRSG blowdown	gpm	21	16	21	16	21	20	20
	Blowdown, after flashing	gpm	13	10	12	10	12	12	12
30	Quench water, gpm	gpm	10	9	11	9	11	11	11
31	To blowdown sump	gpm	23	19	24	19	24	23	23
41	Fire water system	gpm	0	0	0	0	0	0	0
61	Demin water to CTG water wash	gpm	0	0	0	0	0	0	0
62	Demin water to ACC fin tube cleaning	gpm	0	0	0	0	0	0	0
63	Demin water to chemical dilution	gpm	0	0	0	0	0	0	0
501	Non oily wastewater	gpm	5	5	5	5	5	5	5
502	Condensate polisher backwash	gpm	0.3	0.3	0.3	0.3	0.3	0.3	0.3
503	sample panel drains	gpm	4	4	4	4	4	4	4
505	RO Reject	gpm	53	5	6	53	6	6	53
506	Evaporative cooler blowdown	gpm	0	0	0	0	0	0	0
	Total from blowdown sump	gpm	28	37	28	37	35	32	32
507	Recycle to CT basin from BD sump	gpm	0	28	37	0	37	35	0
508	To cartridge filters	gpm	32	0	0	28	0	0	32
509	Recycle water sump	gpm	4	0	0	4	0	0	4
510	Recycle to 5f water tank	gpm	32	0	0	28	0	0	32
511	Oily wastewater	gpm	2	2	2	2	2	2	2
512	CT blowdown	gpm	18	14	19	19	21	17	21
512	Temperature degree F	degree F	41	67	91	54	91	67	54
512	Total dissolved solids	mg/l	2494	1034	1061	2480	975	1026	2437
512	Total suspended solids	mg/l	4	7	7	5	7	7	2
513	Plant process wastewater, Final	gpm	0.23	0.80	0.85	0.34	0.78	0.80	0.32
513	Temperature	degree F	44	66	87	55	87	66	55
513	Total dissolved solids	mg/l	2179	897	950	2,180	883	909	2,159
513	Total suspended solids	mg/l	15	21	18	15	17	19	12
513	Sanitary wastewater	gpm	0.22	0.68	0.75	0.31	0.70	0.70	0.29
514	Rinse water recycle to service/fire water tank	gpm	0.21	0.63	0.70	0.29	0.66	0.65	0.28
515	Total wastewater	gpm	2.9	0	0	2.9	0	0	2.9
515	Total dissolved solids	mg/l	2022	840	899	2,030	842	858	2,017
515	Total suspended solids	mg/l	34	44	36	34	34	39	30
515	Zinc	mg/l	0.21	0.63	0.70	0.29	0.66	0.65	0.28
516	Rinse water recycle to service/fire water tank	gpm	0	0	0	0	0	0	0

ORIGINAL

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED FOR TOWER CYCLE OF CONCENTRATION
FOR LOW AMBIENT AND CASE 6.

ISSUED FOR CONSTRUCTION

REVISED COOLING TOWER CYCLE
FOR LOW AMBIENT AND CASE 6.

	Unit	City water supply, stream 1	Demineralized water	Evaporative cooler feed, stream 7	Evaporative cooler blowdown, stream 506	Boiler blowdown, exclude quenching	RO reject from permanent stream 505	Combined cooling tower makeup	Cooling tower blowdown, stream 512	Sanitary wastewater, stream 514	Plant discharge to sewer main, stream 15
Flow rate	gpm	120	0	0	10	5	100	14	2	19.3	
Biochemical oxygen demand (5 day)	mg/l	<1	<1				<1	3.5	220	25	
Chemical oxygen demand	mg/l	4.9	4.9				4.9	17.15	500	64	
Oil and grease, total*	mg/l	<1	<1	<6			<1	7	100	17	
Oil and grease, hydrocarbon fraction	mg/l		<1	<6				1	7	220	43
Total suspended solids	mg/l	<0.10	<0.10	<0.6			<0.10	0.05	30	3	
Ammonia, as nitrogen*	mg/l	0.39	0.39	2.34			0.39	2.73	3.26	2.46	
Phosphorus, total	mg/l										
Ortho phosphate	mg/l	2.75	2.75	16.5	6	18.3	3.87	27.08	10	21.82	
Nitrate	mg/l	0.039	0.039	0.234			0.03	0.22	0.078	0.18	
Nitrite*	mg/l		<0.002	<0.012			<0.002	0.014		<0.02	
Total Fieldable nitrogen	mg/l	0.97	0.97				0.8	5.5	40	8	
Total residual chlorine	mg/l	1	0.2				0.08	0.1		0.1	
Temperature	degrees F	60	60	212	60	65.29	67.4	60		65.5	
pH		7.8	7.8	7.8	8.8-10	7.9	7.8	7.8-5		7.8-5	
Lead, total*	mg/l	<0.01	<0.01	<0.06			<0.01	0.07		0.052	
Antimony, total*	mg/l	<0.001	<0.001	<0.006			<0.001	0.007		0.005	
Chromium, total*	mg/l	0.1	0.1	0.6		0.7	0.11	0.80		0.62	
Zinc, total	mg/l										
Antimony, total*	mg/l	<0.0008	<0.0008	<0.0048			<0.0008	0.0056		0.004	
Arsenic, total*	mg/l		<0.0005	<0.0005			<0.0005	0.0035		0.0026	
Boron, total*	mg/l	<0.0003	<0.0003	<0.0018			<0.0003	0.0021		0.0016	
Cadmium, total*	mg/l	<0.0003	<0.0003	<0.0018			<0.0003	0.0021		0.0016	
Chromium, total*	mg/l	<0.001	<0.001	<0.006			<0.001	0.007		0.005	
Chromium	mg/l										
Mercury, total*	mg/l		<0.0002	<0.0002			<0.0002	0.0014		0.001	
Nickel, total*	mg/l		<0.005	<0.005			<0.005	0.035		0.026	
Selenium, total*	mg/l		<0.001	<0.001	<0.006		<0.001	0.007		0.005	
Silver, total*	mg/l		<0.001	<0.001	<0.006		<0.001	0.007		0.005	
Thallium, total*	mg/l		<0.001	<0.001	<0.006		<0.001	0.007		0.005	
Cyanide, total*	mg/l		<0.0066	<0.0066	<0.04		<0.0066	0.0462		0.034	
Cyanide	mg/l										
Phenols, total	mg/l										
Bromide*	mg/l	<0.05	<0.05	<0.3			<0.05	0.35		0.26	
Color	C.U.	2	2				2	20			
Fecal coliform	CFU/100 ml	<1	<1				<1	7			
Fluoride	mg/l	0.74	0.74	4.44			4.93	0.85	5.93	4.7	
Nitrogen, total organic	mg/l										
Radioactivity	mg/l										
Sulfate	mg/l	17	0.003	17	102	1	113	20	179	51	142
sulfide*	mg/l	<0.05	<0.05	<0.3			<0.05	0.35		0.26	
Surfactants	mg/l										
Aluminum, total	mg/l	0.02		0.02			0.02	0.16		0.12	
Barium, total	mg/l	0.014		0.014			0.016	0.112		0.086	
Boron, total	mg/l	0.012		0.012			0.014	0.096		0.074	
Cobalt, total	mg/l										
Iron, total*	mg/l	<0.01	<0.01	<0.06			0.07	0.01	0.08	0.02	0.06
Magnesium, total	mg/l	4.5	4.5	27			30	5.2	36.1	9	29
Manganese	mg/l		<0.01	<0.01	<0.06		<0.07	0.01	0.08	0.02	0.06
Calcium	mg/l	14	14	84			93	16	112	90	
Sodium	mg/l	19	0.003	19	114	3	127	22	157	125	
Potassium	mg/l	2	2	2	12	13	2	16	13	13	
Silica	mg/l	4.4	0.01	4.4	26	2	29	5.3	37.0	29	
Chloride	mg/l	31	0.003	32	192		207	36	249	199	
Total dissolved solids	mg/l	125		125	706	12	844	148	1034	386	839
Alkalinity, as CaCO ₃	mg/l	31		31	125		207	36	205	100	170

ESTIMATED PERFORMANCE - CASE 5

Parameter	Unit	City water supply, stream 1	Demineralized water	Evaporative cooler feed, stream 7	Evaporative cooler blowdown, stream 506	Boiler blowdown, exclude quenching	RO reject from permanent RO/DI system, stream 505	Combined cooling tower makeup	Cooling tower blowdown, stream 512	Sanitary wastewater, stream 514	Plant discharge to sewer main, stream 515
Flow rate	gpm	143		20	3	12	6	103	17	2	22
Biochemical oxygen demand (5 day)	mg/l	<1		<1			<1	3	220	22	
Chemical oxygen demand	mg/l	5		5			4.9	15	500	56	
Oil and grease, total*	mg/l	<1		<1	<6		<1	6	100	15	
Oil and grease, hydrocarbon fraction	mg/l										
Total suspended solids	mg/l	<1		<1	<6	2	1	7	220	39	
Ammonia, as nitrogen*	mg/l	<0.1		<0.1	<0.6		<0.1	0.05	30	2.74	
Phosphorus, total	mg/l	0.39		2			0.39	2.34	3.26	2.19	
Ortho phosphate	mg/l	3		2.75	17	6	18.3	4.5	27.0	10.0	22.5
Nitrate	mg/l	0.039		0.23			0.04	0.22	0.08	0.19	
Nitrite*	mg/l	<0.002		<0.012			<0.002	0.012		<0.009	
Total kjeldahl nitrogen	mg/l	1		1			1	4	40	7	
Total residual chlorine	mg/l	1		1.0			0	0.8	0.1	0.1	
Temperature	degree F	60		60		212	60	64.8	67.4	60	65.7
pH		7.8		7.8	0	8.8-10	7.9	7.8	7-8.5	7-8.5	
Copper, total*	mg/l	<0.01		<0.01	<0.06		<0.01	0.06		0.046	
Lead, total*	mg/l	<0.001		<0.001	<0.006		<0.001	0.006		0.005	
Zinc, total	mg/l	0.1		0.1	0.6		0.7	0.1	0.8	0.7	
Antimony, total*	mg/l	<0.0008		<0.0008	<0.0048		<0.0008	0.0048		0.0037	
Arsenic, total*	mg/l	<0.0005		<0.0005	<0.003		<0.0005	0.003		0.0023	
Beryllium, total*	mg/l	<0.0003		<0.0003	<0.0018		<0.0003	0.0018		0.0014	
Cadmium, total*	mg/l	<0.0003		<0.0003	<0.0018		<0.0003	0.0018		0.0014	
Chromium, total*	mg/l	<0.001		<0.001	<0.006		<0.001	0.006		0.005	
Chromium	mg/l										
Mercury, total*	mg/l										
Nickel, total*	mg/l										
Selenium, total*	mg/l										
Silver, total*	mg/l										
Thallium, total*	mg/l										
Cyanide, total*	mg/l										
Cyanide	mg/l										
Phenols, total	mg/l										
Bromide*	mg/l	<0.05		<0.05	<0.3		<0.05	0.3		0.23	
Color	C.U.	2		2			2	20			
Fecal coliform	CFU/100 ml	<1		<1			<1	6			
Fluoride	mg/l	0.74		0.74	4.44		4.93	0.99	5.95	1.48	4.91
Nitrogen, total organic	mg/l										
Radioactivity	mg/l										
Sulfate	mg/l	17	0.003	17	102	1	113	23	174	51	143
sulfide	mg/l										
sulfite*	mg/l	<0.05		<0.05	<0.3		<0.05	0.3		0.24	
Surfactants	mg/l										
Aluminum, total	mg/l	0.02		0.02	0.12		0.03	0.16	0.04	0.13	
Barium, total	mg/l	0.014		0.014	0.084		0.019	0.113	0.028	0.092	
Boron, total	mg/l	0.012		0.012	0.072		0.016	0.097	0.024	0.079	
Cobalt, total	mg/l										
Iron, total *	mg/l	<0.01		<0.01	<0.06		0.07	0.01	0.08	0.02	0.07
Magnesium, total	mg/l	5		5	27		30	6	36	9	30
Manganese	mg/l	<0.01		<0.01	<0.06		0.07	0.01	0.08	0.02	0.07
Calcium	mg/l	14		14	84		93	19	113	28	93
Sodium	mg/l	19	0.003	19	114	1	127	26	155	38	128
Potassium	mg/l	2		2	12		13	3	16	4	13
Silica	mg/l	4	0.01	4	26	2	29	6.2	37.0	9	30.5
Chloride	mg/l	31	0.003	31	186		42	42	249	62	206
Total dissolved solids	mg/l										
Alkalinity, as CaCO ₃	mg/l	31		31	125		700	10	844	1026	386

3

Total kjeldahl nitrogen	mg/l	1	1	1	1	1	4	40	7
Total residual chlorine	mg/l	1	1.0	0	0.8	0.1	0.1	0.1	0.1
Temperature	degree F	60	60	212	60	64.8	67.4	60	65.7
pH		7.8	7.8	0	8.8-10	7.9	7.8	7-8.5	7-8.5
Copper, total*	mg/l	<0.01	<0.01	<0.06	<0.01	<0.01	0.06	0.046	
Lead, total*	mg/l	<0.001	<0.001	<0.006	<0.001	<0.001	0.006	0.005	
Zinc, total	mg/l	0.1	0.1	0.6	0.7	0.1	0.8	0.7	
Antimony, total*	mg/l	<0.0008	<0.0008	<0.0048	<0.0008	<0.0008	0.0048	0.0037	
Arsenic, total*	mg/l	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	0.003	0.0023	
Beryllium, total*	mg/l	<0.0003	<0.0003	<0.0018	<0.0003	<0.0003	0.0018	0.0014	
Cadmium, total*	mg/l	<0.0003	<0.0003	<0.0018	<0.0003	<0.0003	0.0018	0.0014	
Chromium, total*	mg/l	<0.001	<0.001	<0.006	<0.001	<0.001	0.006	0.005	
Chromium									
Mercury, total*	mg/l	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	0.0012	0.0012	0.0009
Nickel, total*	mg/l	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	0.03	0.023

3

Silver, total*	mg/l	<0.001	<0.006	<0.001	0.006	0.005
Thallium, total*	mg/l	<0.001	<0.006	<0.001	0.006	0.005
Cyanide, total*	mg/l	<0.0066	<0.04	<0.0066	0.0396	0.0307
Cyanide	mg/l					
Phenols, total	mg/l					
Bromide*	mg/l	<0.05	<0.3	<0.05	0.3	0.23
Color	C.U.	2	2	2	20	
Fecal coliform	CFU/100 ml	<1	<1	<1	6	
Fluoride	mg/l	0.74	4.44	4.93	5.95	4.91
Nitrogen, total organic	mg/l					
Radioactivity	mg/l					
Sulfide	mg/l					
Sulfide	mg/l					
Sulfide*	mg/l	<0.05	<0.05	<0.3	<0.05	0.3
Surfactants	mg/l					0.24

1

1

F

E

D

C

B

A

F

E

D

C

B

A

ESTIMATED PERFORMANCE - CASE 6

		Recycled from HRSG blowdown sump + demin system rinse. Stream 510+stream 516	Service/fire water tank outlet, stream 4	Demineralized water	Evaporative cooler feed, stream 7	Evaporative cooler blowdown, stream 506	Boiler blowdown, exch quenching	RO reject from permanent RO/DI system, stream 505	Cooling tower blowdown, stream 512	Sanitary wastewater, stream 514	Plant discharge to stream 515
Flow rate	gpm	619	35	655	0	0	12	53	84.8	206	25.6
Biochemical oxygen demand (5 day)	mg/l	<1	1	1	1	4.8		0.98	2.15	220	19
Chemical oxygen demand	mg/l	4.9	3.2	4.8				4.8	10.3	500	47
Oil and grease, total*	mg/l	<1	0.7	1.0		1.0	<6	0.98	4.3	100	12
Oil and grease, hydrocarbon fraction	mg/l										
Total suspended solids	mg/l	<1	1	1	1	<6	2	0.4	2	220	30
Ammonia, as nitrogen*	mg/l	<0.1	0.07	0.10	0.10	<0.6		0.10	0.06	30	2.39
Phosphorus, total	mg/l	0.39	0.26	0.38	0.38	2.30		0.4	1.6	3.26	1.66
Ortho phosphate	mg/l	2.75	3.86	2.81	2.81	16.86	6	18.7	12.7	54.8	10
Nitrate	mg/l	0.039	0.026	0.038	0.038	0.230		0.014	0.062	0.078	0.06
Nitrite*	mg/l	<0.002	0.001	0.002	0.002	<0.012		0.002	0.009		0.01
Total Kjeldahl nitrogen	mg/l	0.97	0.64	0.95	0.95			0.4	1.5	40	5
Total residual chlorine	mg/l	1	0.3	1.0	1.0			0.36	0.1		0.1
Temperature	degree F	60	117	63	63	212	63	63.1	54.1	60	55.3
pH		7.8	8.1	7.5	7.5	7.8	8.3-10	7.9	7.8	7.8-8.5	
Copper, total*	mg/l	<0.01	0.01	0.01	0.01	0.06		0.010	0.04		0.03
Lead, total*	mg/l	<0.001	0.001	0.001	0.001	<0.006		0.001	0.004		0.003
Zinc, total (NOTE 2)	mg/l	0.1	0.1	0.1	0.1	0.6		0.1	0.08	0.33	0.30
Antimony, total*	mg/l	<0.0008	0.0005	0.0008	0.0008	0.008	<0.0008		0.008	0.003	0.003
Arsenic, total*	mg/l	<0.0005	0.0003	0.0005	0.0005	0.0005	<0.003		0.0005	0.002	0.002
Beryllium, total*	mg/l	<0.0003	0.0002	0.0003	0.0003	0.0003	<0.0003		0.0003	0.001	0.001
Cadmium, total*	mg/l	<0.0003	0.0002	0.0003	0.0003	0.0003	<0.0008		0.0003	0.001	0.001
Chromium, total*	mg/l	<0.001	0.001	0.001	0.001	0.001	<0.006		0.001	0.004	0.003
Chromium	mg/l										
Mercury, total*	mg/l	<0.0002	0.0013	0.0003	0.0003	0.0003	<0.0012		0.0003	0.0009	0.0007
Nickel, total*	mg/l	<0.005	0.003	0.005	0.005	0.005	<0.003		0.0049	0.022	0.017
Selenium, total*	mg/l	<0.001	0.0007	0.001	0.001	0.001	<0.006		0.0010	0.004	0.003
Silver, total*	mg/l	<0.001	0.0007	0.001	0.001	0.001	<0.006		0.0010	0.004	0.003
Thallium, total*	mg/l	<0.001	0.0007	0.001	0.001	0.001	<0.006		0.0010	0.004	0.003
Cyanide, total*	mg/l	<0.0006	0.0004	0.0005	0.0005	0.0065	<0.04		0.0065	0.028	0.023
Cyanide	mg/l										
Phenols, total	mg/l										
Bromide*	mg/l	<0.05	0.03	0.05	0.05	<0.3			0.0491	0.215	0.175
Color	CU.	2	1	2	2			2	20		
Fecal coliform	CFU/100 ml	<1	0.7	1	1			1	4		
Fluoride	mg/l	0.74	0.49	0.73	0.73	4.84	3.30	14.18	1.48	11.7	
Nitrogen, total organic	mg/l										
Radioactivity	mg/l										
Sulfate	mg/l	17	12	17	0.003	17	100	1	111	76	610
sulfide*	mg/l	<0.05	0.03	0.05	0.05	<0.3			0.049	0.215	0.188
Surfactants	mg/l										
Aluminum, total	mg/l	0.02	0.01	0.02	0.02	0.12			0.09	0.38	0.31
Barium, total	mg/l	0.014	0.009	0.014	0.014	0.014	0.082		0.062	0.268	0.220
Boron, total	mg/l	0.012	0.008	0.012	0.012	0.012	0.071		0.053	0.230	0.189
Cobalt, total	mg/l	<0.01	0.01	0.01	0.01	<0.06		0.07	0.04	0.19	0.158
Magnesium, total	mg/l	4.5	3.0	4.4	4.4	26.5		29	20	86	71
Manganese	mg/l	<0.01	0.01	0.01	0.01	<0.06		0.07	0.04	0.19	0.16
Calcium	mg/l	14	9	14	14	82		92	62	268	28
Sodium	mg/l	19	13	19	19	0.003		19	85	366	38
Potassium	mg/l	2	1	2	2			1	124	9	301
Silica	mg/l	4.4	3.0	4.3	4.3	0.01		13	38	4	32
Chloride	mg/l	31	22	31	31	183		204	139	596	490
Total dissolved solids	mg/l	125	89	123	123	829		10	138	347	2016
Alkalinity, as CaCO ₃	mg/l	31	20	30	30	122		203	138	297	253

1

2

3

4


3

4

5

GENERAL NOTES:

1. ASTERISK (*) INDICATES TESTING PARAMETER IS UNDETECTABLE IN WATER VALUE SHOWN REPRESENTS THE DETECTION LIMIT OF THE ANALYTICAL INSTRUMENT.
2. RO REJECT WILL BE TREATED WITH ZINC REMOVAL ON EXCHANGER WHEN THE PLANT RUNS ON FUEL/OIL OPERATION.



1

ESTIMATED PERFORMANCE - CASE 6

2

2

3

3

4

4

5

5

1

1

2

2

3

3

4

4

5

5

6

6

7

7

8

8

9

9

10

10

11

11

12

12

13

13

14

**Connecticut Siting Council – Development and Management Plan Update No. 3
PSEG Bridgeport Harbor Station Unit 5
Petition No. 1218 (Approved July 21, 2016)
February 28, 2019**


Exhibit 3 Onsite Underground Utility Design, Site Finishing, and Grading Plans


Revisions to paving / grading, site finishes and on-site underground utility drawings to reflect minor changes made during construction:


<u>Drawing No.</u>	<u>Rev.</u>	<u>Drawing Title</u>
644911 C006-S001	1	Yard Roads and Paving – Paving Plan Sheet 1 of 5
644911 C006-S002	1	Yard Roads and Paving – Paving Plan Sheet 2 of 5
644911 C006-S003	1	Yard Roads and Paving – Paving Plan Sheet 3 of 5
644911 C006-S004	1	Yard Roads and Paving – Paving Plan Sheet 4 of 5
644911 C006-S005	1	Yard Roads and Paving – Paving Plan Sheet 5 of 5
644911-P200-S001	1	Yard Underground Piping Plan
644911-P201-S001	2	Yard Underground Piping Plan Area 1
644911-P202-S001	1	Yard Underground Piping Plan Area 2
644911-P203-S001	3	Yard Underground Piping Plan Area 3
644911-P204-S001	2	Yard Underground Piping Plan Area 4
644911-P205-S001	5	Yard Underground Piping Plan Area 6
644911-P206-S001	1	Yard Underground Piping Plan Area 6
644911-P207-S001	1	Yard Underground Piping Plan Area 7
644911-P208-S001	3	Yard Underground Piping Plan Area 8
644911-P209-S001	3	Yard Underground Piping Plan Area 9
644911-P210-S001	3	Yard Underground Piping Plan Area 10
644911-P211-S001	3	Yard Underground Piping Plan Area 11
644911-P212-S001	6	Yard Underground Piping Plan Area 12
644911-P213-S001	4	Yard Underground Piping Plan Area 13


**Connecticut Siting Council – Development and Management Plan Update No. 3
PSEG Bridgeport Harbor Station Unit 5
Petition No. 1218 (Approved July 21, 2016)
February 28, 2019**


644911-P214-S001	5	Yard Underground Piping Plan Area 14
644911-P215-S001	0	Yard Underground Piping Plan Area 15
644911-P216-S001	4	Yard Underground Piping Plan Area 16
644911-P217-S001	5	Yard Underground Piping Plan Area 17
644911-P218-S001	5	Yard Underground Piping Plan Area 10
644911-P219-S001	5	Yard Underground Piping Plan Area 19
644911-P220-S001	2	Yard Underground Piping Plan Area 20
644911-P221-S001	5	Yard Underground Piping Plan Area 21
644911-P222-S001	7	Yard Underground Piping Plan Area 22
644911-P223-S001	2	Yard Underground Piping Plan Area 23
644911-P224-S001	4	Yard Underground Piping Plan Area 24
644q11-P225-S001	1	Yard Underground Piping Plan Area 25
644911-P226-S001	3	Yard Underground Piping Plan Area 26
644911-P227-S001	1	Yard Underground Piping Plan Area 27
644911-P230-S001	1	Underground Piping Bedding Details
644911-P231-S001	2	Underground Piping Details
644911-P232-S001	1	Underground Piping Cathodic Protection Details
644911-P233-S001	3	Underground Fire Protection Piping Firewater Loop
644911-P233-S002	0	Underground Fire Protection Piping Sections and Details


























11

33

100


1


2


८


4


5









































GENERAL NOTES:


1. FOR GENERAL NOTES SEE DWG 644911 P200-S001


- 10 -


ORIGINAL

REVISED LINE 5FVf-507

PROJECT ENGINEERING DIVISION	
PROJECT: PSEG	
SNC-LAVALIN CONSTRUCTORS INC.	
 SNC-LAVALIN CONSTRUCTORS INC.	
SCALE: 1/8" = 10'	BRIDGEPORT 05
UNDERGROUND DRAINAGE PLAN	
AUG 27 2001	
DESIGN-CIVIL GENERAL	
PARTIAL SITE PLAN	
644911 P227-S001	







**Connecticut Siting Council – Development and Management Plan Update No. 3
PSEG Bridgeport Harbor Station Unit 5
Petition No. 1218 (Approved July 21, 2016)
February 28, 2019**

Exhibit 4 General Arrangement and Foundation Plan Update

The most recent General Arrangement drawing is included to update the CSC records and for reference. There have been no changes of significance since the previous submittal in April 2018. Additionally, the specific Plans and Details for the Recycle Sump (No. 128 on the General Arrangement) and the overall Foundation Location Plan are included.

<u>Drawing No.</u>	<u>Rev.</u>	<u>Drawing Title</u>
644911 GA002-S001	1	Plant Layout – Power Block General Arrangement
644911 F043-S001	1	Recycle Water Sump – Foundation Plan
644911 F002-S001	16	Foundation Location Plan Sheet 1 of 1

