




August 30, 2017

**VIA ELECTRONIC MAIL AND OVERNIGHT MAIL**

Melanie A. Bachman  
Executive Director  
State of Connecticut  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, CT 06051



**Petition No. 1218 – PSEG Power Connecticut LLC  
Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
Monthly Progress Report No. 8 – August 2017**

Dear Ms. Bachman:

This is the August 2017 monthly progress report submittal to the Connecticut Siting Council (CSC) for the new combined cycle generating station designated by PSEG Power Connecticut LLC (PSEG) as the PSEG Bridgeport Harbor Station Unit 5 Combined Cycle Project (BHS 5, the Project or the Facility). This monthly progress report documents compliance with the CSC's conditions as set forth in the CSC Decision and Order, as well as the Development and Management Plan (D&MP) approvals.

A complete and updated CSC Condition Compliance Matrix is included in this report as **Exhibit 1** and will continue to be included in future progress reports to track the CSC's requirements.

**Construction Status Summary**

The project continues on schedule. During August, foundation activities and installation of site fill continued. The barge delivery of fill materials was completed in August and the equipment has been demobilized. All of the rigid inclusions have been installed and approximately 65% of the steel pipe piles have been completed. Underground utility construction, including the stormwater conveyance system, continued. Construction of the stormwater outfall is scheduled to begin in early September. Soil Erosion and Sediment Control installation is complete and is being maintained.

**Remediation Status Summary**

The second phase of remediation at the site is continuing. As noted in prior monthly submittals, the remaining remediation scope includes the placement of an orange geotextile warning fabric over the soils remaining onsite. To date, approximately 85% of the orange warning fabric has been installed. Additionally, the material that will be placed under permanent structures (water and fuel oil tanks), in order to remain inaccessible, is stockpiled on-site and will be placed in its final locations later this year as construction progresses.

**Connecticut Siting Council  
Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
Monthly Progress Report No. 8 – August 2017**

The remediation schedule for the tank farm area has been optimized to reflect actual installation dates for the tank foundations, which serve to physically make the soil inaccessible, and are currently scheduled for construction in January 2018.

The formal documentation addressing all tank farm remediation is scheduled for submittal to the Connecticut Department of Energy and Environmental Protection (CT DEEP) in the first quarter of 2018, after completion of the tank foundations. It should be noted that this work is tracked in both the prior CSC Exempt Modification (EM-PSEG-015-160205) and in Condition 1(f) of this Petition. At the time of closeout, PSEG will assure both of these CSC actions are appropriately addressed. The date for resolution of Condition 1(f) in Exhibit 1 has been revised accordingly.

**Engineering and Regulatory Status Summary**

SNC-Lavalin (SNCL) is continuing with the detailed design for the Project, and major construction and equipment supply contracting remains on schedule. Engineering design and City of Bridgeport Building Permitting activities supporting ongoing site field work are continuing on schedule.

Permit applications for the southern and eastern roll-off unloading (CT DEEP General Permit for Coastal Maintenance and the related United States Army Corps of Engineers (USACE) General Permit for Maintenance Activities) were filed on July 17. On August 18, the USACE approved the General Permit for Maintenance Activities; the CT DEEP approval is pending.

On August 18, an update to PSEG's Individual Permit Application for Wastewater Discharges from Manufacturing, Commercial and Other Activities (i.e. Industrial Wastewater) was provided to the CT DEEP and City of Bridgeport Water Pollution Control Authority. The update included a revised water balance diagram and other minor changes identified during detailed design and water treatment vendor selection. A copy of the update is included as **Exhibit 2**.

**Offsite Fabrication and Barge Delivery of Equipment / Fill**

Delivery of the Heat Recovery Steam Generator (HRSG) and the stack sections to the site remains scheduled for May 2018. The offloading plans have been reviewed with the CT DEEP, USACE, United States Coast Guard, and the City of Bridgeport Harbor Commission / Harbormaster. As referenced above, the USACE General Permit for Maintenance Activities was received this month and the CT DEEP permit to support these activities is anticipated by the end of 2017.

Fill deliveries by barge commenced in early June 2017 at the previously identified eastern location on the site. Approximately 150,000 tons of clean fill were delivered via barge. As noted above, this delivery process was completed during August.

The delivery / off-loading schedule for other large equipment from barges, including the Combustion Turbine, the Steam Turbine, other ancillary power island equipment, and the Air Cooled Condenser components remains on track. The plans call for these deliveries to also use the previously identified eastern locations. Delivery schedules vary by component and are expected to start in late 2017.

**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

Deliveries to the PSEG site through the adjoining Remington property continued. PSEG remains in discussions with the City of Bridgeport to lease additional City-owned storage and laydown areas in the vicinity of the plant and Bridgeport Harbor.

**Construction Schedule Update**

Other than the commencement of initial equipment deliveries to the site this month, there have been no significant changes in the schedule for major activities from the prior reporting period. Equipment deliveries to the site have started.

1.	Forward Capacity Auction No. 10	February 10, 2016 (A)
2.	Completion of City of Bridgeport Land Use Permitting	November 1, 2016 (A)
3.	Completion of Non-Air CT DEEP Permitting	February 2017 (A)
4.	Initial City of Bridgeport Building Permit Submittals	February 2017 (A)
5.	Receipt of CT DEEP Final Air Permit	April 11, 2017 (A)
6.	Initiation of Field Construction Activities	April 12, 2017 (A)
	a. Temporary Construction Facilities	November 2016 (A)
	b. Site Work	April 12, 2017 (A)
	c. Foundations	June 2017 (A)
	d. Initial Equipment Deliveries	August 2017 (A)
	e. Major Equipment Delivery (Turbines, etc.)	November 2017
	f. GIS and Transformer Foundation Installation	June 2017 (A)
	g. Gas Turbine Generator (GTG) Installation	December 2017
	h. HRSG Delivery	May 2018
	i. Start-up Testing and Commissioning	September 2018
7.	Operational Testing (first GTG operations)	November 2018
8.	Balance of Plant Initial Start-up	September 2018
9.	Performance and Reliability Testing	March 2019
10.	Target Completion	April 2019
11.	Commercial Operations	June 2019

Note: "(A)" refers to ACTUAL

**Status of CSC Conditions**

The following changes or updates are provided in the full listing of CSC conditions included as Exhibit 1.

1. The closure date for Condition 1(f) (Remediation) has been revised from October 2017 to March 2018 to reflect the documentation submittal date target for the final remediation reporting to CT DEEP.
2. The status of Condition 1(i) was revised for administrative clarity to include a reference to previously approved D&MP Update No. 1.
3. PSEG will provide information to address Conditions 6(i) through 8(iii) by December 31, 2017 based on the current planning in process to address these conditions appropriately.

**Connecticut Siting Council  
Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
Monthly Progress Report No. 8 – August 2017**

4. PSEG has not determined the specifics of the fuel oil dock repair at this time. As a result, the target date for submittal of information required by Condition 1(d) (which is tracked in Exhibit 1 as Condition 12/23/16-05) has been revised from September 2017 to June 30, 2018.

If you have any questions or require clarification, please contact me at 973-856-0066 or the Project Senior Technical Director / Regulatory Lead, Jeff Pantazes at 856-359-7645.

Very truly yours



David Hinchey, Jr.

Manager Environmental - Major Permits & Technical Services  
PSEG Power LLC  
Fossil Environment, Health, and Safety

**Enclosures - Exhibits:**

1. **Updated CSC Condition Compliance Matrix**
2. **Update to CT DEEP of previously submitted Individual Permit for Wastewater Discharges from Manufacturing, Commercial and Other Activities application dated August 18, 2017**

C Michael Perrone  
Harold Blinderman, Esq.  
Franca L. DeRosa, Esq.  
Leilani M. Holgado, Esq.  
Karl Wintermeyer  
Scott Matheson  
Jeffrey Pantazes  
James R. Morrissey, Esq.

**Connecticut Siting Council  
Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
Monthly Progress Report No. 8 – August 2017**

**Exhibit 1 – Updated CSC Condition Compliance Matrix**

**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

<b>CSC Requirement Number</b>	<b>CSC Requirement</b>	<b>D&amp;M Plan Phase 1 Construction Support Facilities</b>	<b>D&amp;M Plan Phase 2 BHS 5 Design</b>	<b>Subsequent Filing Report and Date Closure Status</b>
1(a)	Final site plan showing roads, structures, and other improvements on the site	Partial: construction execution planning process summary included as Exhibit 1. A general update on Project Scope and Design is included as Exhibit 15.	Final structures and other improvements, including buildings, stack, power block, and balance of plant (Exhibits 1 and 2)	Completed; D&MP Update No. 1 was filed in June 2017 and approved in July 2017.
1(b)	Consideration of waste heat as supply for thermal loop or nearby industrial user	N/A	Included (Exhibit 9)	Completed; see CSC Requirement Number 12/23/16-04 below for follow-up requirements.
1(c)	Lighting plan and details to minimize impact on off-site properties	Partial: construction lighting only – Exhibit 9	Final lighting plans (Exhibits 1 and 2)	Completed
1(d)	Final fuel dock rehabilitation plan	Update on status included as Exhibit 7	Status unchanged since D&MP Phase 1 – PSEG will provide an update of this portion of the project by September 30, 2017 after design is completed. See Exhibit 10.	Completed; see CSC Requirement Number 12/23/16-05 below for follow-up actions.
1(e)	Water and sewer connection routes	Partial: temporary construction sewer line connection and other utilities included in Exhibit 9. Note that the status of the UI Exempt Modification request is included as Exhibit 11.	Permanent utility routing included (Exhibits 1 and 2)	Completed
1(f)	Status of site remediation in existing fuel tank area and remaining remediation work - Which areas of contamination will be inaccessible? - Layer showing contaminated soil locations	Remedial Action Plan Addendum included as Exhibit 6. Status of remediation implementation included as Exhibit 5.  Unit 3 tank and unloader status included as Exhibit 4.	Status for remaining work will be included to document final soil placement locations. (Exhibits 7 and 8)	Open – PSEG will submit final remediation status to the CT DEEP and CSC with a target of March 31, 2018.
1(g)	Natural gas interconnection plan and gas compressor building design and location	N/A	Included (Exhibit 2)	Completed
1(h)	Final Erosion and Sediment Control Plans	Soil Erosion and Sediment Control Plans included in Exhibit 9 as noted in Exhibit 14.  The USACE Jurisdictional Determination is included as Exhibit 13.	SESC plans included in Exhibit 2; they were previously provided in D&MP Phase 1 as well.	Completed

**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

<b>CSC Requirement Number</b>	<b>CSC Requirement</b>	<b>D&amp;M Plan Phase 1 Construction Support Facilities</b>	<b>D&amp;M Plan Phase 2 BHS 5 Design</b>	<b>Subsequent Filing Report and Date Closure Status</b>
1(i)	Final stormwater design	N/A	Included (Exhibit 2)	Completed. D&MP Update No. 1 was filed in June 2017 and approved in July 2017 that included stormwater design revisions.
1(j)	Stormwater Pollution Protection Plan	N/A	Included (Exhibit 15)	Completed
1(k)	Flood Mitigation Plan	N/A	Included (Exhibit 3)	Completed
1(l)	Final plans to demonstrate compliance with CT DEEP noise standards	N/A	Final Noise Study Report Included (Exhibit 14)	Completed
1(m)	Fuel storage and handling plan, including containment and spill protection measures	N/A	Spill Prevention Control and Countermeasures Plan included (Exhibit 18)	Completed
1(n)	Containment measures for step-up transformer dielectric fluids and ULSD storage tank	N/A	Included (Exhibit 3)	Completed
1(o)	Containment and/or protective measures for delivery and storage of hydrogen and aqueous ammonia	N/A	Included (Exhibits 3 and 20)	Completed
1(p)	Backup generator design and containment measures for fuel, oil, and coolant	N/A	Included (Exhibit 3)	Completed: Vendor data included in Exhibit 4 of the May 2017 Monthly Progress Report No. 5
1(q)	Dewatering plan to address groundwater issues during construction	N/A	Stormwater Pollution Control Plan for construction stormwater and dewatering included. (Exhibits 15 and 16)	Completed
1(r)	Detailed project schedules for all work activities and proposed typical construction days and hours	Partial: Schedule update Included as Exhibit 2 and permitting status included as Exhibit 3.	Work hours and schedule update included in Exhibits 3 and 6 respectively.	Completed
1(s)	Construction laydown area locations	Included in Exhibits 8 and 10 including access routings for high trucks.  In addition, the plans for barge delivery of equipment and unloading are included as Exhibit 12.	See Exhibit 3 for an update regarding a lease agreement for an adjoining property	Complete: Submitted information in D&MP Phases 1 and 2 was updated in May 2017 Monthly Progress Report No. 5.
1(t)	Site security measures	Partial: site security for construction discussed in Exhibit 1.	Partial: Site security measures (Exhibit 3)	Completed

**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

<b>CSC Requirement Number</b>	<b>CSC Requirement</b>	<b>D&amp;M Plan Phase 1 Construction Support Facilities</b>	<b>D&amp;M Plan Phase 2 BHS 5 Design</b>	<b>Subsequent Filing Report and Date Closure Status</b>
1(u)	Final FAA lighting design for the stack and any FAA crane determinations	N/A	Included (Exhibit 3)	Completed
1(v)	Decommissioning Plan as contingency plan, including infrastructure removal and site restoration plans	N/A	Included (Exhibit 19)	Completed
2	Submit FAA Determinations for temporary structures (cranes) and stack	N/A	N/A	Completed April 11, 2017 via memorandum to the CSC.
3	Submit local permits relative to the discharge of wastewater	N/A	N/A	Completed April 11, 2017 via memorandum to the CSC.
4	Submit final CT DEEP air emissions and water discharge permits	N/A	N/A	Completed April 11, 2017 via memorandum to the CSC.
5	The use of natural gas as a fuel pipeline / system cleaning medium for construction or any future facility modification shall be prohibited.	N/A	N/A	PSEG notes this condition and will retain it as "Open". The provisions of CSC Requirement Number 6 (below) address the specifics of compliance.
6	Submit the information included below in CSC requirement Numbers 6(i) to 6(viii) at least 15 days prior to fuel pipeline / system cleaning medium for construction or any future facility modification.*	N/A	N/A	Open – an update response to all of the Condition 6 (i) to (viii) through 8(iii) will be provided by December 31, 2017
6(i)*	Identification of cleaning media to be used	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
6(ii)*	Identification of any known hazards through use of selected cleaning media	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
6(iii)*	Description of how known hazards will be mitigated, including applicable state or federal regulations	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
6(iv)*	Identification and description of accepted industry practices or relevant regulations concerning proper use of such media	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.



**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

CSC Requirement Number	CSC Requirement	D&M Plan Phase 1 Construction Support Facilities	D&M Plan Phase 2 BHS 5 Design	Subsequent Filing Report and Date Closure Status
6(v)*	Detailed narratives/drawings showing location and procedures to be used during pipe cleaning process, including worker safety exclusion zones	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
6(vi)*	Identification of contractor or personnel performing work, including description of past project experience and level of training/qualifications necessary for work	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
6(vii)*	Contact information for special inspector (CT registered engineer with knowledge or experience with electric generating facilities) with written approval by local fire marshal and building inspector	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
6(viii)*	Certification of notice regarding pipe cleaning operations (Submitted to all state agencies listed in CGS §16-50j(g), Dept of Consumer Protection, Dept of Labor, Dept of Emergency Services and Public Protection, Dept of Construction Services, Dept of Emergency Management and Homeland Security, and local fire marshal)	N/A	Not currently available. An update will be provided one month prior to the start date for pipe cleaning.	Open - An update will be provided by December 31, 2017 regarding the anticipated schedule.
7	Compliance with specific codes and standards for any fuel pipeline / system cleaning operations related to construction or any future facility modification, as applicable. (Note: the Codes and Standards are listed in the Decision and Order)	N/A	N/A	PSEG notes this condition and will retain it as "Open". The provisions of CSC Requirement Number 6 (above) address the specifics of compliance.
8(i)†	Description of results of simulated emergency response activities	N/A	Not currently available.	Open - a status to all of the Condition 6 (i) through 8(iii) will be provided by December 31, 2017

**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

<b>CSC Requirement Number</b>	<b>CSC Requirement</b>	<b>D&amp;M Plan Phase 1 Construction Support Facilities</b>	<b>D&amp;M Plan Phase 2 BHS 5 Design</b>	<b>Subsequent Filing Report and Date Closure Status</b>
8(ii)†	Details of any facility site access system that accounts for all personnel entering and leaving the facility	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
8(iii)†	Establishment of emergency responder/local community notification system for onsite emergencies and planned construction-related activities	N/A	Not currently available.	Open - An update will be provided by December 31, 2017.
9	Unless otherwise approved by the Council, the facility must be constructed within five years of July 22, 2016 (by July 21, 2021) or re-approval by the Council is required.	N/A	N/A	Open: PSEG anticipates completion of BHS 5 by June 1, 2019.
10	Notify the Council within 45 days of the completion of construction.	N/A	N/A	Open
11	Maintain the facility in a reasonable physical and operational condition consistent with the Decision and Order and the approved D&MPs.	N/A	N/A	Noted
12	Provide the Council with a minimum of 30 days written notice when the facility will cease operations.	N/A	N/A	Noted
13	Remit timely payments associated with annual assessments and invoices submitted by the Council.	N/A	N/A	Noted
14	Notify the Council of any change in ownership or contact information within 30 days of the sale and / or transfer.	N/A	N/A	Noted
15	Submit any request for extension as noted in CSC Requirement Number 9 (above) not later than 60 days prior to the expiration, including notice to specific parties and the service list.	N/A	N/A	Noted

**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

<b>CSC Requirement Number</b>	<b>CSC Requirement</b>	<b>D&amp;M Plan Phase 1 Construction Support Facilities</b>	<b>D&amp;M Plan Phase 2 BHS 5 Design</b>	<b>Subsequent Filing Report and Date Closure Status</b>
16	The Declaratory Ruling may be transferred subject to being current with payments and an agreement to continue payments as required.	N/A	N/A	Noted
17	Retain a Special Inspector to assist the Fire Marshall to assure compliance with CGS §16-50ii	N/A	N/A	Noted. This will be addressed in the response to CSC Requirement Number 6(vii). An update will be provided by December 31, 2017.
18	Deposit a fee into the Code Training Fund in accordance with CGS § 29-251c.	N/A	N/A	Open. PSEG will work with the City of Bridgeport to establish the timing and amount of the subject fee. This will be addressed in a future Monthly Progress Report prior to the completion of the project.
	<b>D&amp;MP Phase 1 Conditions</b>			
10/31/16-01	Use of off-road construction equipment that meet the latest EPA or California Air Resources Board standards, or in the alternative, equipment with the best available controls on diesel emissions, including but not limited to retrofitting with diesel oxidation catalysts, particulate filters and use of ultra-low sulfur fuel.			Completed: February 2017 Monthly Progress Report.
10/31/16-02	Compliance with the provisions of Section 22a-174-18(b)(3)(C) of the RCSA that limit the idling of mobile sources to 3 minutes.			Completed: February 2017 Monthly Progress Report.
10/31/16-03	The petitioner shall submit the specifications of the fill to the Council			Completed; December 2, 2016 response to Interrogatory CSC D&M-05.
	<b>D&amp;MP Phase 2 Conditions</b>			
12/23/16-01	Same as 10/31/16-01 above			Completed: February 2017 Monthly Progress Report.

**Connecticut Siting Council  
 Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
 Monthly Progress Report No. 8 – August 2017**

CSC Requirement Number	CSC Requirement	D&M Plan Phase 1 Construction Support Facilities	D&M Plan Phase 2 BHS 5 Design	Subsequent Filing Report and Date Closure Status
12/23/16-02	Same as 10/31/2016-02 above			Completed: February 2017 Monthly Progress Report.
12/23/16-03	Compliance with the reporting requirements under Section 16-50j-62 of the RCSA			Ongoing Reporting to continue
12/23/16-04	The final modifications of the plant to accommodate the use of waste heat, if applicable, shall be submitted to the Council for review and approval.			PSEG will provide an update by January 31, 2018.
12/23/16-05	The final fuel dock rehabilitation plan shall be submitted to the Council for review and approval.			PSEG will provide an update by June 30, 2018.
12/23/16-06	The containment measures for the backup generator engine oil and coolant shall be submitted to the Council.			Completed: Vendor data included in Exhibit 4 of the May 2017 Monthly Progress Report No. 5
12/23/16-07	Prior to testing of start-up of the plant, the Certificate Holder shall submit to the council its final plans to comply with the recommendation and conditions relative to Council Docket No. NT-2010 and conditions (6i through 8iii) Council's Decision and Order for Petition No. 1218 relative to plant safety.			PSEG will provide an update by December 31, 2017 as noted in CSC Requirement Numbers 6(i) to 8(iii) above.
12/23/16-undesignated	The Council recommends that PSEG consult with Council staff regarding dust control measures for materials delivered by barge.			Completed: June 2017 Monthly Progress Report.
* 15 days prior to fuel pipeline/system cleaning operations related to construction or any future facility modifications				
† Submittal of Emergency Response/Safety Plan developed in cooperation with all local public safety officials, DESPP, and other emergency response officials				

**Connecticut Siting Council  
Bridgeport Harbor Station Unit 5 – Bridgeport, Connecticut  
Monthly Progress Report No. 8 – August 2017**

**Exhibit 2 - Update to CT DEEP of previously submitted Individual Permit for Wastewater Discharges from Manufacturing, Commercial and Other Activities application dated August 18, 2017**



**Environmental, Planning, and Engineering Consultants**

307 Fellowship Road  
Suite 214  
Mt. Laurel, NJ 08054  
tel: 856 797-9930  
fax: 856 797-9932  
[www.akrf.com](http://www.akrf.com)

## Memorandum

---

**To:** Peter Ploch / Mariana Miller (via email and hardcopy)  
CT DEEP

**From:** Jeffrey Pantazes

**Date:** August 18, 2017

**Re:** **Individual Sewer Discharge Permit Application Update**  
**PSEG Power Connecticut LLC - Bridgeport Harbor Station Unit 5**  
**1 Atlantic Street, Bridgeport, Connecticut**  
**Application No. 201614170**

**cc:** Ravi Keerthy (WPCA), Scott Matheson (PSEG), David Hinchey (PSEG),  
Mark Woloski (PSEG), Karl Wintermeyer (PSEG), David Schafer (AKRF)

---

On behalf of PSEG Power Connecticut LLC (PSEG), AKRF is providing the attached update to the Individual Permit Application for Wastewater Discharges from Manufacturing, Commercial, and Other Activities originally submitted to the Connecticut Department of Energy and Environmental Protection (CT DEEP) on October 28, 2017 for PSEGs proposed discharge of sanitary and process wastewater from the Bridgeport Harbor Station Unit 5. The plant is currently under construction.

This update primarily addresses minor refinements to the Project's water balance diagrams developed during final design. Additionally, minor revisions to facility equipment (such as oil/water separator sizing) and changes in chemicals due to vendor selection are included.


The following updated sections/pages of the application are included for your review:

- Updated Application Form sheet (Part III) identifying the current Project Design Engineer's Contact Information;
- Updated Application Form sheet (Part V), Project Description, Appendix 1 to address the updated water balance for the Facility;
- Appendix 2 was updated to include Safety Data Sheets (SDS) associated with selection of an alternative chemical vendor (Note the SDS documentation is provided in hardcopy only due to file size.);
- Updated Attachment A, Executive Summary Form; and,

- Updated Attachments
  - Attachment I (oil/water separator sizing);
  - Attachment M (water balances);
  - Attachment N (oil/water separator sizing); and.
  - Attachment O final water tank volumes, treatment chemicals, and water balance information.

This update package is consistent with the Instructions for Completing the Permit Application for Wastewater Discharges from Manufacturing, Commercial, or Other Activities (DEEP-WPED-INST-100). Should you have any questions concerning facility wastewater discharge needs, please feel free to contact me (609-440-0236 / [jpantazes@akrf.com](mailto:jpantazes@akrf.com)) or Dave Schafer (978-758-1554 / [dschafer@akrf.com](mailto:dschafer@akrf.com)).

We appreciate your review of the enclosed documents. We will be in touch over the next few weeks to schedule a phone or in person discussion to address any questions you may have.



---

Jeffrey Pantazes

Senior Technical Director / Senior Consultant

Attachment – Updated application sections

Hard Copy to follow

**Permit Application for Wastewater Discharges from  
Manufacturing, Commercial, and Other Activities**

**Bridgeport Harbor Station Unit 5 Combined Cycle Project  
1 Atlantic Street  
City of Bridgeport, Fairfield County, Connecticut**

**Submitted to:**

**Connecticut Department of Energy and Environmental Protection**

**Prepared for:**

**PSEG Power Connecticut LLC  
1 Atlantic Street  
Bridgeport, CT 06604**

**Prepared by:**

**AKRF Inc.  
307 Fellowship Road, Suite 214  
Mount Laurel, NJ 08054**

**Updated August 2017**



## TABLE OF CONTENTS

### APPLICATION FORM

### WATSEWER DISCHARGE PERMIT APPLICATION CHECKLIST

<b>1.0</b>	<b>PROJECT DESCRIPTION .....</b>	<b>1</b>
1.1	Project Overview.....	1
1.2	Facility Description.....	1
<b>2.0</b>	<b>PROCESS AND POTABLE WATER MAKEUP REQUIREMENTS .....</b>	<b>6</b>
<b>3.0</b>	<b>WASTEWATER GENERATION .....</b>	<b>9</b>
3.1	Sanitary Wastewater.....	9
3.2	On-site Water Treatment (Demineralization System) Wastewater.....	10
3.3	Combustion Turbine (CT) Inlet Air Cooler .....	10
3.4	Off-line Compressor Wash Water.....	11
3.5	Floor Drains (Equipment Drains/Plant Maintenance Wastewater).....	11
3.6	HRSG and Auxiliary Boiler Blowdown.....	11
3.7	Auxiliary Cooling Tower Blowdown.....	12
<b>4.0</b>	<b>WATER CONDITIONING PROGRAM .....</b>	<b>13</b>
4.1	RO Treatment Train .....	13
4.2	Heat Recovery Steam Generator (HRSG).....	13
4.2.1	Condensate/Feedwater .....	13
4.2.2	Boiler Water.....	15
4.3	Selective Catalytic Reduction (SCR) .....	15
4.4	Auxiliary Boiler.....	15
4.5	Auxiliary Cooling Tower .....	15
<b>5.0</b>	<b>COMPLIANCE WITH EFFLUENT LIMITATIONS.....</b>	<b>17</b>
5.1	Metering and Compliance Monitoring.....	17
5.2	Compliance with Pretreatment Standards for New Sources (PSNS).....	17
5.2.1	PCBs .....	17
5.2.2	Chemical Metal Cleaning Wastes.....	18
5.2.3	Auxiliary Cooling Tower Blowdown .....	18
5.2.4	Fly Ash Transport Water .....	21
5.2.5	FGD Wastewater.....	22
5.2.6	Flue Gas Mercury Control Wastewater .....	22
5.2.7	Bottom Ash Transport Water.....	22
5.2.8	Gasification Wastewater .....	22
5.2.9	Combustion Residuals Leachate .....	22
5.3	Summary .....	23

**LIST OF FIGURES**

Figure 1: Site Location Map ..... 3  
Figure 2: Aerial Photo..... 4  
Figure 3: General Arrangement Plan ..... 5  
Figure 4: Water Balance Diagram .....7

**LIST OF TABLES**

Table 1: Water Balance Table..... 8  
Table 2: Water Conditioning Program.....14  
Table 3: PSNS Criteria for Chemical Metal Cleaning Wastes .....18  
Table 4: Discharge Point: DSN 201 - Conventional Constituents .....19  
Table 5: Discharge Point: DSN201 - Heavy Metals<sup>1</sup> ..... 20  
Table 6: PSNS Criteria for Cooling Tower Blowdown .....21

**APPENDICIES**

- Appendix 1: Water Balance Diagrams
- Appendix 2: Safety Data Sheets

**ATTACHMENTS**

- Attachment AA: Notice of Permit Application
- Attachment A: Executive Summary
- Attachment B: Applicant Background Information
- Attachment C: Applicant Compliance Information Form
- Attachment D: USGS Map
- Attachment E: Coastal Consistency Review Form
- Attachment F: Connecticut NDDDB Information
- Attachment I-1: Site Plans and Floor Plans
- Attachment I: Operation and Maintenance of Collection and Treatment Systems
- Attachment K: Spill Prevention and Control Plan
- Attachment L: Resource Conservation Strategies
- Attachment M: Line Drawing and Process Flow Diagram
- Attachment N: Description and Plans and Specifications of the Collection, Treatment and Disposal Systems
- Attachment O: Discharge Information

**Part V: Facility or Activity Information (continued)**

4. Inventory of toxic and hazardous substances and oil or petroleum liquids (please see instructions)

Check here if additional sheets are necessary. If so, please reproduce this sheet and attach copies to this sheet.

Name of toxic or hazardous substance or oil	Use of toxic or hazardous substance and maximum quantity used per day	If stored on-site, indicate maximum quantity of stored substance	TRI pollutant yes or no
Lube Oil/Hydraulic Fluid	NA	7,400 gal	Yes
Sodium Hypochlorite	1.43 gal/hr	1,600 gal	Yes
Sulfuric Acid	0.1 gal/hr	1,600 gal	Yes
Corrosion Inhibitor	0.13 gal/hr	1,600 gal	Yes
Antiscalant	0.09 gal/hr	1,600 gal	Yes
Aqueous Ammonia	3.25 gal/hr	1,200 gal	Yes
Filming Amine	3.25 gal/hr	1,200 gal	Yes
Trisodium Phosphate	3.4 gal/hr	1,200 gal	Yes
Sodium Bisulfite	0.25 gal/hr	1,200 gal	Yes
Antiscalant	0.5 gal/hr	1,200 gal	Yes
Sodium Hydroxide	0.5 gal/hr	1,200 gal	Yes
Polyphosphoric Acid	0.36 gal/hr	800 gal	Yes
Aqueous Ammonia	0.12 gal/hr	400 gal	Yes
Aqueous Ammonia	174 gal/hr	20,000 gal	Yes

**Item 8. List any engineer(s) or other consultant(s) employed or retained to assist in preparing the application or in designing or constructing the facility (Continued)**

**Name:** SNC-Lavalin

**Mailing Address:** 19015 North Creek Parkway, Suite 300

**City/Town:** Bothell

**State:** WA    **Zip Code:** 98011

**Business Phone:** 425-489-8000

**ext:**

**Contact Person:** Ms. Wendy Wong

**Phone:** 425-489-7610

**E-mail:** Wendy.Wong@snclavalin.com

**Service Provided:** Water Supply/Wastewater Discharge Engineering Design Support Services

## **1.0 PROJECT DESCRIPTION**

---

### **1.1 PROJECT OVERVIEW**

PSEG Power Connecticut LLC (PSEG) is developing a nominal 485 megawatt (MW) gas turbine combined cycle electric generating facility, known as Bridgeport Harbor Station Unit 5 (BHS Unit 5), at PSEG's Bridgeport Harbor Station located in the City of Bridgeport, Fairfield County, Connecticut. The site is located at 1 Atlantic Street as shown on the site location map included as Figure 1. The general station boundaries, existing site conditions, and adjacent developments are shown in greater detail in the site aerial included as Figure 2.

### **1.2 FACILITY DESCRIPTION**


Bridgeport Harbor Station is owned and operated by PSEG. It has been in operation as an electric generating station since August 1957. The station was previously owned by Wisvest-Connecticut, LLC from April 16, 1999 through December 5, 2002, and the United Illuminating Company prior to 1999. The Station encompasses approximately 59.8 acres of land along the western shoreline of Bridgeport Harbor in Bridgeport, Connecticut.

Currently, electricity is generated in an approximately 400 megawatt (MW) (summer rating) coal / oil fired unit (Unit 3) and a 20 MW combustion turbine (Unit 4). Additionally, there is an 84.7 MW oil-fired unit (Unit 1) and a 170 MW oil-fired unit (Unit 2), which are now retired.

The new combined cycle facility (BHS Unit 5) will be located at the southern end of the site encompassing the existing fuel oil tank farm area. A general arrangement plan for BHS Unit 5 is shown in Figure 3. The new power block will consist of one combustion turbine generator set, a heat recovery steam generator ("HRSG") and a steam turbine generator set. Ancillary equipment at the facility will include an air cooled condenser ("ACC") for steam cycle cooling, a process makeup water demineralization system, a small mechanical draft cooling tower for ancillary cooling (i.e., an auxiliary cooling tower), a 950,000 gallon service/fire water storage tank, a 1,000,000 gallon demineralized water storage tank, a 5.5 million gallon ultra-low sulfur distillate (ULSD) fuel oil storage tank, and an auxiliary boiler.

The combined cycle facility will primarily use natural gas as the fuel. However, to enhance electric system reliability, BHS Unit 5 is designed as a dual fuel facility that can also use ULSD as a backup fuel. Other than for periodic testing, PSEG anticipates that ULSD primarily would be used during unusually

10/22/2015



- Approximate Area of Development
- Project Site Property Boundary
- 1/2-Mile Study Area

0 2,000 FEET

USGS 7.5 Minute Topographic Map  
 Bridgeport Quad  
 Figure 1

**BRIDGEPORT HARBOR STATION - Combined Cycle Project**

10/23/2015



- Approximate Area of Development
- Project Site Property Boundary
- 1/2-Mile Study Area

0  4,000 FEET

**BRIDGEPORT HARBOR STATION - Combined Cycle Project**

Site Location Aerial  
Figure 2





cold winter operating conditions, if necessary. ULSD is permitted for use for up to 720 hours at full load per year.

BHS Unit 5 will ultimately replace the electric generating capabilities of the Station's Unit 3, which is expected to be retired on July 1, 2021. As indicated above, the Station's former Units 1 and 2 have previously been retired. Because BHS Unit 5 will utilize an air cooled condenser for steam cycle cooling rather than rely on once-through or evaporative cooling technologies, following retirement of Unit 3 the Station will no longer require operation of a once-through condenser cooling water system.

## **2.0 PROCESS AND POTABLE WATER MAKEUP REQUIREMENTS**

Water is required for several functions associated with the clean and efficient operation of BHS Unit 5. Process water is needed for steam cycle makeup (i.e., heat recovery steam generator or HRSG makeup), auxiliary cooling tower makeup, plant maintenance, inlet air-cooling, compressor cleaning, and air pollution control (i.e., NO<sub>x</sub> injection water when firing ULSD). It is also required to meet the facility's potable water needs. Potable and process makeup needs will be satisfied through withdrawals from the municipal distribution system, which is owned and operated by Aquarion Water Company (Aquarion). Aquarion has provided a "Will Serve" letter to the Project, confirming its ability to satisfy facility water demands.

A facility water balance diagram is provided in Figure 4 with corresponding flows for various operating conditions listed in Table 1. Figure 4 illustrates, in schematic form, the principal water supply and wastewater discharge pathways through the facility. Process flows listed in Table 1, shown in units of gallons per minute (gpm), reflect facility operation under various operating conditions when firing natural gas as well as when the facility would use the backup fuel, ULSD. Figure 4 also illustrates how internal recycle and reuse of process wastewater is incorporated throughout the facility to improve overall water efficiency and reduce process wastewater discharge requirements.

When using natural gas as the fuel, projected average daily water supply needs for BHS Unit 5 are expected to range from approximately 120 gallons per minute (gpm) to 170 gpm. This estimate assumes that the facility is operating at 100% capacity (i.e., under full load conditions). When ULSD is used, water needs are expected to total approximately 620 gpm at full load, as additional water is required for air pollution control purposes (i.e., water injection for controlling nitrous oxide [NO<sub>x</sub>] emissions). PSEG anticipates that ULSD will primarily be used during extreme winter operating conditions when natural gas supplies are prioritized to satisfy winter heating demands (i.e., during natural gas curtailments). Historically, natural gas curtailments have occurred in the Northeast during unusually cold winter conditions, such as when average daily temperatures remain below 15° F for several days.


**GENERAL NOTES:**

1. THE INTENT OF THIS DIAGRAM IS TO SHOW THE MAJOR WATER AND WASTEWATER FLOWS.
2. REFER TO 6449311-F0002-S002 FOR STREAM FLOW DATA.
3. DASHED LINES REPRESENT INTERMITTENT FLOWS.

**Figure 4**

ISSUED FOR CONSTRUCTION	DATE	BY
ISSUED FOR APPROVAL	DATE	BY
ISSUED FOR APPROVAL	DATE	BY

PROJECT ENGINEERING DIVISION  
**PSEC**  
 SNC-LAVALIN CONSTRUCTORS INC.  
 BRIDGEPORT 05  
 PROCESS FLOW DIAGRAM  
 WATER SYSTEM  
 LOW DUCHEM  
 WATER BALANCE  
 SPT. 1 OF 5  
 MECHANICAL PIPING  
 6449311-F0002-S001



A B C D E F

1

2

3

4

5

A

B

C

D

E

F

Table 1: Bridgeport Unit 5 Water Balance

Stream no.	Description	Units	Low Ambient Case		CASE 1		CASE 2		CASE 3		CASE 4		CASE 5		CASE 6		Remarks
			USLD, EC, DT, DF ON, 100% GT load	0 F	NG, EC ON, DF ON, 100% GT load	59 F / 60% RH	NG, EC ON, DF ON, 100% GT load	90 F / 70% RH	USLD, EC, DT, DF ON, 100% GT load	35 F / 50% RH	NG, EC ON, DF ON, 100% GT load	90 F / 70% RH	USLD, EC, DT, DF ON, 100% GT load	35 F / 50% RH	NG, EC ON, DF ON, 100% GT load	59 F / 60% RH	
	HRSG & Heat balance Case no.		55 & CCA20146		Case 1 (HRSG) & Heat balance CCA20095	Case 2 (HRSG performance) & Heat balance CCA20081	Case 3 (HRSG) & Heat balance CCA20139	Case 4 (HRSG) & Heat balance CCA20081	Case 5 (HRSG) & Heat balance CCA20004	Case 6 (HRSG) & Heat balance CCA20138							
1	City water supply	gpm	586		120	169	619	169	143	624							
2	Portable water network	gpm	2		2	2	2	2	2	2							
3	Supply to Service/Re water tank	gpm	594		118	167	617	167	141	622							
4	Service water demand	gpm	619		118	167	617	167	141	622							
5	Service water makeup to CT makeup	gpm	8		64	79	31	79	59	32							
6	Service water for misc uses	gpm	10		10	10	10	10	10	10							
7	Supply to CTG evap cooler	gpm	0		0	23	0	23	0	0							
8	Total steam rate	lb/h	1,072,600		821,700	1,032,100	812,500	1,026,000	982,100	1,002,500							
9	Boiler makeup	gpm	38		28	36	28	36	35	35							
10	Nox Water	gpm	493		0	0	509	0	0	509							
11	Total demin water	gpm	531		29	36	537	36	35	544							
12	Leased RODI trailers, permeate	gpm	300		29	36	300	36	35	300							
13	Supplement DI trailer, min flow	gpm	231		0	0	237	0	0	244							
14	Leased RODI trailers, feed	gpm	353		34	42	353	42	41	353							
15	Supplement DI trailer, feed	gpm	237		0	0	244	0	0	251							
16	Water pretreatment backwash	gpm	1		1	1	1	1	1	1							
17	Total supply to water treatment	gpm	591		35	43	598	43	42	598							
18	CT evaporation	gpm	46		86	105	68	105	88	68							
19	CT Cycles of concentration	-	3.5		8.5	7	4.5	7	7	4.3							
20	CT Drift	gpm	0.1		0.1	0.1	0.1	0.1	0.1	0.1							
21	CTG evap cooler evaporation	gpm	0		0	19	0	19	0	17							
22	Misc. losses from tws cycle	gpm	11.8		8	11.2	7.9	11.1	10.6	10.7							
23	HRSG blowdown	gpm	13		16	21	16	21	20	20							
24	Blowdown, after flashing	gpm	10		10	12	10	12	12	12							
25	Quench water, gpm	gpm	10		9	11	9	11	11	11							
26	To blowdown sump	gpm	23		19	24	19	24	23	23							
27	Fire water system	gpm	0		0	0	0	0	0	0							
28	Demin water to CTG water wash	gpm	0		0	0	0	0	0	0							
29	City water to ACC fin tube cleaning	gpm	0		0	0	0	0	0	0							
30	Demin water to chemical dilution	gpm	0		0	0	0	0	0	0							
31	Non oily wastewater	gpm	5		5	5	5	5	5	5							
32	Condensate polisher backwash	gpm	0.3		0.3	0.3	0.3	0.3	0.3	0.3							
33	sample panel drains	gpm	4		4	4	4	4	4	4							
34	RO reject	gpm	53		5	6	53	6	6	53							
35	Evaporative cooler blowdown	gpm	0		0	4	0	4	3	0							
36	Recycle to CT basin from BD sump	gpm	0		28	37	0	37	35	0							
37	To cartridge filters	gpm	32		0	0	28	0	0	0							
38	Recycle water sump	gpm	4		0	0	4	0	0	0							
39	Recycle to S/F water tank	gpm	32		0	0	28	0	0	0							
40	Oily wastewater	gpm	5		5	5	5	5	5	5							
41	CT blowdown	gpm	18		11	18	19	18	14	21							
42	CT blowdown, oily w/w and filter backwash	gpm	24		17	24	25	24	20	27							
43	Sanitary wastewater	gpm	2		2	2	2	2	2	2							
44	Total wastewater	gpm	26.4		19.5	25.5	27.4	25.5	22.3	28.6							
45	Waste water recycle to service/Re water tank	gpm	2.9		0	0	2.9	0	0	2.9							

NOTE 1 Indicated flow rates may not balance due to rounding.

NOTE 2 Quenched blowdown temperature equal or less than 140 degree F.

NOTE 3 Assumes 85% RO recovery.

NOTE 4 Based on 6 cycles of concentration.

### **3.0 WASTEWATER GENERATION**

---

The low volume waste streams generated by the facility include:

- Sanitary wastewater;
- On-site water treatment wastewater;
- Evaporative cooler blowdown;
- Off-line compressor wash water;
- Plant maintenance water collected in facility floor drains;
- HRSG blowdown;
- Auxiliary boiler blowdown; and,
- Auxiliary cooling tower blowdown.

As shown on the water balance diagram, most of the process waste streams generated at the facility will be reused as auxiliary cooling tower makeup. Discharge of process wastewater to the sanitary collection system will consist primarily of cooling tower blowdown and treated effluent from oil/water separators (i.e., Outfall DSN 201). Sanitary wastewater from BHS Unit 5 will be collected and combined with process wastewater and discharged into the City of Bridgeport's collection system near the intersection of Railroad Avenue and Main Street through a new force main. The new force main extends in a northerly direction through the BHS property to Ferry Access Road, then westerly along Ferry Access Road to the intersection of Railroad Avenue and Main Street. At the discharge point, the collection system consists of a 60-inch gravity main, which conveys wastewater to the City's West Side Water Pollution Control Facility (WPCF).

The water conditioning program for various pieces of equipment is summarized in Section 4. Section 5 addresses compliance with applicable effluent guidelines, limitations and monitoring requirements.

#### **3.1 SANITARY WASTEWATER**

Sanitary wastewater will be collected and conveyed to one of two packaged wastewater pumping stations via gravity flow. It will discharge with process wastewater into the City's collection system. The facility is anticipated to employ approximately 25 people over three shifts. The average daily sanitary wastewater generation rate is expected to be approximately 2 gpm or 2880 gallons per day (gpd).

### **3.2 ON-SITE WATER TREATMENT (DEMINERALIZATION SYSTEM) WASTEWATER**

High purity demineralized water is required for HRSG makeup (i.e., boiler makeup), auxiliary boiler makeup, periodic combustion turbine washes and to control air emissions when firing ULSD. A demineralization system will be used to purify water from the municipal distribution system. When firing natural gas as the fuel, demineralization will be accomplished using reverse osmosis (RO) followed by ion exchange. A sand filter will be installed ahead of the RO system to remove suspended sediment. Backwash water from the sand filter will be directed to the General Services Sump. Residual chlorine, which can degrade RO membranes, will be removed using sodium bisulfite addition. Makeup water to the RO system will typically range from 35 gpm to 50 gpm when firing natural gas under full load conditions. When firing ULSD as the fuel, demineralization will be accomplished using RO and supplemented through use of leased ion exchange trailers. Demineralized water makeup requirements will be approximately 590 gpm when firing ULSD. The leased trailer mounted ion exchange resins will be regenerated off-site by the selected vendor.

Wastewater from the RO system (RO reject water) is expected to range from 5 to 10 gpm when firing natural gas as the fuel and up to approximately 55 gpm when firing ULSD. RO reject water will be reused as auxiliary cooling tower makeup. The constituents in RO reject water, which will consist of the naturally occurring dissolved salts and minerals contained in the municipal distribution system, will have a concentration approximately seven (7) times the municipal water concentration.

As indicated above, the ion exchange resins will be regenerated off-site by the selected vendor. Initial rinse water (i.e., when new ion exchange resin beds arrive on-site) will be recycled to the service/fire water tank. Drain down water (i.e., when emptying the beds prior to off-site transport) will be reused as auxiliary cooling tower makeup. (Initial rinse water and drain down water is not anticipated to meet the stringent demineralized process water makeup requirements for use in the HRSG or combustion turbine.)

### **3.3 COMBUSTION TURBINE (CT) INLET AIR COOLER**

The CT will be equipped with an inlet air cooler (i.e., evaporative cooler) to cool the inlet air stream, thereby increasing inlet air density and CT output. The inlet air cooler can be used at an ambient air temperature above 40° F, but is most effective when ambient air temperature is greater than approximately 60° F. Makeup water to the inlet air cooler will be from the service/fire water storage tank. When on, makeup requirements are estimated to range from approximately 20 gpm to 25 gpm under peak summer operating conditions (i.e., when ambient air temperature approaches or exceeds 90° F).

Blowdown from the inlet air cooler will be routed to the HRSG blowdown sump to offset cooling tower makeup requirements. Evaporative cooler blowdown also contains the naturally occurring dissolved salts and minerals contained in the municipal water, but at a concentration roughly 6 times the municipal water concentration (i.e., the concentration in the municipal distribution system) due to evaporative water loss.

### **3.4 OFF-LINE COMPRESSOR WASH WATER**

The compressor serving the CT requires periodic cleaning to maintain operating efficiency and prevent excessive wear and tear on internal components. Compressor cleaning can be performed when the CT is on-line or off-line. Off-line washes are generally performed on a monthly or quarterly basis. An off-line compressor wash consists of injecting a demineralized water/detergent mixture into the compressor when the combustion turbine is off-line. The mixture is used to remove accumulated dust, dirt or other contaminants that cannot be removed during an on-line wash. In general, the cleaning solution will consist of approximately 25 percent detergent and 75 percent demineralized water. The resultant wastewater will be collected in the false start drain tank and trucked for off-site processing at an appropriately licensed facility.

On-line washes do not generate wastewater, as demineralized water injected into the CT during an on-line wash is lost to the atmosphere through evaporation.

### **3.5 FLOOR DRAINS (EQUIPMENT DRAINS/PLANT MAINTENANCE WASTEWATER)**

Floor drains located in potentially oily areas of the facility will be routed through oil/water separators. Water processed through the oil water separators will be discharged to the General Services Sump. Accumulated oil and sediment will be periodically trucked offsite and properly disposed at an appropriately licensed facility. Equipment drains from non-oily areas will be routed to the wastewater collection sump for reuse as auxiliary cooling tower makeup, as needed.

### **3.6 HRSG AND AUXILIARY BOILER BLOWDOWN**

HRSG and auxiliary boiler blowdown will be quenched (i.e., cooled) and reused in the auxiliary cooling tower to offset cooling tower makeup requirements or recycled as process makeup water to the service/fire water storage tank. Quenched blowdown will be collected in the HRSG blowdown sump prior to reuse. When firing ULSD, quenched HRSG blowdown will be routed to a cartridge filter and returned to the service/fire water storage tank for reuse as process makeup water.

Sample drains, which are used to monitor steam cycle chemistry, and condensate polisher backwash water will discharge to the wastewater collection sump for reuse as auxiliary cooling tower makeup, as needed.

### **3.7 AUXILIARY COOLING TOWER BLOWDOWN**

When operating on natural gas, auxiliary cooling tower blowdown represents the primary waste stream requiring offsite disposal. The blowdown rate will vary depending on the allowable cycles of concentration required to control scale formation and prevent excessive corrosion. Review of water quality data from the municipal distribution system (i.e., operated by Aquarion Water Co.) and projected water quality characteristics from internal reuse streams indicates that the auxiliary cooling tower would typically operate at from seven (7) to nine (9) cycles of concentration when firing natural gas and at approximately 4.5 cycles of concentration when firing ULSD. The resulting blowdown will consist primarily of the naturally occurring dissolved salts and minerals present in the municipal water supply, but at concentrations approximately seven (7) to nine (9) times those of constituents in the auxiliary cooling tower makeup water due to evaporative water loss. Blowdown rates are anticipated to range from approximately 10 gpm to 20 gpm under routine operating conditions.

During periodic maintenance outages requiring draining of the auxiliary cooling tower, drain down water from the auxiliary cooling tower and circulating water system will be directed to the General Service Sump for discharge to the sewer. When this occurs, the maximum instantaneous discharge rate to the sewer will be approximately 150 gpm over a two hour period. The total volume of the auxiliary cooling tower and circulating water system ranges between 9,000 and 13,500 gallons. Note that the auxiliary cooling tower and circulating water system can only be drained when the facility is offline (i.e., during a plant maintenance outage).



## **4.0 WATER CONDITIONING PROGRAM**

---

---

Maintaining proper water chemistry is critical to proper functioning and long term maintenance of the steam cycle, auxiliary cooling tower, circulating water system (i.e., piping and heat exchangers), and the RO treatment train. Table 2 identifies the types of chemicals, dosing rates and storage containers that are routinely used at combined cycle generating facilities for this purpose. Representative Safety Data Sheets for the proposed water conditioning program are included in Appendix 2.

Note that there are several potential water treatment/chemical vendors that can be selected to satisfy the water conditioning needs for the facility. As such, adjustments to the water conditioning program may occur during final design or when a water treatment/chemical vendor is selected prior to facility startup. Although different vendors offer their own blends of conditioners, the overall water conditioning program will be consistent with the types of chemicals listed in Table 2. A brief description of the water conditioning program for various pieces of equipment follows:

### **4.1 RO TREATMENT TRAIN**

Water conditioning chemicals will be added ahead of the RO system to prevent premature fouling of the RO membranes. Based on preliminary design, this will consist of sodium bisulfite to remove residual chlorine, an antiscalant to limit the potential for scale formation, sulfuric acid for pH control, and a caustic to remove carbon dioxide. Projected dosing rates (in ppm) are listed in Table 2.

### **4.2 HEAT RECOVERY STEAM GENERATOR (HRSG)**

Consistent with the feedwater treatment program employed in the industry BHS Unit 5 steam cycle chemistry will be controlled by injecting aqueous ammonia and a filming amine into the Condensate/feedwater systems combined with trisodium phosphate injection in the high pressure (HP) and intermediate pressure (IP) drums, as further described below.

#### **4.2.1 Condensate/Feedwater**

An aqueous ammonia solution will be used to maintain the HRSG condensate/feedwater pH between 9.4 and 9.6. A filming amine will be used to provide a protective film on internal surfaces within the HRSG and steam cycle to reduce corrosion. The ammonia and amine feed rates will be automatically adjusted

**TABLE 2: WATER CONDITIONING PROGRAM**  
V 5

AUXILIARY COOLING TOWER												
Chemicals	Chemical Supplier	Name, Concentration	Density (lb/gal)	Dose (ppm)	Flow (gph)	Flow (lb/hr)	Continuous / Intermediate	Purpose	Tank/Tote & Quantity	Site Storage	ASME Category M Fluid	Comments
Sodium Hypochlorite	ChemTreat	Sodium Hypochlorite, 12.5%	10.09	0.2	1.43	14.43	Continuous	Oxidant - Biofilm control	Tote, 400 gal	Estimate one to two spare totes	No	Feed skid equipped with 1" female cam-lock
Acid	Univar	Sulfuric Acid, 77-100%	15.28	11	0.1	1.53	Continuous	pH and Scale control	Tote, 400 gal	Estimate one to two spare totes	No	Acid will be diluted to 3% before feeding to tower. Feed skid equipped with 1" female cam-lock.
Antiscalant	ChemTreat	Polymer Dispersant, ChemTreat CL4704.	9.61	30	0.09	0.86	Continuous	Scale control	Tote, 400 gal	Estimate one to two spare totes	No	Feed skid equipped with 1" female cam-lock
Corrosion Inhibitor	ChemTreat	Flexpro, ChemTreat CL5644	10.78	30	0.13	1.40	Continuous	Corrosion inhibition	Tote, 400 gal	Estimate one to two spare totes	No	Feed skid equipped with 1" female cam-lock

Total = 18.2

CYCLE FEEDWATER / CONDENSATE / HRSG DRUM / AUXILIARY BOILER												
Chemicals	Chemical Supplier	Name, Concentration	Density (lb/gal)	Dose (ppm)	Flow (gph)	Flow (lb/hr)	Continuous / Intermediate	Purpose	Tank/Tote & Quantity	Site Storage	ASME Category M Fluid	Comments
Condensate Ammonia			7.71	1-2	3.25	25.1	Continuous					
Aux. Boiler Ammonia	ChemTreat	ChemTreat BL153, 10-30%	7.71	1-4	0.12	0.9	Intermediate (Startup/Shutdown Only)	pH Control	Tote, 250 gal	Total ammonia based products are limited to 500 gallons total.	No	Feed skid equipped with 1" female cam-lock.
Condensate Filming Amine	ChemTreat	ChemTreat BL8100, 10-30%	8.35	1-2	3.25	27.1	Continuous	pH Control	Tote, 250 gal		No	Feed skid equipped with 1" female cam-lock.
Trisodium Phosphate	ChemTreat	ChemTreat BL1794, 1-5%	8.67	1-5	3.4	29.5	Intermediate	pH buffer and hardness/scale	Removal totes Tote, 400 gal	Estimate one to two spare	No	HP and IP boiler drum feed. Feed skid equipped with 1" female cam-lock. One HP and one IP phosphate tote.

Total = 82.5

HRSG / SCR												
Chemicals	Chemical Supplier	Name, Concentration	Density (lb/gal)	Dose (ppm)	Flow (gph)	Flow (lb/hr)	Continuous / Intermediate	Purpose	Tank/Tote & Quantity	Site Storage	ASME Category M Fluid	Comments
Ammonia	ChemTreat / Tanner Industries	Ammonia Hydroxide, 19%	7.71	--	173.89	1340.7	Continuous	SCR Catalyst Reagent	Tank, 20,000 gals	The amount of storage allowed in the tank.	No	Two (2) 2" Female Cam-lock connections on unloading skid for tank fill and vent.

Total = 1340.7

SERVICE/FIRE WATER STORAGE TANK												
Chemicals	Chemical Supplier	Name, Concentration	Density (lb/gal)	Dose (ppm)	Flow (gph)	Flow (lb/hr)	Continuous / Intermediate	Purpose	Tank/Tote & Quantity	Site Storage	ASME Category M Fluid	Comments
Polyphosphoric Acid	GE Water	Flogard MS6202, 20 - 40%	11.16	1-1.4	0.36	3-4	Continuous	Antiscalant	Tote, 250 gal. or Drum	Estimate one spare	No	

DEMINERALIZED WATER												
Chemicals	Chemical Supplier	Name, Concentration	Density (lb/gal)	Dose (ppm)	Flow (gph)	Flow (lb/hr)	Continuous / Intermediate	Purpose	Tank/Tote & Quantity	Site Storage	ASME Category M Fluid	Comments
Sodium Bisulfite	Evoqua	Sodium Bisulfite, 50%	10.84	--	0.25	2.7	Continuous	Dechlorination	Tote, 80 gals	Estimate one to two spare totes	No	Contained all within Evoqua container
Antiscalant	Evoqua, Avista Technologies	VITEC 3000 NSF, or equivalent	9.42	--	0.5	4.7	Continuous	Solubility and Scale Control	Tote, 80 gals	Estimate one to two spare totes	No	Contained all within Evoqua container
Caustic	Evoqua, Gehring-Montgomery	Caustic Liquid Soda, 50% or equivalent	12.8	--	0.5	6.4	Continuous	CO2 removal	Tote, 80 gals	Estimate one to two spare totes	No	Contained all within Evoqua container

Total = 13.8

TURBINE GENERATOR												
Chemicals	Chemical Supplier	Name, Concentration	Density (lb/gal)	Dose (ppm)	Flow (gph)	Flow (lb/hr)	Continuous / Intermediate	Purpose	Tank/Tote & Quantity	Site Storage	ASME Category M Fluid	Comments
Hydrogen	Air Products	H2, 100%	0.0056	--	--	17	Continuous	Generator Cooling No Traller/bottle storage.	Generator Cooling No Traller/bottle storage.	The amount of storage allowed in the trailer.		Connections for trailer hookup will be with chemical supplier
Carbon Dioxide	Air Products	CO2, 100%	0.12346	--	--	890	Continuous	Generator Hydrogen Cooling Purge	36 Bottles total, 465 #3 per bottle	The amount of storage allowed in the trailer.	No	Connections for trailer hookup will be with chemical supplier

Total = 907

1. Density is Design Basis.  
NOTE: All Chemicals listed above and on previous page are proposed based on the design of the respective systems. Chemical brand, SDS and feed rates are subject to change based on final commissioning and operation.

by the main plant distributed control system (DCS) based on the specific conductance of the condensate. Estimated dosing rates (in ppm) for ammonia and amine are listed in Table 2.

#### **4.2.2 Boiler Water**

A trisodium phosphate solution will be used in the HP and IP drums to maintain the boiler water pH and prevent scale formation on boiler tube surfaces. The phosphate combines with hardness in the boiler feedwater to form a non-adhering precipitate that can be easily blown down from the boiler. The estimated phosphate dosing rate (in ppm) is listed in Table 2.

#### **4.3 SELECTIVE CATALYTIC REDUCTION (SCR)**

A 19% aqueous ammonia solution will be used as a catalyst reagent in the SCR process for air pollution control purposes. The SCR system does not generate process wastewater. Aqueous ammonia for the SCR will be stored in a 20,000 aboveground storage tank.

#### **4.4 AUXILIARY BOILER**

A 19% aqueous ammonia solution will be used in the auxiliary boiler to maintain pH within the range of 9.5 to 10.2 standard units. Ammonia is fed to the auxiliary boiler deaerator to raise the pH to minimize corrosion. The estimated dosing rate (in ppm) is listed in Table 2. Auxiliary boiler blowdown will be routed to one of the Facility's wastewater sumps for reuse as auxiliary cooling tower makeup.

#### **4.5 AUXILIARY COOLING TOWER**

Makeup water for the auxiliary cooling tower will consist primarily of recycled process wastewater collected in the wastewater collection sump, HRSG blowdown sump and RO reject. This will be supplemented, as required, with water from the service water/fire water storage tank. The water conditioning program for the auxiliary cooling tower will consist of acid addition for alkalinity control, sodium hypochlorite addition to limit biofouling potential, and use of corrosion and scale inhibitors. The program will not use chemical additives containing the 126 priority pollutants, as required under 40 CFR 423.17. Sulfuric acid will be fed to the cooling tower to reduce total alkalinity. Reducing total alkalinity allows the cycles of concentration in the tower to be increased, while controlling the scaling potential of the water. Scale and corrosion inhibitors are added to the auxiliary cooling tower as sequestering agents

to inhibit scale build-up and to reduce corrosion potential. Sodium hypochlorite is fed to the auxiliary cooling tower to minimize biofouling of heat exchange surfaces within the circulating water system and to minimize biological growth on tower fill and circulating water piping. Estimated dosing rates are listed in Table 2.

## **5.0 COMPLIANCE WITH EFFLUENT LIMITATIONS**

Process wastewater discharged directly to the sewer for treatment at the West Side Water Pollution Control Facility (WPCF) will comply with the Effluent Guidelines and Standards for the Steam Electric Power Generating Point Source Category listed at 40 CFR 423.17 entitled "Pretreatment Standards for New Sources (PSNS)." In addition, under normal operating conditions constituent concentrations in the discharge would be less than those allowed under the CT DEEP's General Permit for Miscellaneous Discharges of Sewer Compatible (MISC) Wastewater.

Stormwater runoff from the site will be managed in accordance with the CT DEEP's Stormwater Management Regulations and will discharge directly to receiving waters (i.e., Bridgeport Harbor) in accordance with the CT DEEP's General Permit for the Discharge of Stormwater Associated with Industrial Activity. No stormwater is discharged to the WPCF.

### **5.1 METERING AND COMPLIANCE MONITORING**

PSEG will establish, as required, a wastewater metering and representative sampling/monitoring point to verify compliance with applicable effluent limits and monitoring requirements. Sample collection will be performed in accordance with permit conditions. Sample analysis will be performed by a State of Connecticut certified laboratory using approved analytical methods (40 CFR Part 136).

### **5.2 COMPLIANCE WITH PRETREATMENT STANDARDS FOR NEW SOURCES (PSNS)**

As a steam electric generating facility, BHS Unit 5 is subject to federal effluent limitation guidelines contained in 40 CFR 423 for the Steam Electric Generating Point Source Category. The subsections below demonstrate how the facility will comply with the pretreatment standards for new sources (PSNS criteria) contained in 40 CFR 423.17.

#### **5.2.1 PCBs**

In accordance with 40 CFR 423.17, there shall be no discharge of polychlorinated biphenyl compounds such as those used for transformer fluid.

*None of the equipment at BHS Unit 5, including transformers, will contain polychlorinated biphenyl compounds. As such, the facility will comply with this restriction.*

### 5.2.2 Chemical Metal Cleaning Wastes

The pollutants discharged in chemical metal cleaning wastes shall not exceed the concentration listed in the Table 3.

**Table 3: PSNS Criteria for Chemical Metal Cleaning Wastes**

Pollutant or Pollutant Property	PSNS Maximum for any time (mg/l)
Copper, total	1.0

*The facility will comply with this restriction, as process wastewater associated with chemical metal cleaning will not be discharged to the sewer. Wastewater/rinse water generated during acid cleaning of the HRSG, if required during a maintenance outage, will be trucked for off-site disposal at an appropriately licensed facility. Similarly, offline compressor wash water will also be trucked for off-site disposal at an appropriately licensed facility.*

### 5.2.3 Auxiliary Cooling Tower Blowdown

Process wastewater discharged to the City’s wastewater collection system will consist primarily of auxiliary cooling tower blowdown and discharges from oil/water separators. Due to evaporative loss in the auxiliary cooling tower, the wastewater (blowdown) will consist primarily of the naturally occurring dissolved salts and minerals (i.e., those present in the recycle streams and the municipal water supply distribution system) which have been concentrated through evaporation. The blowdown volume will vary depending on the allowable cycles of concentration required to control scale formation and prevent excessive corrosion.

The engineering review of water quality data indicates the auxiliary cooling tower will typically operate at from 7 to 9 cycles of concentration when firing natural gas and at up to 4.5 cycles of concentration when firing ULSD. Projected auxiliary cooling tower blowdown characteristics are listed in Tables 4 and 5. Projected blowdown concentrations reflect reuse of low volume waste streams, such as HRSG blowdown and RO reject water, as well as the facility’s water conditioning program. Applicable effluent limits under 40 CFR 423.17 and, for comparative purposes, allowable effluent limits under the CT DEEP’s General Permit for Miscellaneous Discharges of Sewer Compatible Wastewater are listed below.

**Table 4: Discharge Point: DSN 201 - Conventional Constituents**

Parameter	Projected Effluent Concentration – NG Firing*	Projected Effluent Concentration – ULSD Firing*	MISC Wastewater Effluent Limit	Units
Biochemical Oxygen Demand	<50	<50	600	mg/l
Chemical Oxygen Demand	<100	<100	-	mg/l
Total Organic Carbon	<100	<100	-	mg/l
Total Suspended Solids	<100	<100	600	mg/l
Total Dissolved Solids	<1500	<3000	-	mg/l
Ammonia (as N)	<20	<20	50	mg/l
pH (in standard units)	5.0 < pH < 12.0	5.0 < pH < 12.0	5.0 < pH < 12.0	SU
Oil & Grease	<25	<25	100	mg/l
Total Petroleum Hydrocarbons	<25	<25	100	mg/l
Calcium	<150	<300	-	mg/l
Chloride	<300	<1000	-	mg/l
Sodium	<300	<300	-	mg/l
Potassium	<10	<25	-	mg/l
Chlorine, Total Residual	<1.0	<1.0	-	mg/l
Sulfate (as SO <sub>4</sub> )	<200	<500	-	mg/l
Surfactants	<5	<5	-	mg/l
Aluminum, Total	<0.5	<0.75	-	mg/l
Barium, Total	<0.5	<0.5	-	mg/l
Boron, Total	<0.5	<0.5	-	mg/l
Iron, Total	<1	<2.0	-	mg/l
Magnesium, Total	<100	<100	-	mg/l
Manganese, Total	<0.1	<0.1	-	mg/l
Nitrogen, Total Organic (as N)	<20	<40	-	mg/l
Nitrate (as N)	<5	<10	50	mg/l
Total Phosphorus (as P)	<15	<25	-	mg/l

\* Effluent concentrations are conservatively estimated based on the auxiliary cooling tower cycles of concentration.

**Table 5: Discharge Point: DSN201 - Heavy Metals<sup>1</sup>**

Parameter	Projected Effluent Concentration – NG Firing	Projected Effluent Concentration – ULSD Firing	MISC Wastewater Effluent Limit	Units
Antimony Total 7440-36-0	<0.1	<0.05	4	mg/l
Arsenic Total 7440-38-2	<0.05	<0.05	-	mg/l
Beryllium Total 7440-41-7	<0.05	<0.05	2	mg/l
Cadmium Total 7440-43-9	<0.05	<0.05	0.5	mg/l
Chromium Total 7440-47-3	<0.20	<0.20	2	mg/l
Copper, Total 7550-50-8	<0.25	<0.25	2	mg/l
Lead, Total 7439-92-1	<0.25	<0.25	0.5	mg/l
Mercury Total 7439-97-6	<0.0002	<0.0002	0.0002	mg/l
Nickel Total 7440-02-0	<0.25	<0.25	2	mg/l
Selenium Total 7782-49-2	<0.25	<0.25	0.5	mg/l
Silver, Total 7440-22-4	<0.05	<0.05	0.5	mg/l
Thallium, Total 7440-28-0	<0.25	<0.5	2	mg/l
Zinc, Total 7440-66-6	<1.0	<2.0	2	mg/l

1) Heavy metals are projected to be present in auxiliary cooling tower blowdown primarily due to their presence in the municipal distribution system (i.e., presence in the makeup water).

In accordance with 40 CFR 423.17, the quantity of pollutants discharged in cooling tower blowdown cannot exceed the concentration based limits listed in Table 6.



**Table 6: PSNS Criteria for Cooling Tower Blowdown**

Pollutant or Pollutant Property	PSNS Maximum for any time (mg/l)
The 126 priority pollutants (Appendix A) contained in chemicals added for cooling tower maintenance, except:	(1)
Chromium, total	0.2
Zinc, total	1.0

<sup>1</sup>No detectable amount.

Also in accordance with 40 CFR 423.17, at the permitting authority's discretion, instead of the monitoring in 40 CFR 122.11(b), compliance with the standards for the 126 priority pollutants in Table 6, above, may be determined by engineering calculations which demonstrate that the regulated pollutants are not detectable in the final discharge by the analytical methods in 40 CFR Part 136.

*The limitations listed in Table 6 apply to priority pollutants which are contained in cooling tower additives/conditioning chemicals. They do not apply to constituents, such as chromium or zinc, which are present in cooling tower makeup water. At BHS Unit 5 neither chromium nor zinc based additives will be used in the auxiliary cooling tower or for treatment or conditioning of any low volume waste streams discharged to the auxiliary cooling tower. In addition, PSEG will not use cooling tower additives containing any of the other 124 priority pollutants. Compliance will be demonstrated through engineering calculations and certification that priority pollutants are not contained in the facility's water conditioning program. As such, the facility will comply with these limits.*

*The thermal component of the discharge will vary as a function of ambient wet bulb temperature. The temperature of auxiliary cooling tower blowdown during the spring, summer, and fall seasons can be estimated assuming a 10° F to 15° F increase above ambient wet bulb temperature, and will generally be less than 100° F. During the winter, discharge temperatures are expected to range between 55° F and 60° F, but can approach 70° F. As such, the facility would comply with the temperature limitation contained in the General Permit for Miscellaneous Discharges of Sewer Compatible (MISC) Wastewater.*

#### **5.2.4 Fly Ash Transport Water**

There shall be no discharge of wastewater pollutants from fly ash transport water.

*BHS Unit 5 will not generate fly ash transport water. As such, the facility will comply with this restriction.*

#### **5.2.5 FGD Wastewater**

*BHS Unit 5 will not generate flue gas desulfurization (FGD) wastewater. As such, effluent limits applicable to FGD wastewater do not apply.*

#### **5.2.6 Flue Gas Mercury Control Wastewater**

There shall be no discharge of pollutants in flue gas mercury control wastewater.

*BHS Unit 5 will not generate flue gas mercury control wastewater. As such, the facility will comply with this restriction.*

#### **5.2.7 Bottom Ash Transport Water**

There shall be no discharge of pollutants in bottom ash transport water.

*BHS Unit 5 will not generate bottom ash transport water. As such, the facility will comply with this restriction.*

#### **5.2.8 Gasification Wastewater**

*BHS Unit 5 will not generate gasification wastewater. As such, effluent limits applicable to gasification wastewater do not apply.*

#### **5.2.9 Combustion Residuals Leachate**

*BHS Unit 5 will not generate combustion residuals leachate. As such, effluent limits applicable to combustion residuals leachate do not apply.*

### 5.3 SUMMARY

The average daily discharge flow to the sewer will be less than or equal to 50,000 gallons per day (34.7 gpm). This includes both process and sanitary wastewater. The maximum instantaneous discharge rate to the sewer will be 150 gpm, lasting for a two hour period. This will occur during a scheduled maintenance outage once or twice per year when the auxiliary cooling tower and circulating water system are drained for maintenance. When this occurs, the total daily flow to the sewer will remain below 50,000 gallons per day as the Facility will be offline (i.e., when the auxiliary cooling system is drained, the plant must be shut down).

In the unlikely event of an equipment failure or unexpected plant shutdown, the maximum daily flow to the sewer would not exceed 75,000 gallons per day. PSEG does not anticipate this would occur more than 5 days per year.


As indicated above, the process wastewater discharged to the sewer will meet the Federal Categorical Pretreatment Standards (40 CFR423 et. seq.). For comparative purposes, projected discharge concentrations would also be less than the effluent limitations contained in CT DEEP's General Permit for Miscellaneous Discharges of Sewer Compatible (MISC) Wastewater when firing natural gas. Sanitary wastewater at the facility will be collected separately from process wastewater, but discharged to the sewer through the newly constructed General Services Sump pump station and force main.

# APPENDIX 1

## Water Balance Diagrams

**GENERAL NOTES:**

1. THE INTENT OF THIS DIAGRAM IS TO SHOW THE FRESH WATER AND WASTEWATER FLOWS.
2. REFER TO 644911-F0002-5002 FOR STREAM FLOW DATA.
3. DASHED LINES REPRESENT INTERMITTENT FLOWS.



**Figure 4**

ISSUED FOR CONSTRUCTION		DATE	BY	CHKD	APPV
ISSUED FOR APPROVAL		05/17/17	WH	LDH	SKO
PROJECT	BRIDGEPORT 05	NO. TECH.	LA	DR	SR
DESIGNED BY		CHECKED			
DATE		APPROVED			
REVISION					
PROJECT ENGINEERING DIVISION					
PSEC					
SNC-LAVALIN CONSTRUCTORS INC.					
SCALE	BRIDGEPORT 05				
PROCESS FLOW DIAGRAM					
WASTEWATER TREATMENT FLOW DIAGRAM					
SHT. 1 OF 5					
WATER BALANCE - MECHANICAL/SIPING					
644911-F0002-5001					



SEWER MAIN  
FLOW METER  
MANHOLE

A B C D E F

1 2 3 4 5

Table 1: Bridgeport Unit 5 Water Balance

Stream no.	Description	Units	Low Ambient Case		CASE 1		CASE 2		CASE 3		CASE 4		CASE 5		CASE 6		Remarks
			USLD, EC off, DF ON, 100% GT load	0 F	NG, EC off, DF Off, 100% GT load	59 F / 60% RH	NG, EC ON, DF ON, 100% GT load	80 F / 70% RH	USLD, EC off, DF Off, 100% GT load	35 F / 50% RH	NG, EC ON, DF ON, 100% GT load	59 F / 60% RH	NG, EC ON, DF ON, 100% GT load	80 F / 70% RH	NG, EC ON, DF ON, 100% GT load	59 F / 60% RH	
	HRSG & Heat balance Case no.		56 & CCA20146		Case 1 (HRSG) & Heat balance CCA20095	Case 2 (HRSG performance) & Heat balance CCA20081	Case 3 (HRSG) & Heat balance CCA20139	Case 4 (HRSG) & Heat balance CCA20081	Case 5 (HRSG) & Heat balance CCA20004	Case 6 (HRSG) & Heat balance CCA20138							
1	City water supply	gpm	586		120	169	619	169	143	624							
2	Portable water network	gpm			2	2	2	2	2	2							
3	Supply to Service/Fire water tank	gpm			118	167	617	167	141	622							
4	Service water demand	gpm			118	167	648	167	141	658							
5	Service water makeup to CT makeup	gpm			8	64	31	79	59	32							
6	Service water for misc uses	gpm			10	10	10	10	10	10							
7	Supply to CTG evap cooler	gpm			0	23	0	23	20	0							
	Total steam rate	lbm	1,072,800		821,700	1,032,100	812,500	1,028,000	882,100	7,002,500							
11	Boiler makeup	gpm			28	35	28	35	35	35							
12	Non Water	gpm			0	0	0	0	0	0							
13	Total gpm water	gpm			531	35	509	56	0	509							
14	Leased RODI trailers, permeate	gpm			300	29	357	36	35	35							
15	Leased RODI trailers, permate	gpm			29	36	300	36	35	35							
16	Supplement DI trailer, min flow	gpm			231	0	237	0	0	244							
17	Leased RODI trailers, feed	gpm			353	34	353	42	41	244							
18	Supplement DI trailer, feed	gpm			237	0	244	0	0	251							
19	Water pretreatment backwash	gpm			1	1	1	1	1	1							
20	Total supply to water treatment	gpm			581	43	598	43	42	505							
21	CT evaporation	gpm			46	86	68	105	86	88							
22	CT Cycles of concentration				3.5	8.5	7	7	7	7							
23	CT Drift	gpm			0.1	0.1	0.1	0.1	0.1	0.1							
24	CTG evap cooler evaporation	gpm			0	19	0	19	0	19							
25	Misc losses from w/s cycle	gpm			11.8	8	7.8	11.2	11.1	10.6							
26	HRSG blowdown	gpm			21	16	21	21	21	10.7							
27	Blowdown, after flashing	gpm			13	10	16	11.1	10.6	10.6							
28	Quench water, gpm	gpm			10	9	10	12	12	12							
29	To blowdown sump	gpm			23	9	11	11	11	11							
30	Fire water system	gpm			0	24	19	24	23	23							
31	Demin water to CTG water wash	gpm			0	0	0	0	0	0							
32	City water to ACC tin tube cleaning	gpm			0	0	0	0	0	0							
33	Demin water to chemical dilution	gpm			0	0	0	0	0	0							
34	Non city wastewater	gpm			5	5	5	5	5	5							
35	Condensate polisher backwash	gpm			0.3	0.3	0.3	0.3	0.3	0.3							
36	Sample panel drains	gpm			4	4	4	4	4	4							
37	RO reject	gpm			53	5	53	6	6	53							
38	Evaporative cooler blowdown	gpm			0	4	0	4	4	4							
39	Recycle to CT basin from BD sump	gpm			32	28	37	37	35	35							
40	To cartridge filters	gpm			0	0	28	0	0	0							
41	Recycle to SFJ water tank	gpm			0	0	4	0	0	0							
42	Oil wastewater	gpm			5	5	5	5	5	5							
43	CT Blowdown	gpm			18	11	19	18	19	14							
44	Sanitary wastewater	gpm			24	17	24	24	24	21							
45	Total wastewater	gpm			2	2	2	2	2	2							
46	Rinse water recycle to service/fire water	gpm			28.4	19.5	27.4	25.5	22.3	28.6							
47		gpm			2.9	0	2.9	0	0	2.9							

NOTE 1 Indicated flow rates may not balance due to rounding.  
 NOTE 2 Quenched blowdown temperature equal or less than 140 degree F.  
 NOTE 3 Assumes 85% RO recovery.  
 NOTE 4 Based on 6 cycles of concentration.

# APPENDIX 2

## Safety Data Sheets

# Attachment A

## Executive Summary



## Attachment A: Executive Summary

Applicant Name: **PSEG Power Connecticut LLC**  
 (as indicated on the *Application Form*)

Location of Facility or Activity:

**1 Atlantic Street, Bridgeport, CT**

Contact Person: **David Hinchey Jr.**

Phone: **973-856-0066**

For renewals or modifications of an existing permit, provide the Facility I.D. No.:

In the table below list *each* discharge that is the subject of this application. For renewals of existing permits, label each discharge by the same discharge serial number stated in the previous permit and provide the existing permit number. For new permits, label each discharge to a surface water consecutively starting with serial number 101; for discharges to a POTW label each discharge consecutively starting with 201; and for discharges to ground water label each discharge consecutively starting with 301.

Discharge Serial Number/ Permit Number	Maximum Flow (gallons per day)	Category of Discharge Source	Name of discharge location (Name of POTW; Name of surface water; For groundwater, name of surface watershed area)	Geographical description of location of discharge point (e.g., 20 feet north from Bear Bridge)
DSN 201	75,000	Cooling Tower Blowdown, Oil/Water Sep.	West Side WPCP	Railroad Avenue and Main Street

## Attachment A: Executive Summary (continued)

Provide a brief general description of the nature of the business or activity and of each existing or proposed activity or process generating each discharge. For new discharges, provide a timeline for initiation of the discharges as well as a brief summary of the environmental impact of the proposed discharges.

**PSEG Power Connecticut LLC is proposing to construct, own and operate a new 485 MW combined cycle generating facility (BHS Unit 5) at Bridgeport Harbor Station located at 1 Atlantic Street in Bridgeport Connecticut. This application addresses sanitary and process wastewater discharges from the facility to the City of Bridgeport collection system for treatment at the West Side Water Pollution Control Plant (WPCP). Sanitary wastewater is estimated to total 2880 gallons per day (gpd). Process wastewater is anticipated to total less than 50,000 gpd on an average daily basis (max day 75,000 gal.) and consist primarily of auxiliary cooling tower blowdown and treated effluent from oil/water separators.**

**The new combined cycle facility (BHS Unit 5) will be located at the southern end of the site encompassing the existing fuel oil tank farm area. The new power block will consist of one combustion turbine generator set, a heat recovery steam generator ("HRSG") and a steam turbine generator set. Ancillary equipment at the facility will include an air cooled condenser ("ACC") for steam cycle cooling, a process makeup water demineralization system, a small mechanical draft cooling tower for ancillary cooling (i.e., an auxiliary cooling tower), a 950,000 gallon service water/fire water storage tank, a 1,000,000 gallon demineralized water storage tank, a 5.5 million gallon ultra-low sulfur distillate (ULSD) fuel oil storage tank, and an auxiliary boiler.**

**BHS Unit 5 will represent one of the most water efficient steam electric generating facilities located in Connecticut. To minimize process makeup and process wastewater discharge needs, internal recycle and reuse will be used to the maximum extent practicable. Water needs for BHS Unit 5 will be satisfied by withdrawals from the municipal distribution system. BHS Unit 5 will not require operation of a cooling water intake structure. As such, potential environmental impacts will be avoided or minimized.**

**Provisional acceptance and commercial operation are targeted for June 2019. A more detailed description of proposed discharges is attached following the Executive Summary.**

Check here if additional sheets are necessary, and label and attach them to this sheet.

Provide a table of contents of the application which includes the permit application form, and a list of titles of all plans, drawings, reports, studies, or other supporting documentation which are attached as part of the application, along with the corresponding attachment label and the number of pages (i.e., Executive Summary - Attachment A - 4 pages).

## Attachment I

### Operation and Maintenance of Collection and Treatment Systems

- Description
- Plan Checklist
- Certification

## **Part A: Wastewater Treatment Units – BHS 5**

Oil/water separators will be located to capture and retain oil from potentially oily areas of the facility (i.e., building floor drains) as well as to provide secondary containment for selected oil filled equipment and/or storage tanks. Oil collected in oil/water separators will be removed using a Vac truck and transported for offsite recycling or disposal at an appropriately licensed facility. Three oil/water separators will be located at the facility as shown on Drawing Numbers 191547-DS-10044A and 191547-DS-1044B included in Attachment N. Highland Tank is the recommended vendor for the oil/water separators at Bridgeport Unit 5. An informational brochure for Highland Tank oil/water separators is attached.

### **Oil Water Separators**

The following lists the models for Highland Tank Oil/Water Separators for Bridgeport Unit 5. The previously submitted preliminary sizes were based on flow and oil volume information taken from a similar project currently under construction (i.e., Sewaren Unit 7). This section has been updated to reflect the detailed design of BHS 5. Design plans and specifications are included in Attachment N. The units are designed to achieve an effluent limit of 10 mg/l for total petroleum hydrocarbons (TPH).

There are three separators in the design: North (between the STG and CTG GSU transformers), South (just east of the HRSG Electrical PDC Enclosure), and Southeast (just south of the Fuel Oil Forwarding Pump Enclosure).

The North OWS is a Highland HT-12,000. Its size is controlled by the volume of oil in the ST Lube Oil Reservoir.

The South OWS is an HT-550. It is sized based on flows from the HRSG Electrical PDC Enclosure.

The East OWS is an HT-3,000. It is sized based on the floor drains that drain to it from the Fuel Oil Forwarding Pump Enclosure, the Fuel Oil Truck Unloading Area, and the Fire Pump House.

### **Plans and Specifications**

Plans and specifications for Highland Tank's Oil/Water Separators are included in Attachment N. Backup calculations for unit sizing are also included in Attachment N.


## **Part B: Operation and Maintenance**

PSEG Power Connecticut LLC (PSEG) will be responsible for operation and maintenance of the oil/water separators located onsite. Manufactures recommended installation, startup, operation and maintenance procedures are described in detail in Highland Tank's Oil/Water Separator's User's Manual included in Attachment N. A copy of the Highland Tank Oil/Water Separators User's Manual will be maintained onsite for easy reference.

Attachment M  
Line Drawing and Process Flow Diagram

**GENERAL NOTES:**

1. THE INTENT OF THIS DIAGRAM IS TO SHOW THE PAUK WATER AND WASTEWATER FLOWS.
2. REFER TO 644911-F0002-S002 FOR STREAM FLOW DATA.
3. DASHED LINES REPRESENT INTERMITTENT FLOWS.



**Figure 4**

ISSUED FOR CONSTRUCTION

NO.	BY	DATE	REVISION
1	WJ	05/13/17	ISSUED FOR APPROVAL
2	WJ		REVISED FOR APPROVAL
3	WJ		
4	WJ		
5	WJ		
6	WJ		
7	WJ		
8	WJ		
9	WJ		
10	WJ		
11	WJ		
12	WJ		
13	WJ		
14	WJ		
15	WJ		
16	WJ		
17	WJ		
18	WJ		
19	WJ		
20	WJ		
21	WJ		
22	WJ		
23	WJ		
24	WJ		
25	WJ		
26	WJ		
27	WJ		
28	WJ		
29	WJ		
30	WJ		
31	WJ		
32	WJ		
33	WJ		
34	WJ		
35	WJ		
36	WJ		
37	WJ		
38	WJ		
39	WJ		
40	WJ		
41	WJ		
42	WJ		
43	WJ		
44	WJ		
45	WJ		
46	WJ		
47	WJ		
48	WJ		
49	WJ		
50	WJ		
51	WJ		
52	WJ		
53	WJ		
54	WJ		
55	WJ		
56	WJ		
57	WJ		
58	WJ		
59	WJ		
60	WJ		
61	WJ		
62	WJ		
63	WJ		
64	WJ		
65	WJ		
66	WJ		
67	WJ		
68	WJ		
69	WJ		
70	WJ		
71	WJ		
72	WJ		
73	WJ		
74	WJ		
75	WJ		
76	WJ		
77	WJ		
78	WJ		
79	WJ		
80	WJ		
81	WJ		
82	WJ		
83	WJ		
84	WJ		
85	WJ		
86	WJ		
87	WJ		
88	WJ		
89	WJ		
90	WJ		
91	WJ		
92	WJ		
93	WJ		
94	WJ		
95	WJ		
96	WJ		
97	WJ		
98	WJ		
99	WJ		
100	WJ		

PROJECT ENGINEERING DIVISION  
**PSEG**  
 SNC • LAVALEN  
 CONSTRUCTORS INC.

SCALE: BRIDGEPORT 05  
 PROCESS FLOW DIAGRAM  
 FLOW DIAGRAM  
 SHT. 1 OF 5

WATER BALANCE: MECHANICAL SYSTEMS  
 644911-F0002-S001


Table 1: Bridgeport Unit 5 Water Balance

Stream no.	Description	Units	Low Ambient Case USLD, EC off, DF ON, 100% GT load 0 F	Case 1 NG, EC Off, DF Off, 100% GT load 59 F / 60% RH Case 1 (HRSG) & Heat balance CCA20095	Case 2 NG, EC ON, DF ON, 100% GT load 90 F / 70% RH Case 2 (HRSG performance) & Heat balance CCA20081	Case 3 USLD, EC off, DF Off, 100% GT load 35 F / 50% RH Case 3 (HRSG) & Heat balance CCA20139	Case 4 NG, EC ON, DF ON, 100% GT load 90 F / 70% RH Case 4 (HRSG) & Heat balance CCA20081	Case 5 NG, EC ON, DF ON, 100% GT load 59 F / 60% RH Case 5 (HRSG) & Heat balance CCA20094	Case 6 USLD, EC Off, DF ON, 100% GT load 35 F / 50% RH Case 6 (HRSG) & Heat balance CCA20138	Remarks
	HRSG & Heat balance Case no.		56 & CCA20146							
	Ambient temperature									
1	City water supply	gpm	585	120	169	619	169	143	624	
2	Perable water network	gpm	2	2	2	2	2	2	2	
3	Supply to Service/Fire water tank	gpm	584	118	167	617	167	141	622	
4	Service water demand	gpm	619	118	167	648	167	141	656	
5	Service water makeup to CT makeup	gpm	8	64	76	31	79	59	32	
6	Service water for misc uses	gpm	10	10	10	10	10	10	10	
7	Supply to CTG evap cooler	gpm	0	23	23	0	23	0	20	
8	Total steam rate	lbm	1,072,500	821,700	1,032,100	812,500	1,028,000	993,100	1,002,500	
9	Boiler makeup	gpm	38	29	36	28	36	35	35	
10	Nox Water	gpm	493	0	0	509	0	0	509	
11	Total Demin water	gpm	531	29	36	537	36	35	544	
12	Leased RO/DI trailers, permeate	gpm	300	29	36	300	36	35	300	
13	Supplement DI trailer, min flow	gpm	231	0	0	237	0	0	244	
14	Leased RO/DI trailers, feed	gpm	353	34	42	353	42	41	353	
15	Supplement DI trailer, feed	gpm	237	0	0	244	0	0	251	
16	Water pretreatment backwash	gpm	1	1	1	1	1	1	1	
17	Total supply to water treatment	gpm	591	35	43	598	43	42	605	
18	CT evaporation	gpm	46	86	105	68	105	88	58	
19	CT Cycles of concentration	-	3.5	8.5	7	4.5	7	7	4.3	
20	CT Drift	gpm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
21	CTG evap cooler evaporation	gpm	0	0	19	0	19	17	0	
22	Misc losses from w/s cycle	gpm	11.8	8	11.2	7.9	11.1	10.6	10.7	
23	HRSG blowdown	gpm	21	16	21	16	21	20	20	
24	Quench water, gpm	gpm	13	10	12	10	12	12	12	
25	To blowdown sump	gpm	10	9	11	9	11	11	11	
26	Fire water system	gpm	23	19	24	19	24	23	23	
27	Demin water to CTG water wash	gpm	0	0	0	0	0	0	0	
28	City water to ACC tin tube cleaning	gpm	0	0	0	0	0	0	0	
29	Demin water to chemical dilution	gpm	0	0	0	0	0	0	0	
30	Non oily wastewater	gpm	5	5	5	5	5	5	5	
31	Condensate polisher backwash	gpm	0.3	0.3	0.3	0.3	0.3	0.3	0.3	
32	sample panel drains	gpm	4	4	4	4	4	4	4	
33	RO reject	gpm	53	5	6	53	6	6	53	
34	Evaporative cooler blowdown	gpm	0	0	4	0	4	3	0	
35	Recycle to CT basin from ED sump	gpm	0	28	37	0	37	35	0	
36	To cartridge filters	gpm	32	0	0	28	0	0	32	
37	Recycle water sump	gpm	4	0	0	4	0	0	4	
38	Recycle to SW water tank	gpm	32	0	0	28	0	0	32	
39	City wastewater	gpm	5	5	5	5	5	5	5	
40	CT blowdown	gpm	18	11	18	19	18	14	21	
41	Sanitary wastewater	gpm	24	17	24	25	24	20	27	
42	Total wastewater	gpm	2	2	2	2	2	2	2	
43	Rinse water recycle to service/fire water	gpm	28.4	19.5	25.5	27.4	25.5	22.3	28.6	
44		gpm	2.9	0	0	2.9	0	0	2.9	

NOTE 1 Indicated flow rates may not balance due to rounding.  
 NOTE 2 Quenched blowdown temperature equal or less than 140 degree F.  
 NOTE 3 Assumes 85% RO recovery.  
 NOTE 4 Based on 6 cycles of concentration.

**GENERAL NOTES:**

1. THE INTENT OF THIS DIAGRAM IS TO SHOW THE MAJOR WATER AND WASTEWATER FLOWS.
2. REFER TO 644911-P0002-S002 FOR STREAM FLOW DATA.
3. DASHED LINES REPRESENT INTERMITTENT FLOWS.



NO.	DATE	BY	CHECKED	APPROVED	PROJ. TECH.	DIR. TECH.	SRD
1	05/17/17	WW					
2							
3							
4							
5							

ISSUED FOR CONSTRUCTION

PROJECT ENGINEERING DIVISION  
PSEG  
Fuel Chemical LLC

SCALE: BRIDGEPORT 05  
Chemical Addition/  
Metering Locations

WATER BALANCE MECHANICAL PIPING



Attachment N

Description and Plans and Specifications of the  
Collection, Treatment and Disposal Systems

## **Attachment N**

Oil/water separators will be located to capture and retain oil from potentially oily areas of the facility (i.e., building floor drains) as well as to provide secondary containment for selected oil filled equipment and/or storage tanks. Oil collected in oil/water separators will be removed using a Vac truck and transported for offsite recycling or disposal at an appropriately licensed facility. Three oil/water separators will be located at the facility as shown on Drawing Numbers 191547-DS-10044A and 191547-DS-1044B, attached. Highland Tank is the recommended vendor for the oil/water separators at Bridgeport Unit 5. An informational brochure for Highland Tank oil/water separators is included in Attachment I.

### **Oil Water Separators**

The following lists the models for Highland Tank Oil/Water Separators for Bridgeport Unit 5. These preliminary sizes were based on flow and oil volume information taken from a similar project currently under construction (i.e., Sewaren Unit 7). The final BHS 5 detailed design is now included and design plans and specifications are attached. The units are designed to achieve an effluent limit of 10 mg/l for total petroleum hydrocarbons (TPH).

There are three separators: North (between the STG and CTG GSU transformers), South (just east of the HRSG Electrical PDC Enclosure), and Southeast (just south of the Fuel Oil Forwarding Pump Enclosure).

The North OWS is a Highland HT-12,000. Its size is controlled by the volume of oil in the ST Lube Oil Reservoir.

The South OWS is an HT-550. It is sized based on flows from the HRSG Electrical PDC Enclosure.

The East OWS is an HT-3,000. It is sized based on the floor drains that drain to it from the Fuel Oil Forwarding Pump Enclosure, the Fuel Oil Truck Unloading Area, and the Fire Pump House.

### **Plans and Specifications**

Plans and specifications for Highland Tank's Oil/Water Separators are attached. In addition, backup calculations for unit sizing are attached.

### **Operation and Maintenance**

PSEG Power Connecticut LLC (PSEG) will be responsible for operation and maintenance of the oil/water separators located onsite. Manufactures recommended installation, startup, operation and maintenance procedures are described in detail in Highland Tank's Oil/Water Separator's User's Manual, attached. A copy of the Highland Tank Oil/Water Separators User's Manual will be maintained onsite for easy reference.

# Attachment O

## Discharge Information

**Attachment O: Discharge Information**  
**(must be completed and submitted for each discharge)**

Applicant Name: **PSEG Power Connecticut LLC**

(as indicated on the permit application form)

Existing Permit Number (if applicable):

Complete this attachment for *each* discharge and label each discharge consecutively starting with serial number 101 for discharges to a surface water, 201 for discharges to a POTW, and 301 for discharges to ground water.

**Part A: General Discharge Information**

**Discharge Serial Number: DSN 201**

1. For discharges to a surface water only:

a. The discharge enters the surface water (check one):

directly

through a municipal storm sewer

through other drainage systems (e.g., swale) Please specify below:

b. Name of surface water body the discharge first enters:

c. Surface water classification of the above listed water body:

Present:

Future:

2. For discharges to a POTW only:

a. The discharge enters the POTW (check one):

directly hauled

through a sanitary sewer or a combined sewer

b. Name of POTW the discharge first enters: **Bridgeport - West Side Water Pollution Control Facility**

c. Facility I.D. or location address of POTW: **205 Bostwick Avenue, Bridgeport CT**

d. Does the discharge contain a substance, which, in the absence of a wastewater discharge permit, would be a hazardous waste under 40 CFR Part 261?  Yes  No

3. For discharges to ground water only:

a. Groundwater classification of the site:

Present:

Future:

b. Name of surface water body in watershed area:

Surface water classification of the above listed water body:

Present:

Future:

**Part A: General Discharge Information (continued)**

**Discharge Serial Number: DSN 201**

4. Average Daily Flow (gpd): **50,000**

Maximum Daily Flow (gpd): **< 75,000**

Design Flow (gpd): **TBD**

Date discharge began or will begin: **January 2019**

5. Is the discharge continuous?  Yes  No  
If yes, indicate:

Average number of hours per day of the discharge: **24**

Maximum number of hours per day of the discharge: **24**

6. For other than a continuous discharge (e.g., batch, intermittent, or seasonal discharges), indicate:

Average number of hours per event of the discharge:

Maximum number of hours per event of the discharge:

The duration and frequency of the discharge:

7. Description of each specific activity or each process generating the discharge and identification of all types of waste generated by each process.

**PSEG Power Connecticut LLC is proposing to construct, own and operate a new 485 MW combined cycle generating facility (BHS Unit 5) at Bridgeport Harbor Station located at 1 Atlantic Street in Bridgeport Connecticut. This application addresses sanitary and process wastewater discharges from the facility to the City of Bridgeport collection system. Sanitary wastewater is estimated to total 2880 gallons per day (gpd). Process wastewater is anticipated to total less than 50,000 gpd on an average daily basis (max day 75,000 gal.) and consist primarily of auxiliary cooling tower blowdown and treated effluent from oil water separators.**

**The new combined cycle facility (BHS Unit 5) will be located at the southern end of the site encompassing the existing fuel oil tank farm area. The new power block will consist of one combustion turbine generator set, a heat recovery steam generator ("HRSG") and a steam turbine generator set. Ancillary equipment at the facility will include an air cooled condenser ("ACC") for steam cycle cooling, a process makeup water demineralization system, a small mechanical draft cooling tower for ancillary cooling (i.e., an auxiliary cooling tower), a 950,000 gallon service water/fire water storage tank, a 1,000,000 gallon demineralized water storage tank, a 5.5 million gallon ultra-low sulfur distillate (ULSD) fuel oil storage tank, and an auxiliary boiler.**

**BHS Unit 5 will represent one of the most water efficient steam electric generating facilities in Connecticut. To minimize process makeup and process wastewater discharge needs, internal recycle and reuse will be used to the maximum extent practicable. Water needs for BHS Unit 5 will be satisfied by withdrawals from the municipal distribution system. BHS Unit 5 will not require operation of a cooling water intake structure. As such, potential environmental impacts will be avoided or minimized.**

**A more detailed description of the proposed discharge is included in Attachment A, Executive Summary.**

Check here if additional sheets are necessary, please label and attach them to this sheet.

**Part A: General Discharge Information (continued)**

8. Process and/or Treatment Substances		Discharge Serial Number: DSN 201
Name of substances used in generating the wastewater	List of toxic or hazardous substances contained in process and/or treatment substance	List any available aquatic toxicity test results for process and/or treatment substance
Sodium Hypochlorite	NaOCl	LC50 Bluegill Sunfish 0.6 mg/l LC50 Ceriodaphnia d. 1.23 mg/l LC50 Fathead Minnow 1.19 mg/l
Sulfuric Acid	Sulfuric acid (77-100%)	NA
Caustic liquid soda (50%)	Sodium hydroxide, Sodium chloride	LC50 Brook Trout 24 hr. 25 mg/l
Antiscalant Chemtreat CL4704	2-Butenedioic Acid (Z), homopolymer and 2-Butenedioic Acid	NA
Corrosion Inhibitor Chemtreat CL5644	Citric Acid	Ceriodaphnia d. LC50 1504 mg/l 48 hour Fathead Minnow LC50 2549 mg/l 96 hour
Chemtreat BL153 and Tanner Industries Ammonium Hydroxide	Ammonium Hydroxide	Fish LC50 0.09-3.51 mg/l 96 hour Fish NOEC 0.025-1.2 mg/l (Based on Tanner Ind.)
Chemtreat BL8100	Cyclohexylamine, Ethanolamine, (z)-N-9-octadecenylpropane-1,3-diamine	Fathead Minnow LC50 96 hour 2.54 mg/l Ceriodapania d. LC50 48 hour 6.94 mg/l
Chemtreat BL1794	Sodium Phosphate, tribasic	Rainbow Trout LC50 1463 mg/l 96 hour Daphnia magna EC50 2158 mg/l 50 hour
Sodium bisulfite	Sodium bisulfite 50%	NA
Flogard MS6202	Phosphoric Acids, Sodium Salts	Daphnia magna 0% mort. 500 mg/l
Vitec 3000	Alkyl phosphonate salt, Phosphonic acid derivative compound, Alkline salt	NOEC Daphnia manga 48 hour 125 mg/l NOEC Rainbow Trout 96 hours 180 mg/l

**Part A: General Discharge Information (continued)**

<b>Effluent Limitations and Conditions</b>		
<b>Discharge Serial Number: DSN 201</b>		
<p>9a. Is this discharge described by any discharge categories listed in Appendix A, "Primary Industry Categories" of RCSA sections 22a-430-3 and 4?</p> <p><input checked="" type="checkbox"/> Yes      <input type="checkbox"/> No</p> <p>9b. Are there any treatment requirements established in RCSA section 22a-430-4(s)?</p> <p><input type="checkbox"/> Yes      <input checked="" type="checkbox"/> No</p> <p>10a. Is there an effluent limitation, standard, guideline, or categorical pretreatment standard established for this type of discharge in 40 CFR Parts 400-471 or elsewhere pursuant to 301, 306, 307, 318, 405 of the Clean Water Act?</p> <p><input checked="" type="checkbox"/> Yes      <input type="checkbox"/> No</p> <p>If you answered yes to question 10a, or 10b, or 11a, please complete the following table by providing the name of the discharge category and the specific citation to the regulation, if applicable, that establishes the limitation or condition.</p>		
Name of discharge category and appropriate citation from state and/or federal regulations.	Effluent limitation or condition: yes or no	Name of subpart and appropriate subpart citation
<i>Example:</i> Iron and Steel Manufacturing; 40 CFR Part 420, RCSA section 22a-430-4(s)	yes	Acid Pickling; 40 CFR Part 420: subpart I
<b>Steam Electric Power Generation; 40 CFR 423</b>	<b>yes</b>	<b>Pretreatment Standards for New Sources: 40 CFR 423.17</b>

**Part A: General Discharge Information (continued)**

Effluent Limitations and Conditions (continued)		Discharge Serial Number: DSN 201	
<p>10b. Are any of the effluent limitations applicable to the discharge expressed in terms of production?</p> <p><input type="checkbox"/> Yes     <input checked="" type="checkbox"/> No</p> <p>If yes, complete the following table. For existing discharge, list an actual measurement of your average or maximum level of daily production. For new discharges, list an average or maximum projected daily production. (Indicate in the table whether the production figures given are average or maximum level.) Express the production in the terms and units used in the applicable discharge limitation. Attach additional sheets if necessary.</p>			
Name of Category and Subpart	Name and Quantity of Product per Day with Units of Measure	Description of Process	No. of Cycles through Process
<i>Example:</i> Iron and Steel Manufacturing; Hydrochloric Acid Pickling	27,000 lbs of Stainless steel strips (average)	Stainless steel strips are passed through solder flux baths in #1 Tinner	2



**Attachment O: Discharge Information (continued)**

**Part B: Discharge Analysis**

All applicants must complete Part B, Tables 1 through 4 for each discharge. Be sure to review the instructions; specifically, "Testing Requirements for All Discharge Categories", Schedule A in the instructions under Attachment O before completing this part. In addition, please note that for existing discharges previously licensed by DEEP, identify the substances that were monitored in the existing permit by placing "PP" in the " Daily Composite or Grab Sample Results" column by the substance. For such substances, you need not repeat the analytical results in Tables 1 through 4, as long as such results are provided in Attachment W of the application.

**Please indicate whether the discharge analysis was based on (check one):**

- Projection       Actual wastewater       Wastewater from other similar discharge

All applicants must provide analysis results in column 1 for *all* the substances listed in Table 1 and other information needed to complete columns 2 and 3, for each discharge except the following: For discharges of non-contact cooling water, heat pump wastewaters and blowdown from heating and cooling equipment, provide analysis results for substances numbered in Table 1 as 3, 5, 6, and 11 through 16 only.

Table 1			
<b>Date Sampled:</b>	<b>Discharge Serial Number: DSN 201</b>		
GENERAL	1 Daily Composite or Grab Sample* Results	2 Number of Analyses	3 EPA** Method
1. Biochemical Oxygen Demand (5Day)	<50 ppm	NA	
2. Chemical Oxygen Demand	<100 ppm	NA	
3. Oil and Grease, Total*	< 25 ppm	NA	
4. Oil and Grease, Hydrocarbon Fraction*	< 25 ppm	NA	
5. Total Suspended Solids	< 100 ppm	NA	
6. Ammonia (as Nitrogen)	< 20 ppm	NA	
7. Phosphorus (Total)	< 25 ppm	NA	
8. Nitrate	< 10 ppm	NA	
9. Nitrite	< 0.1 ppm	NA	
10. Total Kjeldahl Nitrogen	< 25 ppm	NA	
11. Total Residual Chlorine*	< 1 ppm	NA	
12. Temperature (Winter and Summer)*	< 80 F < 110 F	NA	
13. pH (minimum and maximum)*	5.0 < pH < 12.0	NA	
14. Copper, Total	< 0.25 ppm	NA	
15. Lead, Total	< 0.1 ppm	NA	
16. Zinc, Total	< 2.0 ppm	NA	

\* Check the instructions under this part for the required method of sample collection.  
 \*\* For surface water discharges only, check the instructions for *required* EPA methods of analyses.

**Part B: Discharge Analysis (continued)**

All applicants must complete Table 2 for each discharge by placing an "X" in column 1, if applicable *and* by placing an "X" in column 2 or 3. If column 1 or 2 is marked for any substance, you *must* provide analysis results in column 4 for that substance and other information needed to complete columns 5 and 6 for that substance.

<b>Table 2</b>						
<b>Date Sampled:</b>		<b>Discharge Serial Number: DSN 201</b>				
<b>TOXIC METALS, CYANIDES, PHENOLS</b>	<b>1 Analysis Required by Schedule A - see Instructions</b>	<b>2 Known or Suspected Present</b>	<b>3 Believed Absent</b>	<b>4 Daily Composite or Grab Sample Results*</b>	<b>5 Number of Analyses</b>	<b>6 EPA** Method</b>
1. Antimony, Total		X		< 0.1 mg/l		
2. Arsenic, Total		X		< 0.05 mg/l		
3. Beryllium, Total		X		< 0.05 mg/l		
4. Cadmium, Total		X		< 0.05 mg/l		
5. Chromium, Total		X		< 0.2 mg/l		
6. Chromium,			X			
7. Mercury, Total			X			
8. Nickel, Total		X		< 0.1 mg/l		
9. Selenium, Total		X		< 0.1 mg/l		
10. Silver, Total		X		< 0.05 mg/l		
11. Thallium, Total		X		< 0.1 mg/l		
12. Cyanide, Total*			X			
13. Cyanide,			X			
14. Phenols, Total*			X			

**Part B: Discharge Analysis (continued)**

Table 2 (continued)						
Date Sampled:			Discharge Serial Number: DSN 201			
VOLATILES*	1 Analysis Required by Schedule A - see Instructions	2 Known or Suspected Present	3 Believed Absent	4 Daily Composite or Grab Sample Results*	5 Number of Analyses	6 EPA** Method
1. Acrolein			X			
2. Acrylonitrile			X			
3. Benzene			X			
4. Bromoform			X			
5. Carbon Tetrachloride			X			
6. Chlorobenzene			X			
7. Chlorodibromomethane			X			
8. Chloroethane			X			
9. 2-Chloroethylvinyl Ether			X			
10. Chloroform		X		< 0.02 mg/l		
11. Dichlorobromomethane			X			
12. 1, 1-Dichloroethane			X			
13. 1, 2-Dichloroethane			X			
14. 1, 1-Dichloroethylene			X			
15. 1, 2-Dichloropropane			X			
16. 1, 3-Dichloropropylene			X			
17. Ethylbenzene			X			
18. Methylbromide			X			
19. Methylchloride			X			
20. Methylene Chloride			X			
21. 1, 1, 2, 2,-Tetrachloroethane			X			
22. Tetrachloroethylene			X			
23. Toluene			X			
24. 1, 2-Trans-Dichloroethylene			X			

**Part B: Discharge Analysis (continued)**

Table 2 (continued)						
Date Sampled:		Discharge Serial Number: DSN 201				
VOLATILES*	1 Analysis Required by Schedule A - see Instructions	2 Known or Suspected Present	3 Believed Absent	4 Daily Composite or Grab Sample Results*	5 Number of Analyses	6 EPA** Method
25. 1, 1, 1-Trichloroethane			X			
26. 1, 1, 2- Trichloroethane			X			
27. Trichloroethylene			X			
28. Vinyl Chloride			X			
<b>GC/MS FRACTION ACID COMPOUNDS</b>						
1. 2-Chlorophenol			X			
2. 2, 4-Dichlorophenol			X			
3. 2, 4-Dimethylphenol			X			
4. 4, 6-Dinitro-O-Cresol			X			
5. 2, 4-Dinitrophenol			X			
6. 2-Nitrophenol			X			
7. 4-Nitrophenol			X			
8. P-Chloro-M-Cresol			X			
9. Pentachlorophenol			X			
10. Phenol			X			
11. 2, 4, 6- Trichlorophenol			X			
<b>BASE NEUTRAL COMPOUNDS</b>						
1. Acenaphthene			X			
2. Acenaphthylene			X			
3. Anthracene			X			
4. Benzidine			X			
5. Benzo(a)anthracene			X			
6. Benzo(a)pyrene			X			
7. 3, 4-Benzo-fluoranthene			X			

**Part B: Discharge Analysis (continued)**

Table 2 (continued)						
Date Sampled:		Discharge Serial Number: DSN 201				
BASE NEUTRAL COMPOUNDS	1 Analysis Required by Schedule A - see Instructions	2 Known or Suspected Present	3 Believed Absent	4 Daily Composite or Grab Sample Results*	5 Number of Analyses	6 EPA** Method
8. Benzo(ghi)perylene			X			
9. Benzo(k) fluoranthene			X			
10. Bis(2-Chloroethoxy) Methane			X			
11. Bis(2-Chloroethyl) Ether			X			
12. Bis(2-Chloroisopropyl) Ether			X			
13. Bis(2-Ethylhexyl) Phthalate			X			
14. 4-Bromophenylphenyl Ether			X			
15. Butylbenzyl Phthalate			X			
16. 2-Chloronaphthalene			X			
17. 4-Chlorophenylphenyl Ether			X			
18. Chrysene			X			
19. Dibenzo(a, H)anthracene			X			
20. 1, 2-Dichlorobenzene			X			
21. 1, 3-Dichlorobenzene			X			
22. 1, 4-Dichlorobenzene			X			
23. 3, 3-Dichlorobenzidine			X			
24. Diethyl phthalate			X			
25. Dimethyl phthalate			X			
26. Di-n-butyl phthalate			X			
27. 2, 4-Dinitrotoluene			X			
28. 2, 6-Dinitrotoluene			X			
29. Di-n-octyl phthalate			X			
30. 1, 2-Diphenylhydrazine (as Azobenzene)			X			
31. Fluoranthene			X			

**Part B: Discharge Analysis (continued)**

Table 2 (continued)						
Date Sampled:		Discharge Serial Number: DSN 201				
BASE NEUTRAL COMPOUNDS	1 Analysis Required by Schedule A - see Instructions	2 Known or Suspected Present	3 Believed Absent	4 Daily Composite or Grab Sample Results*	5 Number of Analyses	6 EPA** Method
32. Fluorene			X			
33. Hexachlorobenzene			X			
34. Hexachlorobutadiene			X			
35. Hexachlorocyclopentadiene			X			
36. Hexachloroethane			X			
37. Indeno(1,2,3-cd) Pyrene			X			
38. Isophorone			X			
39. Naphthalene			X			
40. Nitrobenzene			X			
41. N-nitroso dimethylamine			X			
42. N-Nitrosodi-n-Propylamine			X			
43. N-Nitrosodiphenylamine			X			
44. Phenanthrene			X			
45. Pyrene			X			
46. 1, 2,4-Trichlorobenzene			X			
<b>PESTICIDES</b>						
1. Aldrin			X			
2. Alpha - BHC			X			
3. Beta - BHC			X			
4. Gamma-BHC			X			
5. Delta-BHC			X			
6. Chlordane			X			
7. 4, 4-DDT			X			
8. 4, 4-DDE			X			

**Part B: Discharge Analysis (continued)**

Table 2 (continued)						
Date Sampled:			Discharge Serial Number: DSN 201			
PESTICIDES	1 Analysis Required by Schedule A - see Instructions	2 Known or Suspected Present	3 Believed Absent	4 Daily Composite or Grab Sample Results*	5 Number of Analyses	6 EPA** Method
9. 4, 4-DDD			X			
10. Dieldrin			X			
11. Alpha-Endosulfan			X			
12. Beta-Endosulfan			X			
13. Endosulfan Sulfate			X			
14. Endrin			X			
15. Endrin Aldehyde			X			
16. Heptachlor			X			
17. Heptachlor Epoxide			X			
18. PCB-1242			X			
19. PCB-1254			X			
20. PCB-1221			X			
21. PCB-1232			X			
22. PCB-1248			X			
23. PCB-1260			X			
24. PCB-1016			X			
25. Toxaphene			X			

**Part B: Discharge Analysis (continued)**

All applicants must complete Table 3 for each discharge by placing an "X" in either column 1 or 2. If column 1 is marked for any substance, you *must* provide analysis results for that substance in column 3 and other information needed to complete columns 4 and 5 for that substance.

Table 3					
Date Sampled:		Discharge Serial Number: DSN 201			
OTHER SUBSTANCES	1 Known or Suspected Present	2 Believed Absent	3 Daily Composite or Grab Sample Results*	4 Number of Analyses	5 EPA** Method
1. Bromide		X			
2. Color	X		< 40 C.U.		
3. Fecal Coliform*		X			
4. Fluoride	X		< 25 mg/l		
5. Nitrogen, Total Organic	X		< 25 mg/l		
6. Radioactivity		X			
a. Alpha, Total		X			
b. Beta, Total		X			
c. Radium, Total		X			
d. Radium, 226 Total		X			
7. Sulfate	X		< 500 mg/l		
8. Sulfide*		X			
9. Sulfite		X			
10. Surfactants		X			
11. Aluminum, Total	X		< 0.75 mg/l		
12. Barium, Total	X		< 0.5 mg./		
13. Boron, Total	X		< 0.5 mg/l		
14. Cobalt, Total		X			
15. Iron, Total	X		< 2.0 mg/l		
16. Magnesium, Total	X		< 100 mg/l		



**Part B: Discharge Analysis (continued)**

Table 3 (continued)					
Date Sampled:		Discharge Serial Number: DSN 201			
OTHER SUBSTANCES	1 Known or Suspected Present	2 Believed Absent	3 Daily Composite or Grab Sample Results*	4 Number of Analyses	5 EPA** Method
17. Molybdenum, Total		X			
18. Manganese, Total	X		< 0.2 mg/l		
19. Tin, Total		X			
20. Titanium, Total		X			
<b>OTHER TOXIC AND HAZARDOUS SUBSTANCES</b>					
1. Asbestos		X			
2. Acetaldehyde		X			
3. Allyl alcohol		X			
4. Allyl chloride		X			
5. Amyl acetate		X			
6. Aniline		X			
7. Benzotrile		X			
8. Benzyl chloride		X			
9. Butyl acetate		X			
10. Butylamine		X			
11. Captan		X			
12. Carbaryl		X			
13. Carbofuran		X			
14. Carbon disulfide		X			
15. Chlorpyrifos		X			
16. Coumaphos		X			
17. Cresol		X			
18. Crotonaldehyde		X			
19. Cyclohexane		X			

**Part B: Discharge Analysis (continued)**

Table 3 (continued)					
Date Sampled:		Discharge Serial Number: DSN 201			
OTHER TOXIC AND HAZARDOUS SUBSTANCES	1 Known or Suspected Present	2 Believed Absent	3 Daily Composite or Grab Sample Results*	4 Number of Analyses	5 EPA** Method
20. 2,4-Dichlorophenoxy (acetic acid)		X			
21. Diazinon		X			
22. Dicamba		X			
23. Dichlobenil		X			
24. Dichlone		X			
25. 2,2-Dichloro-propionic acid		X			
26. Dichlorvos		X			
27. Diethyl amine		X			
28. Dimethyl amine		X			
29. Dinitrobenzene		X			
30. Diquat		X			
31. Disulfoton		X			
32. Diuron		X			
33. Epichlorohydrin		X			
34. Ethanolamine		X			
35. Ethion		X			
36. Ethylene diamine		X			
37. Ethylene dibromide		X			
38. Formaldehyde		X			
39. Furfural		X			
40. Guthion		X			
41. Isoprene		X			
42. Isopropanolamine		X			
43. Kelthane		X			

**Part B: Discharge Analysis (continued)**

Table 3 (continued)					
Date Sampled:		Discharge Serial Number: DSN 201			
OTHER TOXIC AND HAZARDOUS SUBSTANCES	1 Known or Suspected Present	2 Believed Absent	3 Daily Composite or Grab Sample Results*	4 Number of Analyses	5 EPA** Method
44. Kepone		X			
45. Malathion		X			
46. Mercaptodimethur		X			
47. Methoxychlor		X			
48. Methyl mercaptan		X			
49. Methyl methacrylate		X			
50. Methyl parathion		X			
51. Mevinphos		X			
52. Mexacarbate		X			
53. Monoethyl amine		X			
54. Monomethyl amine		X			
55. Naled		X			
56. Napthenic acid		X			
57. Nitrotoluene		X			
58. Parathion		X			
59. Phenolsulfanate		X			
60. Phosgene		X			
61. Propargite		X			
62. Propylene oxide		X			
63. Pyrethrins		X			
64. Quinoline		X			
65. Resorcinol		X			
66. Strontium		X			
67. Strychnine		X			

**Part B: Discharge Analysis (continued)**

Table 3 (continued)					
Date Sampled:			Discharge Serial Number: DSN 201		
OTHER TOXIC AND HAZARDOUS SUBSTANCES	1 Known or Suspected Present	2 Believed Absent	3 Daily Composite or Grab Sample Results*	4 Number of Analyses	5 EPA** Method
68. Styrene		X			
69. 2, 4, 5-T (2, 4, 5-Trichlorophenoxy acetic acid)		X			
70. TDE (Tetrachlorodiphenylethane)		X			
71. 2, 4, 5-TP[2-(2, 4, 5-Trichlorophenoxy) propanoic acid]		X			
72. Trichlorofan		X			
73. Triethylamine		X			
74. Trimethylamine		X			
75. Uranium		X			
76. Vanadium		X			
77. Vinyl acetate		X			
78. Xylene		X			
79. Xylenol		X			
80. Zirconium		X			

**Part B: Discharge Analysis (continued)**

All applicants must complete Table 4 for each discharge, by placing an "X" in either column 1 or 2 for the substances numbered 1-6. If column 1 is marked for any substance, you *must* provide analysis results for that substance and any other information needed to complete columns 3 through 5 for that substance.

Date Sampled:		Table 4				
		Discharge Serial Number: DSN 201				
SUBSTANCES	1 Known or Suspected Present	2 Believed Absent	3 Daily Composite or Grab Sample Results*	4 Daily Number of Analyses	5 EPA** Method	
1. 2, 4,5-trichlorophenoxy acetic acid (2, 4, 5,-T)		X				
2. 2-(2, 4, 5-trichlorophenoxy) propanoic acid (Silvex, 2, 4, 5,-TP)		X				
3. 2-(2, 4, 5-trichlorophenoxy) ethyl, 2, 2-dichloropropionate (Erbon)		X				
4. 0, 0-dimethyl-0-(2, 4, 5-trichlorophenyl) phosphorothioate (Rannel)		X				
5. 2, 4, 5-trichlorophenol (TCP)		X				
6. hexachlorophene (HCP)		X				

In addition, if:

- 1) your facility uses or manufactures one of the substances listed above as items 1-6 or knows or has reason to believe or can reasonably ascertain that one of those substances may be present in the discharge; or
- 2) your facility has a discharge resulting from a process regulated under 40 CFR Part 430 - Pulp, Paper, and Paperboard Point Source Category; or
- 3) you know or have reason to believe or can reasonably ascertain that 2,3,7,8 - Tetrachlorodibenzo-p-dioxin (TCDD) may be present in the discharge;

you must also provide the analysis results for the dioxin and furan substances numbered 7 through 27, on the following page, using "EPA Method 1613: Tetra- through Octa- Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS".

**Part B: Discharge Analysis (continued)**

Table 4 (continued)			
Date Sampled:	Discharge Serial Number: Not Applicable		
SUBSTANCES	1 Daily Composite Sample Results*	2 Number of Analyses	3 EPA** Method
7. 2,3,7,8-TCDD (Tetrachlorodibenzo-p-dioxin)			
8. Total - TCDD			
9. 2,3,7,8-TCDF (Tetrachlorodibenzofuran)			
10. Total - TCDF			
11. 1,2,3,7,8-PeCDD (Pentachlorodibenzo-p-dioxin)			
12. Total - PeCDD			
13. 1,2,3,7,8-PeCDF (Pentachlorodibenzofuran)			
14. 2,3,4,7,8-PeCDF			
15. Total - PeCDF			
16. 1,2,3,4,7,8-HxCDD (Hexachlorodibenzo-p-dioxin)			
17. 1,2,3,6,7,8-HxCDD			
18. 1,2,3,7,8,9-HxCDD			
19. Total - HxCDD			
20. 1,2,3,6,7,8-HxCDF (Hexachlorodibenzofuran)			
21. 1,2,3,7,8,9-HxCDF			
22. Total - HxCDF			
23. 1,2,3,4,6,7,8-HpCDF (Heptachlorodibenzofuran)			
24. 1,2,3,4,7,8,9-HpCDF			
25. Total - HpCDF			
26. OCDD (Optachlorodibenzo-p-dioxin)			
27. OCDF (Hexachlorodibenzofuran)			



**Part B: Discharge Analysis (continued)**

<b>Table 6: Discharge Toxicity Evaluation</b>	<b>All Discharges</b>
<p>1. Except as provided below, all applicants for permits to discharge to a surface waterbody (i.e., for new and existing discharges) must perform a Discharge Toxicity Evaluation (DTE) in accordance with RCSA section 22a-430-4(c)(21)(B) and submit the results of the DTE as Attachment O, Table 6.</p> <p>2. Exceptions: A DTE need not be performed or submitted with this application <i>if</i>:</p> <ul style="list-style-type: none"> <li>a. this application for a permit is to discharge sewage from a POTW; or</li> <li>b. a DTE covering all discharges to surface waters at the site has been previously approved by DEEP; or</li> <li>c. the applicant has been specifically exempted from submission of a DTE for the discharge(s), in writing by DEEP, in accordance with RCSA section 22a-430-4(c)(21)(C), prior to submittal of this application. (see instructions)</li> </ul> <p>3. For discharges to a POTW, a DTE may be required depending on the nature of the discharge. In this case, you will be notified by DEEP after submitting your application.</p>	

If any of the analyses reported in Tables 1 through 6 of this application were performed by a contract laboratory or consulting firm, list the name, address and telephone number of the laboratory or firm and the type of analyses performed.

<b>Table 7: Contract Laboratory Identification</b>			<b>All Discharges</b>
<b>Name</b>	<b>Address</b>	<b>Telephone (Area Code &amp; No.)</b>	<b>Substances Analyzed (List)</b>
Not Applicable			