



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

August 9, 2017

Briony Angus, AICP
Senior Project Manager/Associate
Tighe & Bond
213 Court Street, Suite 1100
Middletown, CT 06457

RE: **PETITION NO. 1224** – Woods Hill Solar, LLC declaratory ruling that no Certificate of Environmental Compatibility and Public Need is required for the proposed construction, maintenance and operation of a 17.61 Megawatt AC Solar Photovoltaic Electric Generating facility located at 90 and 101 Woods Hill Road, Pomfret, Connecticut.

Dear Ms. Angus:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than August 23, 2017. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as a copy via electronic mail. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Yours very truly,

Melanie A. Bachman
Executive Director

MB/CW

c: Council Members

Lee Hoffman, Esq., Pullman & Comley

Petition No. 1224
D&M Plan Interrogatories
August 9, 2017

1. Electrical Construction Plan Set drawings are included in the Development and Management Plan submission. Please provide a drawing showing the AC electric line from the solar facility transformer to its interconnection to the electric grid outside of the facility boundaries. Indicate on the drawing whether such line is overhead, underground or some combination thereof. If overhead, include the pole heights on the subject property.