




Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051
Attn: Robert Stein, Chairman

November 21, 2017

Re: Request for Consideration of Changes
Petition No. 1234



Dear Chairman Stein,

On July 16, 2016, the Connecticut Siting Council ("Council") issued a Declaratory Ruling to SolarCity Corporation that no Certificate of Environmental Compatibility and Public Need is required for the construction, maintenance and operation of an approximately 2.8 megawatt solar voltaic electric generating facility located at the Becton, Dickinson & Company, 7 Grace Way, North Canaan, Connecticut. Subsequently, the Council then considered and approved this project's Development and Management ("D&M") Plan on September 29, 2016.

In accordance with the Regulations of Connecticut State Agencies Section 16-50j-62, we respectfully request the Council consider the following proposed changes.

1. Transfer of Ownership of the Council's Declaratory Ruling from SolarCity Corporation to:

DG Connecticut Solar, LLC,
700 Universe Blvd, C1A/JB
West Palm Beach, FL 33408

Point of contact for this project is Mithun Vyas, who can be reached at 561-694-3842 or via email at Mithun.vyas@nexteraenergy.com.

2. D&M Plan Modifications - As a result of the new owner's review of site and design constraints, the ground-mounted solar arrays necessitate minor changes to meet their electrical output requirements. The proposed modifications to the approved D&M Plan include:

- Removal of the eastern ground-mounted solar panel array (a total of 756 panels) and associated improvements;
- Reduction of the western ground mounted solar panel array from 6,404 to 4,680 panels;
- Revision to layout and clearing limits of the western array to minimize shading, resulting in an increase of the total project clearing from +/-9.0 acres to +/-9.9 acres; and,
- Revision to Sedimentation and Erosion Control Plans due to the time of year construction.

ALL-POINTS TECHNOLOGY CORPORATION, P.C.

3 SADDLEBROOK DRIVE · KILLINGWORTH, CT 06419 · PHONE 860-663-1697 · FAX 860-663-0935

P.O. BOX 504 · 116 GRANDVIEW ROAD · CONWAY, NH 03818 · PHONE 603-496-5853 · FAX 603-447-2124

The proposed modifications to the approved D&M Plan are depicted on the attached Revised D&M Plan. We respectfully request the Council review and approve the modified D&M Plan.


These proposed modifications do not substantially change post-development effects on the environment. Please refer to the enclosed Connecticut Department of Energy & Environmental Protection Natural Diversity Data Base Consultation Update, dated November 21, 2017. It is our professional opinion that the proposed project modifications represent a de minimis change from the previously approved D&M Plan and will result in no likely adverse impacts to wetlands, vernal pools or State-listed species.

Additionally, although not technically part of the D&M Plan, we would like to notify the Council that the Stormwater Pollution Control Plan that was prepared for the CT DEEP's *General Permit Registration for the Discharge of Stormwater and Dewatering Wastewaters from Construction Activities* (Application No. 201609557, Permit No. GSN003069) has also been revised to reflect the proposed changes, in accordance with Section 5(b)(5) "Keeping Plans Current" of this permit. A copy of the revised Stormwater Report is provided as an attachment.

If you have any questions or require additional information, please contact me at (860) 983-5153 or via email at mibertine@allpointstech.com.

Thank you in advance for your consideration.

Sincerely,
All-Points Technology Corporation, P.C.



Bradley J. Parsons, P.E. on behalf of

Michael Libertine
Director of Siting and Permitting

Attachments

- Revised D&M Plan
- DEEP NDDB Consultation Update
- Revised Stormwater Report
- Project Overview Map (Showing Originally Approved and Revised Project limits)