



56 Prospect Street
P.O. Box 270
Hartford, CT 06103

Kathleen M. Shanley
Manager – Transmission Siting
Tel: (860) 728-4527

December 11, 2017

Robert Stein, Chairman
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

Re: Petition No. 1286
West Brookfield Reliability Project
Monthly Construction Progress Report – November 2017

Dear Chairman Stein:

On behalf of The Connecticut Light and Power Company dba Eversource Energy (“Eversource”) and pursuant to the Development and Management Plan specific to the West Brookfield substation expansion, Eversource hereby provides a copy of the Monthly Construction Progress Report for the month of November 2017.

The Project Construction Progress Table is also included in Attachment 1.

Please contact me at (860)728-4527 with any questions that you and other Council member may have on this report.

Sincerely,

A handwritten signature in blue ink, appearing to read "Kathleen M. Shanley".

Enclosures

Petition 1286
West Brookfield Reliability Project
Monthly Construction Progress Report
November 2017

WEST BROOKFIELD SUBSTATION

Above-ground conduit and grounding are 100% complete. All control cables have been pulled. Ninety percent of all pulled cable conductors are either terminated or staged for termination during the outage starting December 11th.

The 115-kV cable has been pulled, terminated and tested. The circuit breaker, circuit switchers and capacitors have been tested.

MINOR D&M PLAN CHANGES

None

Attachment 1 Petition 1286 West Brookfield Reliability Project November 2017 Monthly Construction Progress Report	
Substation Construction	
Site Development	100%
Foundation Installation	100%
Steel Erection	100%
Capacitor Installation	10%
Cable Installation	95%
Test Energization	30%
Total % Complete	80%