

March 7, 2019

Melanie Bachman, Executive Director  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, CT 06051

Re: Sub-Petition No. 1293-MGHACL-01

Dear Ms. Bachman:

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is filing the attached Sub-Petition No. 1293-MGHACL-01 with the Connecticut Siting Council ("Council"), regarding maintenance work within its transmission right-of-way in Manchester, Glastonbury, Hebron, Andover, Columbia, and Lebanon, Connecticut. The work includes replacing 35 existing wooden transmission structures with new weathering steel transmission structures.

Eversource notified the officials of the municipalities of Manchester, Glastonbury, Hebron, Andover, Columbia, and Lebanon of Eversource's submission of the Sub-Petition and sent copies of the Sub-Petition to owners of directly abutting properties (see Proof of Notice).

Enclosed please find an original and 3 copies of this filing.

Please contact me at 860-728-4527 if you have any questions regarding the enclosed Sub-Petition.

Sincerely,



Enclosures

Attachments:

Exhibit A: Sub-Petition

Exhibit B: Photographs and Photo Simulation

Exhibit C: Maps

Exhibit D: Abutter Letter and Proof of Notice

**ATTACHMENT A**  
**SUB-PETITION**

**THE CONNECTICUT LIGHT AND POWER COMPANY doing business as  
EVERSOURCE ENERGY**

Sub-Petition  
CONNECTICUT SITING COUNCIL – PETITION NO. 1293  
TRANSMISSION FACILITY ASSET CONDITION  
MAINTENANCE IMPROVEMENTS TO COMPLY  
WITH THE UPDATED NATIONAL ELECTRIC  
SAFETY CODE CLEARANCE REQUIREMENTS

Towns: Manchester, Glastonbury, Hebron, Andover, Columbia and Lebanon

Sub-Petition No. 1293-MGHACL-01

Project: 310/368 Transmission Line Structure Replacement Project

Structure Locations: 35 Transmission Structures located in Manchester, Glastonbury, Hebron, Andover, Columbia and Lebanon, Connecticut

I. Introduction:

In accordance with Condition 1 of the March 30, 2017 ruling by the Connecticut Siting Council (the "Council") (as set forth in the Council's March 31, 2017 letter) regarding Petition No. 1293, The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") submits this Sub-Petition.

II. Description of Transmission Work Activities:

Eversource's 310/368 Transmission Line Structure Replacement Project is part of an ongoing maintenance program which evaluates the integrity of its utility structures and implements repair, upgrade or replacement in order to ensure the safe and reliable transmission of power to its customers. Due to asset condition, many structures require replacement on portions of the 310 and 368 Lines between Shallow Brook Lane in Manchester and Village Hill Road in Lebanon where both lines occupy the same right-of-way. The 310 Line in its entirety, is a 345-kV transmission line that extends from Manchester Substation in Manchester, to Millstone Substation in Waterford. The 368 Line in its entirety, is a 345-kV transmission line that extends from Manchester Substation to Card Substation in Lebanon. Of these replacements, 35 structures require a slight increase in structure height to comply with current clearance requirements. The 35 structures to be replaced are a mix of wood H-frame and monopole structures.

Eversource plans to conduct transmission structure replacement work to remediate structure damage caused by structure age, weather, and woodpecker activity. The following work ("Work Activities") will be performed:

- Replace 35 existing wood structures with new weathering steel structures. Each replacement structure will be of the same design as its corresponding existing structure, though slightly taller (10 feet or less) than the existing structures. The replacement structures will be installed within 15 feet of the existing structure locations.

III. No Substantial Adverse Environmental Effect:

Eversource respectfully submits that the proposed modifications would have no "substantial adverse environmental effect" pursuant to Conn. Gen. Stat. § 16-50k, based on the following factors:

- a) Work Activities would take place in areas within Eversource's property and existing right-of-way ("ROW") utilizing existing and proposed new permanent access roads, as well as some temporary access roads (collectively the "Work Areas"). Some of the existing access roads will be improved. Eversource can access the structure locations utilizing its existing rights but it is currently working with a private landowner to obtain rights to utilize an alternative off-ROW access route that would minimize the amount of proposed permanent and temporary access roads that would need to be installed within the ROW and lessen the impact to an agricultural area and wetland.
- b) Work Activities would currently result in approximately 18,135 square feet ("SF") of temporary wetland impacts, limited to temporary construction matting required for the construction of work pads for Structures 18067, 18100, 18111, 29228 and 29199 and the access road to structure 18142.

<b>Structure Number</b>	<b>Construction Work Pads Temporary Wetland Impacts (SF)</b>	<b>Access Roads Temporary Wetland Impacts (SF)</b>
18067	±770	0
18100	±5,255	0
18111	±895	0
29228	±2,455	0
29199	±655	0
18142	0	±8,095
<i>Subtotals:</i>	<i>±10,040</i>	<i>±8,095</i>
<b>TOTAL:</b>	<b>±18,135</b>	

Work would be conducted in accordance with Eversource's *Best Management Practices Manual for Massachusetts and Connecticut (Construction and Maintenance Environmental Requirements)*, September 2016 ("BMPs") to avoid impact to nearby wetland and watercourse resources.

- c) No vernal pools are located in proximity to the Work Activities.
- d) As a result of Eversource's review of the Connecticut Department of Energy and Environmental Protection's ("CTDEEP") Natural Diversity Data Base ("NDDB"), only the Work Activities associated with Structure 18100 are proposed within an NDDB buffered area and wetland jurisdictional area and/or CTDEEP owned/managed land and therefore would be subject to an NDDB review request. Eversource submitted an NDDB review request to CTDEEP on November 2, 2018 and received a response from NDDB on January 25, 2019 with recommendations for the protection of rare species potentially present. Eversource will adhere to the protective measures recommended by CTDEEP for the protection of any potential rare species and will incorporate those measures into the Company's BMPs during construction. Therefore, no adverse impact to rare species will result from activities proposed in the Work Areas.

- e) The Work Activities will not require any tree clearing. However, Eversource may need to undertake minor tree trimming and/or vegetation removal/mowing within the managed ROW corridor to improve access to portions of the Work Areas.
- f) A Phase 1A assessment review of previously recorded cultural resources on file with the Connecticut State Historic Preservation Office conducted by Heritage Consultants, LLC ("Heritage") did not identify that any National or State Register of Historic Places properties/districts are located within 500 feet of the Work Areas. Based on a review of historic maps, aerial photographs, and available soil profiles, 27 of the proposed work pad locations and 3 of the access roads were identified to possess a potential for moderate to high archaeological sensitivity. These locations were evaluated in the field with a pedestrian survey by a representative from Heritage and 13 of the work pad locations and 1 access road were found to have the potential for moderate to high archaeological sensitivity. A Phase 1B cultural reconnaissance survey (shovel pit testing) was conducted at each of these locations and except for the proposed work pad at Structure 18080, no physical evidence of archaeological significance was found at these locations. A Phase II cultural investigation was then conducted at the Structure 18080 work pad location. The horizontal and vertical boundaries at the structure replacement location were delineated and temporal diagnostic artifacts and intact cultural deposits were recovered during the Phase II investigation. A copy of the Phase II report prepared by Heritage has been forwarded to SHPO and a response is forthcoming. To avoid impacts, the work pad for Structure 18080 will be matted during construction so that no ground disturbance, beyond that for structure replacement, occurs. Eversource will adhere to any further protective measures put forth by SHPO. As a result of the completed investigations and the proposed protective measures the Project will have no effect on cultural resources.
- g) Increased heights of the 15 replacement structures average approximately 5 feet and none will exceed 10 feet.
- h) Replacement structures would be located within 15 feet of existing structures.
- i) There are no 100-year flood zones in the Work Areas.
- j) No change in noise levels would result from the installation of the replacement structures and the line would continue to comply with the State of Connecticut noise regulations.
- k) Any changes in electric and magnetic field levels outside of the ROW would be negligible.

#### IV. Mitigation:

Temporary environmental effects from construction will be mitigated as follows:

- Erosion and sediment controls ("E&S") will be employed and maintained, as needed, throughout the execution of the Work Activities in accordance with the 2002 Connecticut Guidelines for Soil Erosion and Sediment Control and the BMPs.
- Potential impacts to wetlands and watercourses will be mitigated with the use of temporary construction matting and adherence to the BMPs.
- NDDB recommended rare species protective measures will be incorporated into the Company's BMPs during construction.

- The work pad for structure 18080 will be matted to prevent ground disturbance and avoid any potential impacts to cultural resources.
- Eversource's contractor will perform construction sequencing such that any earth materials are exposed for a minimum amount of time before they are covered, seeded, or otherwise stabilized to prevent erosion.
- During construction, when necessary, anti-tracking mats would be installed at construction entrances onto public roads to prevent tracking of soil onto local streets.
- Upon completion of the Work Activities, all disturbed/exposed areas would be stabilized and revegetated. After the establishment of permanent ground cover, Eversource's contractor would remove the temporary E&S controls and remove/dispose of any accumulated sediments and debris from areas where such measures were used.

V. Access:

Some new permanent access roads would be constructed to facilitate access to structures within the ROW and existing access roads may be hardened and widened at turning areas to facilitate the safe passage of construction vehicles. Construction matting would be used on temporary access roads in wetlands as well as in agricultural/maintained lawn upland areas. The matting will be removed upon completion of the Work Activities and the areas restored, as necessary.

Eversource would access the Work Areas by entering its ROW from existing access points on public roads as follows:

- Manchester Road for structures 18030 and 18031
- Mountain Road for structures 18033, 18137 and 29298
- Birch Mountain Road for structures 18049, 29275 and 29274
- North Street for structures 18067, 29273, 18068, 18080, 18081 and 29258
- East street for structures 18087 and 18089
- Cone Road for structures 18100 and 18102
- Hebron Road for structure 29233
- West Street for structures 18109, 18111, 29228, 18113, 18115, 18118 and 29222
- Henequin Road for structure 18123
- Jones Road for structures 18141, 29199, 18142, 29198, 18144, 29195 and 18147 (off-ROW access from Szedga Road would be used for structures 18141, 29199, 18142 and 29198 if rights are obtained)
- Village Hill Road for structure 18159

By:

  
 Kathleen M. Shanley  
 Manager - Transmission Siting

**ATTACHMENT B**  
**PHOTOGRAPHS AND**  
**PHOTO SIMULATION**

Structure #18026



Wood Pecker Damage

Spit Pole


Structure #18043



Structure #18092



Structure #18157



Age Related Decay/Rot

Split Pole

Woodpecker Damage



**EXISTING**

368 LINE

**STRUCTURE 18111**

LOCATION

**WEST STREET EXTENSION  
COLUMBIA, CT**

ORIENTATION

**WEST**



**ALL-POINTS  
TECHNOLOGY CORPORATION**



**EVERSOURCE  
ENERGY**



**PROPOSED**

368 LINE

**STRUCTURE 18111**

LOCATION

**WEST STREET EXTENSION  
COLUMBIA, CT**

ORIENTATION

**WEST**



**ALL-POINTS  
TECHNOLOGY CORPORATION**



**EVERSOURCE  
ENERGY**

**ATTACHMENT C**


**MAPS**

# 310/368 LINE STRUCTURE REPLACEMENT PROJECT

Manchester, Glastonbury, Hebron, Andover, Columbia & Lebanon, CT

Sub-Petition Map Set

Revised Date: February 28, 2019



PREPARED FOR:  
**EVERSOURCE ENERGY**  
 107 Seiden Street  
 Berlin, CT 06037

INDEX OF FIGURES  
 TITLE SHEET / INDEX MAP  
 MAP SHEETS 1-22  
 ABUTTER TABLES

PREPARED BY:  
**BSC GROUP**  
 33 Waldo Street  
 Worcester, MA 01608

**310/368 Line Structure Replacement Project  
Map Sheet 1 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
166	SALVATORE & CAROL A. ABBATIello	52 SHALLOWBROOK LANE	MANCHESTER	CT	06040
167	MICHAEL J. JR & GINA D. SILVESTER	24 SHALLOWBROOK LANE	MANCHESTER	CT	06040
200	MICHAEL J. JR. & GINA D SILVESTER	2155 MANCHESTER ROAD	GLASTONBURY	CT	06033
202	CAROL & SALVATORE ABBATIello	52 SHALLOWBROOK LANE	GLASTONBURY	CT	06033
203	RAYMOND FRANCIS HEALY & JUDITH Z. HEALY	21371A MANCHESTER ROAD	GLASTONBURY	CT	06033
207	CONNECTICUT LIGHT & POWER CO.	2134 MANCHESTER ROAD	GLASTONBURY	CT	06033
209	CONNECTICUT LIGHT & POWER CO.	2142 MANCHESTER ROAD	GLASTONBURY	CT	06033
212	CONNECTICUT LIGHT & POWER CO.	LINE STREET	GLASTONBURY	CT	06033
220	CONNECTICUT LIGHT & POWER CO.	LINE STREET	GLASTONBURY	CT	06033



**310/368 Line Structure Replacement Project  
Map Sheet 2 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
220	CONNECTICUT LIGHT & POWER CO.	LINE STREET	GLASTONBURY	CT	06033
223	CONNECTICUT LIGHT & POWER CO.	MOUNTAIN ROAD	GLASTONBURY	CT	06033



**310/368 Line Structure Replacement Project  
Map Sheet 3 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
223	CONNECTICUT LIGHT & POWER CO.	MOUNTAIN ROAD	GLASTONBURY	CT	06033
226	TOWN OF MANCHESTER WATER DEPT	OLD HEBRON ROAD	GLASTONBURY	CT	06033



**310/368 Line Structure Replacement Project  
Map Sheet 4 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
231	TOWN OF MANCHESTER WATER DEPT	333 BIRCH MOUNTAIN RD	GLASTONBURY	CT	06033



**310/368 Line Structure Replacement Project  
Map Sheet 5 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
231	TOWN OF MANCHESTER WATER DEPT	333 BIRCH MOUNTAIN RD	GLASTONBURY	CT	06033



**310/368 Line Structure Replacement Project  
Map Sheet 6 Abutters List**

INTENTIONALLY LEFT BLANK  
NO ABUTTERS TO JURISDICTIONAL WORK AREAS



**310/368 Line Structure Replacement Project  
Map Sheet 7 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
313	STATE OF CONNECTICUT DEP	FOOTE LANE	HEBRON	CT	06248



**310/368 Line Structure Replacement Project  
Map Sheet 8 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
313	STATE OF CONNECTICUT DEP	FOOTE LANE	HEBRON	CT	06248
314	STATE OF CONNECTICUT	435 NORTH STREET	HEBRON	CT	06248



**310/368 Line Structure Replacement Project  
Map Sheet 9 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
309	CONNECTICUT LIGHT & POWER CO	NORTH STREET	HEBRON	CT	06248



**310/368 Line Structure Replacement Project  
Map Sheet 10 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
309	CONNECTICUT LIGHT & POWER CO	NORTH STREET	HEBRON	CT	06248



**310/368 Line Structure Replacement Project  
Map Sheet 11 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
309	CONNECTICUT LIGHT & POWER CO	NORTH STREET	HEBRON	CT	06248



**310/368 Line Structure Replacement Project  
Map Sheet 12 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
309	CONNECTICUT LIGHT & POWER CO	NORTH STREET	HEBRON	CT	06248
328	HARTFORD NEIGHBORHOOD CENTERS INC	444 EAST STREET	HEBRON	CT	06248
400	HARTFORD NEIGHBORHOOD CENTERS	EAST ST	ANDOVER	CT	06232



**310/368 Line Structure Replacement Project  
Map Sheet 13 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
400	HARTFORD NEIGHBORHOOD CENTERS	EAST ST	ANDOVER	CT	06232



**310/368 Line Structure Replacement Project  
Map Sheet 14 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
421	CONNECTICUT LIGHT & POWER	CONE RD	ANDOVER	CT	06232
422	CONNECTICUT LIGHT & POWER	HEBRON RD	ANDOVER	CT	06232



**310/368 Line Structure Replacement Project  
Map Sheet 15 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
422	CONNECTICUT LIGHT & POWER	HEBRON RD	ANDOVER	CT	06232
439	CONNECTICUT LIGHT & POWER	BAUSOLA RD	ANDOVER	CT	06232
444	CONNECTICUT LIGHT & POWER	HEBRON RD	ANDOVER	CT	06232



**310/368 Line Structure Replacement Project  
Map Sheet 16 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
444	CONNECTICUT LIGHT & POWER	HEBRON RD	ANDOVER	CT	06232
500	CONNECTICUT LIGHT & POWER	WEST ST	COLUMBIA	CT	06237
501	CONNECTICUT LIGHT & POWER	WEST ST	COLUMBIA	CT	06237
505	CONNECTICUT LIGHT & POWER	WEST ST	COLUMBIA	CT	06237
508.01	KRISTEN COBB	114 WEST ST	COLUMBIA	CT	06237



**310/368 Line Structure Replacement Project  
Map Sheet 17 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
508.01	KRISTEN COBB	114 WEST ST	COLUMBIA	CT	06237
511	CONNECTICUT LIGHT & POWER	LAKE RD	COLUMBIA	CT	06237
512	JUDITH BASKIN	114 LAKE RD	COLUMBIA	CT	06237
515	KRISTEN COBB	LAKE RD	COLUMBIA	CT	06237



**310/368 Line Structure Replacement Project  
Map Sheet 18 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
524	JOSHUA TRACT CONSERVATION & HISTORIC TRUST	LAKE RD	COLUMBIA	CT	06237



**310/368 Line Structure Replacement Project  
Map Sheet 19 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
573	TOWN OF COLUMBIA	40 SZEGDA RD	COLUMBIA	CT	06237
574	HERMINO & LINDA DECASTRO	437 RT 87 EAST	COLUMBIA	CT	06237
575	LOUIS BACON	JOHNSON RD	COLUMBIA	CT	06237



**310/368 Line Structure Replacement Project  
Map Sheet 20 Abutters List**


Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
573	TOWN OF COLUMBIA	40 SZEGDA RD	COLUMBIA	CT	06237
574	HERMINO & LINDA DECASTRO	437 RT 87 EAST	COLUMBIA	CT	06237
575	LOUIS BACON	JOHNSON RD	COLUMBIA	CT	06237
576	DARBY POLLANSKY	JOHNSON RD	COLUMBIA	CT	06237



**310/368 Line Structure Replacement Project  
Map Sheet 21 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
576	DARBY POLLANSKY	JOHNSON RD	COLUMBIA	CT	06237

Path: \\bos\w\GIS\WORK\GISP\1898635-310\report\Map\SubPetitionLine310\_368SR2019\_SubPetition\_ER\_20181115.mxd  
 Date Saved: 2/28/2019 12:46:27 PM



**Legend**

- Existing Structure
- Proposed Structure
- Existing Structure to be Removed
- Existing Access
- Proposed Access
- Proposed Alternate Access
- Access Road to be Improved
- Stone Work Pad
- Temporary Construction Matting

- ▬ Delineated Intermittent Watercourse
- ▬ Delineated Perennial Watercourse
- ▬ Delineated Wetland Boundary
- ▬ Field Delineated Wetland
- ▬ Approximate Wetland
- ▬ NDDB Area December 2018
- ▬ FEMA 100 year Flood Zone
- ▬ State Owned Property

- ▬ Eversource Owned Property
- ▬ Municipal Boundary
- ▬ LL #100 LLN/Property Owner
- ▬ Existing Right of Way
- ▬ 10' Contours
- ▬ 2' Contours
- ▬ Gate
- ▬ Approx Gas Line

- ▬ Hiking Trail
- Culvert
- ▬ Stone Wall

1 inch = 200 feet

**Index Map**

**310/368 LINE**

**STRUCTURE REPLACEMENT PROJECT**

**Sub-Petition Map Set**

**February 28, 2019**

**Columbia, CT**

**Page 21 of 22**

Source: CT DEEP - Eversource Data  
 Aerial & Topography  
 ESRI: DigitalGlobe, GeoEye, -imagery,  
 Microsoft, CNES, Airphoto, USDA,  
 Aerial & Topography  
 GEBCO: FAO, NGS, GEBCO, CNES, Airphoto,  
 N. Orange Survey, ESRI Japan, METI,  
 GeoEye, GeoEye, -imagery, -imagery,  
 GIS User Community

THIS DOCUMENT IS INTENDED FOR GENERAL PLANNING & INFORMATION PURPOSES ONLY. ALL MEASUREMENTS & LOCATIONS ARE APPROXIMATE.

**310/368 Line Structure Replacement Project  
Map Sheet 22 Abutters List**

Line List Number	Owner Name	Parcel Address	Parcel Town	Parcel State	Parcel Zip Code
608	JOHN KRAUSE & FREDRICK TYSON KRAUSE	38 KRAUSE RD	LEBANON	CT	06249



**ATTACHMENT D**  
**ABUTTER LETTER AND**  
**PROOF OF NOTICE**

March 7, 2019

Dear Neighbor,

As part of our everyday effort to deliver reliable energy to our customers and communities, we're planning work in your area to replace electric transmission structures. Maintaining the infrastructure that supports the electric lines is one of the ways Eversource ensures the safe, secure transmission of electricity throughout the region.

You're receiving this letter and a copy of the Sub-Petition because the proposed work would be taking place within the right of way on or near your property in Manchester, Glastonbury, Hebron, Andover, Columbia and Lebanon. A Sub-Petition is a document with detailed information about the proposed upgrades. Eversource is submitting Sub-Petition 1293-MGHACL-01 this week to the Connecticut Siting Council (CSC) for its review and approval.

**About This Electric System Improvement: What You Can Expect**

First, we want you to know that this work will not interrupt electric service to your property.

As part of this project, we are proposing to replace, and slightly increase the height of the existing wood structures. The new, weathering steel structures will increase in height by 9 feet or less, depending on the location.

We are proposing to do the work within the existing rights of way on or near your property. The new structures will provide continued reliability of the transmission system.

**Connecticut Siting Council Process and Timing**

With this letter, Eversource is providing notice to you of its proposed work activity, as described in the enclosed Sub-Petition. If you have any comments or concerns about the project, please send them to the CSC at the following address within 30 days of the date of this letter: Melanie Bachman, Acting Executive Director; Connecticut Siting Council; Ten Franklin Square; New Britain, CT 06051. You may also email them to the [siting.council@ct.gov](mailto:siting.council@ct.gov). If you choose to send comments to the CSC, please reference Sub-Petition 1293-MGHACL-01 in your correspondence.

**Our Commitment to You**

We are committed to being a good neighbor and doing our work with respect for you and your property. If you would like more information about this work please call 1-800-793-2202, or send an email to [TransmissionInfo@eversource.com](mailto:TransmissionInfo@eversource.com). Thank you.

Sincerely,

*Brian Ragozzine*

Brian Ragozzine  
Eversource Project Manager – Transmission Projects

