


Exhibit 2

Part 2



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



Ian & Sandra Clifford
10 County Road
Simsbury, CT 06070

June 16, 2011

RE: Drinking Water Supply Analysis

Dear Residents:

Enclosed is a copy of the laboratory analysis for the raw water sample collected from 10 County Road on April 6th, 2011. The water samples were analyzed using EPA test method 504.1 for the presence of 1,2 -Dibromoethane (EDB), 1,2-Dibromo-3-Chloropropone (DBCP), 1,2,3-Trichloropropane (TCP) all of which are agricultural pesticides.

The summary table below includes each compound's respective action level set by the Connecticut Department of Public Health (DPH). If an action level has not established for that particular compound, its detection does not render the water unsafe for drinking or other domestic uses. The summary table also indicates the compound concentrations that were detected. ND indicates None Detected.

COMPOUND	RAW WATER CONCENTRATION MICROGRAMS PER LITER (μ g /L)	DRINKING WATER ACTION LEVEL (μ g /L)
1,2 -Dibromoethane (EDB)	ND	0.05
1,2-Dibromo-3-Chloropropone (DBCP)	ND	None established
1,2,3-Trichloropropane (TCP)	ND	0.05

The raw water collected from the kitchen tap contained 0 μ g/L pesticides. Consequently, the water is potable (suitable for human consumption) with respect to these constituents analyzed.

If you have any further questions regarding these results, please do not hesitate to contact me at (860) 424-3796. You may also contact the Connecticut DPH Division of Environmental Epidemiology & Occupational Health at (860) 509-7742 for additional information about the toxicity of specific chemicals found in drinking water.

Sincerely,

MaryAnne Danyluk
Environmental Analyst 2
Remediation Division
Bureau of Water Protection and Land Reuse
Enclosure



STATE OF CONNECTICUT

Department of Public Health Laboratory
 Clinical Testing License: CL-0197
 10 Clinton St.
 P.O. Box 1689
 Hartford, CT 06144
 Telephone (860) 509-8500

I.D.	ACCESSION NO.	ACCOUNT NO.	AGE	S.	PAGE
NR:10	18025496	A00142	0.		1
INFORMATION					
128SIMSBURY IAN&SANDRA CLIFFORD 10 COUNTY RD SIMSBURY CT					
	COLLECTED	RECEIVED	REPORTED		
	04/06/11 12:00	04/07/11 10:48	04/19/11 08:08		

DEP - REMEDIATION

79 ELM ST.
HARTFORD CT 06106

REPORT	FINAL REPORT	COMMENT	
TEST(S)	RESULT(S)		
	SAMPLING POINT: KITCHEN COLLECTOR: BRIGHTWELL TITLE: COMP. SPECIALIST PRIVATE WELL TREATMENT:		
*** DATE ANALYZED	4/14/11		
EPA 504.1	EPA METHOD 504.1 MEASUREMENT OF 1,2-DIBROMOETHANE (EDB), 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) AND 1,2,3-TRICHLOROPROPANE (123TCP) IN DRINKING WATER BY MICROEXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON CAPTURE DETECTION. Final Result: [All values expressed in $\mu\text{g/L}$ (ppb)] Compound Result MDL PQL 1,2-Dibromoethane ND 0.004 0.02 1,2-Dibromo-3-Chloropropane ND 0.004 0.02 1,2,3-Trichloropropane ND 0.004 0.04 ND = None Detected (Result Less Than The PQL) PQL = Practical Quantitation Limit (lowest standard) MDL = method Detection Limit MDL calculated based on a Signal/Noise Ratio of 5:1 according to CFR Part 136 Appendix B		
APR 17 2011 WATER QUALITY LABORATORY DEPARTMENT OF PUBLIC HEALTH			

** END OF REPORT **

REQUEST FOR ORGANICS / RADIATION WATER EXAMINATION



STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH LABORATORY
PO BOX 1689, HARTFORD, CONNECTICUT 06144
10 CLINTON STREET, HARTFORD, CONNECTICUT 06106

APR - 7 AM 10:48

m/t

Organic Chemistry Section: (860) 509-8547 / Special Chemistry Section: (860) 509-8535

1802 5496-3	Bottles Received 3V105	100142
<input type="checkbox"/> PUBLIC <input checked="" type="checkbox"/> PRIVATE		REASON
<i>R. V. Vassel</i>		

TO BE COMPLETED BY COLLECTOR

Town Number 128	Date Collected (MM/DD/YYMM) 04/06/2011	Time Collected (Military Time) 1200 HRS
Name of Utility or Property Owner IAN & SANDRA C. JEFFORD	Collector's Sample Number 10	
Source Kitchen	Address of Sample Collection 10 COUNTY RD	
Collected By Brightwell	Collector's Title Compliance Specialist	
Collector's Phone Number 424-3293	Town and State of Sample Collection Simsbury, CT	Zip Code 06076-0000

REMARKS (Additional Information: Complaints, Requests, Treatments, Etc.)


WATER TEST REQUEST

ORGANICS

- 100J EPA 524.2 VOLATILE ORGANICS
- 010H EPA 504.1 EDB AND DBCP
- 183O EPA 525.2 SEMI-VOLATILE ORGANICS
- 106O EPA 505 ORGANOCHLORINE PESTICIDES
- 176O EPA 515.3 CHLORINATED HERBICIDES
- 178O EPA 531.1 CARBAMATES & CARBAMOYLOXIMES
- 179O EPA 547 GLYPHOSATE
- 181O EPA 549.2 DIQUAT
- 184O EPA 8260b VOLATILE ORGANICS
- 100H CT ETPH
- OTHER _____

RADIATION

- 916R EPA 900.0 GROSS ALPHA
- 917R EPA 900.0 GROSS BETA
- 919R EPA 903.0 RADIUM 226
- 918R EPA 903.0 RADIUM 228
- 915R EPA 913.0 RADON 222
- 920R EPA 908.0 URANIUM
- 151R EPA 905.0 STRONTIUM 89
- 152R EPA 905.0 STRONTIUM 90
- 155R EPA 902.0 IODINE 131
- 511R EPA 906.0 TRITIUM
- 504R EPA 901.1 GAMMA
- OTHER _____



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



July 1, 1996

John Pozzato
20 County Road
Simsbury, CT 06070

Dear Sir or Madam:

The analytical results for the water sample collected at your home on 5-31-96 have been received and recorded at my office. The water was tested for the presence of ethylene dibromide (EDB). A copy of the results is attached.

Please note the following regarding the sample: (Only those comments that are checked apply to your sample.)

- EDB was not detected in your water sample.
- EDB was detected at _____ ppb in your water sample. The action level for EDB is 0.05 ppb. The action level is the concentration at or above which the Department of Public Health has determined there could be a health risk to persons using the water for drinking purposes.
- EDB is present in your water at concentrations below the action level. At these levels it is not considered to be a risk to your health.
- We will be sampling your water again in _____ months to monitor any changes in water quality.
- This is the first sample for your home in our records that shows EDB present above the action level. We will be resampling at your home in the very near future. If the second sample shows EDB above the action level, you will be notified as to what action should be taken.
- This is the second sample for your home in our records that shows EDB present above the action level. You are therefore eligible for a carbon filter. Within the next month your water will be sampled for several parameters (such as iron) that may affect the operation of the carbon filter. When these results come back, arrangements for the filter installation will be made.

If you have any questions, please contact me at (860) 424-3771.

Sincerely,

Naomi Davidson
Supervising Environmental Analyst
Permitting, Enforcement and
Remediation Division

enclosure

(Printed on Recycled Paper)

79 Elm Street • Hartford, CT 06106-5127

An Equal Opportunity Employer

STATE OF CONNECTICUT
Dept. of Public Health, Water Pollution Control
Bureau of Laboratories
10 Clinton St.
P.O. Box 1687
Hartford, CT 06144
TELEPHONE: (203) 566-5063

1-511MSWY
JOHN J. OZIATI
28 COUNTY RD
MERRIMACK

DEP-BRD, FED, PRE-REMEDIAL

79 ELM STREET

HARTFORD

CT 06106

RECEIVED BY DATE RECEIVED BY REPORTER		
05/31/95	05/31/95	05/21
10:54	10:54	11:19

REPORT

FINAL REPORT

RESULTS

COMMITTEE

SAMPLING POINT: TAP
COLLECTOR: HAROLD GOODMAN TITLE: S. ENGINEER
PRIVATE WELL TREATMENT

DATE ANALYZED

5/10/95

EPA METHOD 504.1
MEASUREMENT OF 1,2-DIBROMOETHANE (EDB) AND
1,2-DIBROMO-3-CHLOROPROPANE (DSCP) IN DRINKING WATER
BY MICROEXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON
CAPTURE DETECTOR.
THE FOLLOWING COMPOUNDS CAN BE DETERMINED BY THIS METHOD
COMPOUND METHOD DETECTION LIMIT (U)
1,2-DIBROMOETHANE (EDB) 0.02
1,2-DIBROMO-3-CHLOROPROPANE (DSCP) 0.02
1,2,3-TRICHLOROPROPANE (1,2,3-TCP) 0.04

EPA 504.1

COMPOUND	QUANTITY (UG/L)
1,2-DIBROMOETHANE (EDB)	NONE DETECTED
1,2-DIBROMO-3-CHLOROPROPANE (DSCP)	NONE DETECTED
1,2,3-TRICHLOROPROPANE (TCP)	NONE DETECTED

RECEIVED

JUN 26 1995

WATER MANAGEMENT
PERMITTING, ENFORCEMENT
REMEDIATION DIVISION

2-Vials

COLLECTION DATA FOR DRINKING WATER SUPPLIES	96 MAY 31	STATE OF CONNECTICUT DEPARTMENT OF PUBLIC HEALTH BUREAU OF LABORATORIES P.O. BOX 1629 10 CLINTON STREET HARTFORD, CT. 06144	Bottles Received 2 Amber 4ozm Vials
ORGANIC CHEMISTRY		PHONES: Area code (203) Env. Chem. Division: 566-5626 Organic Chemistry : 566-3802 Pesticide/Residue : 566-2787	Town No. / 2 P Date Collected: 5/31/90 Time Collected: 9:55
<input checked="" type="checkbox"/> Priv <input type="checkbox"/> Pub			

Account # / Address Label Here A 00106 / PEP PEP - PORTABLE WATER - PERO 79 ELM STREET HARTFORD, CT 06106 (Bill / Report to this Address)	Sample No. 51-20	1610 8399-3
Source TAP	Name of Utility or Property Owner PO 22470, JOHN	
Collected By: (Please Print) HAROLD BOBOWSKI	Address of Sample Collection 20 County Road	
Collector's Title / Phone # S. Engineer 2 / 424-3293	Town & Zip code SIMSBURY	
Agency CT - PEP		

Remarks (Additional Information: Complaints, Request, Treatment, etc.)

Composite

TEST ORDERS

Tests - Circle No. of Test (NOTE: Last Digit Letter "O" Not Number "0")

Computer No. #	Dept. No. #	EPA Method No. #	Test Description
100J	16	524.2	Volatile Organic Compounds (VOCs) (Quantity: 60) and MTBE
010H	16	504	EDB and DBCP
1830	16	525.2	Semi Volatile Organics including PAHs benzo(a) pyrene; also bis(2-ethylhexyl) phthalate and bis(2-ethylhexyl) adipate
1800	16	548.1	Endothall
1060	18	505	Organochlorine pesticides, Triazine Herbicides and Polychlorinated Biphenyls (PCBs)
1760	18	555	Chlorophenoxy Acid Herbicides
1780	18	531.1	N-methylcarbamates and N-methylcarbamoyloximes (aldicarb, oxamyl, carbofuran, etc.)
1790	18	547	Glyphosate
1810	18	549	Diquat
1820	18	552.1	Disinfectant by-products (haloacetic acids) and dalapon
1840	18	551	Chlorinated disinfectant by-products



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



Naomi Davidson

May 12 1994

46 County Road
Simsbury, CT 06070

Dear Sir or Madam:

The analytical results from the water sample taken at your home on 4-04-94 have been received and recorded at my office. Your water was tested for the presence of ethylene dibromide (EDB). A copy of the results is attached.

Please note the following: (Only those comments that are checked apply to your home.)

EDB was not detected in your water at this time. We will be sampling your well several times over the next 5 years to ensure that EDB does not impact you. If at some time in the future your well does become contaminated with EDB at a concentration greater than the action level, you will be notified as to what action should be taken.

EDB was detected at 0.5 ppb in your water. The action level for EDB is 0.10 ppb.

EDB is present in your water at concentrations below the action level. At these levels it is not considered to be a risk to your health. We will be sampling your water again in month(s) to ensure that the level of EDB remains low.

This is the first sample for your home in our records that shows EDB present above the action level. We will be resampling at your home in the very near future. If the second sample shows EDB above the action level, you will be notified as to what action should be taken.

This is the second sample for your home in our records that shows EDB present above the action level. You are therefore eligible for a carbon filter. Within the next month, your water will be sampled for several parameters (such as iron) that may affect the operation of the carbon filter. When these results come back, the necessary arrangements for filter installation can be made.

If you have independent analyses of your water for EDB that either confirm or contradict these sample results, it would be very helpful for me to have that information. I would appreciate it if you would send a copy of any independent laboratory results to my attention. If you have any questions, please contact me at 566-3654.

We will continue to have bottled water delivered until it is determined what action is necessary to provide you with a permanent supply of potable water.
enclosure

Sincerely,

Naomi Davidson

Naomi Davidson
Supervising Environmental Analyst
Permitting, Enforcement and Remediation
Division

STATE OF CONNECTICUT

Division of Health and Environmental Protection
Bureau of Laboratories
10 Clinton St.
P.O. Box 1689
Hartford, CT 06144

TELEPHONE: (203) 566-5063

APR 29 1994

APR 29 1994

APR 29 1994

1125 MUSKORY
DONNA DAVIDSON
46 COUNTY RD
MUSKORY

DEP-PL-BER-RD, POTABLE WATER
BOX 5066
75 ELM ST.
HARTFORD, CT 06106

COLLECTED	RECEIVED	REPORTED
04/04/94 10:05	04/04/94 12:40	04/25/94 10:22

REPORT

FINAL REPORT

COMMENT

TEST(S)

RESULT(S)

SAMPLING POINT: KITCHEN TAP
COLLECTOR: STEPHEN J. GAUR TITLE: EA1
PRIVATE WELL TREATMENT

DATE ANALYZED

4/21/94

EPA METHOD 504

MEASUREMENT OF 1,2-DIBROMOETHANE (EDB) AND
1,2-DIBROMO-3-CHLOROPROPANE (DBCP) IN DRINKING WATER
BY MICROEXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON
CAPTURE DETECTOR.

THE FOLLOWING COMPOUNDS CAN BE DETERMINED BY THIS METHOD
COMPOUND METHOD DETECTION LIMIT (UG/L)

1,2-DIBROMOETHANE (EDB)	0.02
1,2-DIBROMO-3-CHLOROPROPANE (DBCP)	0.02

EPA 504

COMPOUND	QUANTITY (UG/L)
1,2-DIBROMOETHANE(EDB)	0.5
1,2-DIBROMO-3-CHLOROPROPANE(DBCP)	NONE DETECTED

RECEIVED

APR 29 1994

WATER MANAGEMENT
PERMITTING, ENFORCEMENT
& REMEDIATION DIVISION

APR 29 1994



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



Lucie (J) S. Kite
50 County Rd
Somers CT 06070

Aug 1 1994

Dear Sir or Madam:

The analytical results from the water sample taken at your home on July 7 1994 have been received and recorded at my office. Your water was tested for the presence of ethylene dibromide (EDB) and other volatile organic compounds (VOCs). A copy of the results is attached.

Please note the following: (Only those comments that are checked apply to your home.)

EDB was not detected in your water at this time. We will be sampling your well several times over the next 5 years to ensure that EDB does not impact you. If at some time in the future your well does become contaminated with EDB at a concentration greater than the action level, you will be notified as to what action should be taken.

EDB was detected at 0.060 ppb in your water. The action level for EDB is 0.10 ppb.

EDB is present in your water at concentrations below the action level. At these levels it is not considered to be a risk to your health. We will be sampling your water again in 12 month(s) to ensure that the level of EDB remains low.

1,2-dichloropropane was not detected in your water supply.

1,2-dichloropropane was detected at a concentration of 3.2 ppb in your water. The action level for 1,2-dichloropropane is 5.0 ppb.

1,2-dichloropropane is present in your water at a concentration below the action level.

1,2-dichloropropane is present in your water at a concentration above the action level. Bottled water will be supplied to your residence for drinking and cooking purposes until arrangements have been made for implementation of a permanent water supply alternative (GAC filter system or public water).

If you have any questions, please contact me at 566-3654.

Sincerely,

Naomi Davidson

Naomi Davidson
Supervising Environmental Analyst
Permitting, Enforcement and Remediation
Division

enclosure

STATE OF CONNECTICUT

DEPARTMENT OF ENVIRONMENT
WATER QUALITY DIVISION
10 Clinton Street
P.O. Box 3039
Hartford, CT 06143
TELEPHONE (203) 560-5063

WATER

16099580

00014

DEP P.E.R.D. POTABLE WATER
BOX 5068
79 ELM ST.
HARTFORD

CT 06106

128 SIMSBURY

50 COUNTY RD
SIMSBURY

CT

COLLECTED	RECEIVED	REPORTED
05/17/94	05/18/94	05/18/94
17:25	10:47	14:14

REPORT

FINAL REPORT

COMMENT

TEST(S)	RESPONSE
	SAMPLING POINT: REAR OUTSIDE TAP COLLECTOR: S GAURA TITLE: EA 1 PRIVATE WELL TREATMENT:
*** DATE ANALYZED	6/14/94 EPA METHOD 504 MEASUREMENT OF 1,2 DIBROMOETHANE (EDB) AND 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) IN DRINKING WATER BY MICROEXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON CAPTURE DETECTOR. THE FOLLOWING COMPOUNDS CAN BE DETERMINED BY THIS METHOD COMPOUND METHOD DETECTION LIMIT (UG 1,2-DIBROMOETHANE (EDB) 0.02 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) 0.02
EPA 504	COMPOUND QUANTITY (UG/L) 1,2 DIBROMOETHANE (EDB) 0.060 1,2 DIBROMO-3-CHLOROPROPANE (DBCP) NONE DETECTED
	RECEIVED JUN 23 1994 WATER MANAGEMENT PERMITTING, ENFORCEMENT & REMEDIATION DIVISION

STATE OF CONNECTICUT

Dept. of Public Health and Addiction Services
Bureau of Laboratories
100 Clinton St.
P.O. Box 1629
Hartford, CT 06144
TELEPHONE: (203) 566-5063

RR:EGG

16099579

PO0143

128 SIMSBURY

50 COUNTY RD

SIMSBURY

CT

DEP-PERD NON POTABLE
BOX 3066
79 ELM STREET
HARTFORD

CT 06105

COLLECTED	RECEIVED	REPORTED
06/07/94 17:25	06/08/94 10:47	06/20/94 14:08

REPORT

FINAL REPORT

COMMENT

TEST(S)

RESULT(S)

SAMPLING POINT: REAR OUTSIDE TAP
COLLECTOR: S GAURA TITLE: EA 1
PRIVATE WELL TREATMENT

DATE ANALYZED

6/9/94

ANALYTICAL METHOD: EPA METHOD 524.2
MEASUREMENT OF ORGANIC COMPOUNDS IN WATER BY
CAPILLARY COLUMN GAS CHROMATOGRAPHY/MASS SPECTROMETRY.

EPA 524.2

FINAL RESULT:

COMPOUND	QUANTITY (UG/L)
BENZENE	ND
BROMOBENZENE	ND
BROMOCHLOROMETHANE	ND
BROMODICHLOROMETHANE	ND
BROMOFORM	1.1
BROMOMETHANE	ND
N-BUTYLBENZENE	ND
SEC-BUTYLBENZENE	ND
TERT-BUTYLBENZENE	ND
CARBON TETRACHLORIDE	ND
CHLOROBENZENE	ND
CHLOROETHANE	ND
CHLOROFORM	ND
CHLOROMETHANE	ND
2-CHLOROTOLUENE	ND
4-CHLOROTOLUENE	ND
DIBROMOCHLOROMETHANE	ND
1,2-DIBROMO-3-CHLOROPROPANE	ND
1,2-DIBROMOETHANE	ND
DIBROMOMETHANE	ND
1,2-DICHLOROBENZENE	ND
1,3-DICHLOROBENZENE	ND
1,4-DICHLOROBENZENE	ND
DICHLORODIFLUOROMETHANE	ND
1,1-DICHLOROETHANE	ND
1,2-DICHLOROETHANE	ND

RECEIVED
JUN 24 1994WATER MANAGEMENT
PERMITTING, ENFORCEMENT
& REMEDIATION DIVISIONRMM
6/21/94

*** CONTINUED ***

STATE OF CONNECTICUT

DEPARTMENT OF ENVIRONMENTAL PROTECTION
Bureau of Laboratories
10 Church St.
P.O. Box 1639
Hartford, CT 06144
TELEPHONE: (203) 566-5063

NR:500

16099578

AD-14

DEP PERD NON POTABLE
BOX 5066
79 ELM STREET
HARTFORD CT 06106

128 SIMSBURY

50 COUNTY RD
SIMSBURY

CT

COLLECTED	RECEIVED	REPORTED
06/07/94	06/08/94	06/20/
17:25	10:47	14:03

REPORT

FINAL REPORT

COMMENT

TEST(S)	RESULTS
1,1 DICHLOROETHENE	ND
CIS-1,2-DICHLOROETHENE	ND
TRANS-1,2-DICHLOROETHENE	ND
1,2-DICHLOROPROPANE	3.2
1,3-DICHLOROPROPANE	ND
2,2-DICHLOROPROPANE	ND
1,1-DICHLOROPROPENE	ND
CIS-1,3-DICHLOROPROPENE	ND
TRANS-1,3-DICHLOROPROPENE	ND
ETHYLEBENZENE	ND
HEXACHLOROBUTADIENE	ND
ISOPROPYL BENZENE	ND
4-ISOPROPYLTOLEUENE	ND
METHYLENE CHLORIDE	ND
METHYL T-BUTYL ETHER	ND
NAPHTHALENE	ND
PROPYLBENZENE	ND
STYRENE	ND
1,1,1,2-TETRACHLOROETHANE	ND
1,1,2,2-TETRACHLOROETHANE	ND
TETRACHLOROETHENE	ND
TOLUENE	ND
1,2,3-TRICHLOROBENZENE	ND
1,2,4-TRICHLOROBENZENE	ND
1,1,1 TRICHLOROETHANE	ND
1,1,2-TRICHLOROETHANE	ND
TRICHLOROETHENE	ND
TRICHLOROFLUOROMETHANE	ND
1,2,3 TRICHLOROPROPANE	ND
1,2,4-TRIMETHYLBENZENE	ND
1,3,5-TRIMETHYLBENZENE	ND
VINYL CHLORIDE	ND
M,O,P-XYLENES (TOTAL)	ND
NOTE: ND = NONE DETECTED	
METHOD DETECTION LIMIT IS 0.5 ug/l FOR THE ABOVE COMPOUNDS	

RAM
6/21/94



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



John W. Loring

6/14/94

St. County Rd

Simsbury, CT 06070

Dear Sir or Madam:

The analytical results from the water sample taken at your home on Jun 7, 1994 have been received and recorded at my office. Your water was tested for the presence of ethylene dibromide (EDB) and other volatile organic compounds (VOCs). A copy of the results is attached.

Please note the following: (Only those comments that are checked apply to your home.)

EDB was not detected in your water at this time. We will be sampling your well several times over the next 5 years to ensure that EDB does not impact you. If at some time in the future your well does become contaminated with EDB at a concentration greater than the action level, you will be notified as to what action should be taken.

EDB was detected at <0.02 ppb in your water. The action level for EDB is 0.10 ppb. (Under detection limit)

EDB is present in your water at concentrations below the action level. At these levels it is not considered to be a risk to your health. We will be sampling your water again in _____ month(s) to ensure that the level of EDB remains low.

1,2-dichloropropane was not detected in your water supply.

1,2-dichloropropane was detected at a concentration of <0.5 ppb in your water. The action level for 1,2-dichloropropane is 5.0 ppb.

1,2-dichloropropane is present in your water at a concentration below the action level.

1,2-dichloropropane is present in your water at a concentration above the action level. Bottled water will be supplied to your residence for drinking and cooking purposes until arrangements have been made for implementation of a permanent water supply alternative (GAC filter system or public water).

If you have any questions, please contact me at 566-3654.

Sincerely,

Naomi Davidson

Naomi Davidson
Supervising Environmental Analyst
Permitting, Enforcement and Remediation
Division

enclosure

(Printed on Recycled Paper)

79 Elm Street • Hartford, CT 06106-5124

An Equal Opportunity Employer

STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC SAFETY AND ENVIRONMENTAL PROTECTION
Division of Laboratories
10 Clinton Street
P.O. Box 1689
Hartford, CT 06144
TELEPHONE (203) 566-5065

MR:1560

16777573

AOC142

123 SIMSBURY
JOHN LANERGAN
56 COUNTY RD
SIMSBURY CT

DEP P.D.E.R.D. POTABLE WATER
BOX 5065
79 ELM ST.
HARTFORD CT 06106

COLLECTED	RECEIVED	REPORTED
JUN 17 1994 17:10	JUN 20 1994 10:46	JUN 18 1994 14:14

FINAL REPORT

COMMENT

TEST(S)	RESULT(S)
	SAMPLING POINT: REAR OUTSIDE TAP COLLECTOR: S GAURA TITLE: EA 1 PRIVATE WELL TREATMENT:
*** DATE ANALYZED	6/14/94
EPA 504	EPA METHOD 504 MEASUREMENT OF 1,2-DIBROMOETHANE (EDB) AND 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) IN DRINKING WATER BY MICROREXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON CAPTURE DETECTOR. THE FOLLOWING COMPOUNDS CAN BE DETERMINED BY THIS METHOD COMPOUND METHOD DETECTION LIMIT (UG/L) 1,2 DIBROMOETHANE (EDB) 0.02 1,2 DIBROMO-3-CHLOROPROPANE (DBCP) 0.02
	COMPOUND QUANTITY (UG/L) 1,2 DIBROMOETHANE (EDB) <0.02 1,2 DIBROMO-3-CHLOROPROPANE (DBCP) NONE DETECTED

RECEIVED

JUN 25 1994

WATER MANAGEMENT
PERMITTING, ENFORCEMENT
& REMEDIATION DIVISION

28
6/17/1994

STATE OF CONNECTICUT

Department of the Environment, Division of Water

Bureau of Laboratories

40 Clinton St.

P.O. Box 1693

Hartford, CT 06144

TELEPHONE (203) 566-5063

NR-360

15099577

#00142

6

DEP-P.E.R.D. POTABLE WATER
BOX 5056
79 ELM ST.
HARTFORD

CT 06106

128 SIMSBURY
JOHN LANERGAN
56 COUNTY RD
SIMSBURY

COLLECTED	RECEIVED	REPORTED
06/07/94	06/08/94	06/20/
17:10	10:46	14:08

REPORT

FINAL REPORT

COMMENT

TEST(S)

RESULT(S)

SAMPLING POINT: REAR OUTSIDE TAP
COLLECTOR: S GAURA TITLE: EA 1
PRIVATE WELL TREATMENT

DATE ANALYZED

6/9/94

ANALYTICAL METHOD: EPA METHOD 524.2
MEASUREMENT OF ORGANIC COMPOUNDS IN WATER BY
CAPILLARY COLUMN GAS CHROMATOGRAPHY/MASS SPECTROMETRY

EPA 524.2

FINAL RESULT:

COMPOUND	QUANTITY (UG/L)
BENZENE	ND
BROMOBENZENE	ND
BROMOCHLOROMETHANE	ND
BROMODICHLOROMETHANE	ND
BROMOFORM	ND
BROMOMETHANE	ND
N-BUTYLBENZENE	ND
SEC-BUTYLBENZENE	ND
TERT-BUTYLBENZENE	ND
CARBON TETRACHLORIDE	ND
CHLOROBENZENE	ND
CHLOROETHANE	ND
CHLOROFORM	ND
CHLOROMETHANE	ND
2-CHLOROTOLUENE	ND
4-CHLOROTOLUENE	ND
DIBROMOCHLOROMETHANE	ND
1,2-DIBROMO-3-CHLOROPROPANE	ND
1,2-DIBROMOETHANE	ND
DIBROMOMETHANE	ND
1,2-DICHLOROBENZENE	ND
1,3-DICHLOROBENZENE	ND
1,4-DICHLOROBENZENE	ND
DICHLORODIFLUOROMETHANE	ND
1,1-DICHLOROETHANE	ND
1,2-DICHLOROETHANE	ND

RECEIVED
JUN 24 1994
WATER MANAGEMENT
PERMITTING, ENFORCEMENT
& REMOVALS DIVISION
ENVIRONMENTAL
PROTECTION DIVISION

RBM
6/21/94

*** CONTINUED ***

DEPARTMENT OF ENVIRONMENT
SUBDIVISION: Hartford
PC City: Hartford
PC Post: 1986
Sampled: CT 06106
TELEPHONE (203) 566-2363

1235 MURRAY
JOHN LANERAN
56 COUNTY RD

DEP-ER-RD - POTABLE WATER
30X506
79 ELM ST.
HARTFORD
CT-D6106

17:10 10:46 14:08

REPORT FINAL REPORT

TEST(S) REPORT(S)

COMMENT

STANBURY CT

TEST(S)	REPORT(S)	COMMENT
1,1 DICHLOROETHENE	ND	
CIS-1,2 DICHLOROETHENE	ND	
TRANS-1,2 DICHLOROETHENE	ND	
1,2 DICHLOROPROPANE	<3.5	
1,3 DICHLOROPROPENE	ND	
2,2 DICHLOROPROPANE	ND	
1,1 DICHLOROPROPENE	ND	
CIS-1,3 DICHLOROPROPENE	ND	
TRANS-1,3 DICHLOROPROPENE	ND	
ETHYLBENZENE	ND	
HEXACHLORODUADINE	ND	
ISOPROPYLENE	ND	
4 ISOPROPYLtoluene	ND	
METHYLENE CHLORIDE	ND	
METHYL T-BUTYL ETHER	ND	
NAPHTHALENE	ND	
PROPYLBENZENE	ND	
STYRENE	ND	
1,1,1,2-TETRACHLOROETHANE	ND	
1,1,2,2-TETRACHLOROETHANE	ND	
TETRACHLOROETHENE	ND	
TOLUENE	ND	
1,2,3-TRICHLOROBENZENE	ND	
1,2,4-TRICHLOROBENZENE	ND	
1,1,1-TRICHLOROETHANE	ND	
1,1,2-TRICHLOROETHANE	ND	
TRICHLOROETHENE	ND	
TRICHLOROFLUOROMETHANE	ND	
1,2,3-TRICHLOROPROPANE	ND	
1,2,4-TRIMETHYLBENZENE	ND	
1,3,5-TRIMETHYLBENZENE	ND	
VINYL CHLORIDE	ND	
XYLOXYLINES (TOTAL)	ND	

NOTE: ND = NONE DETECTED
METHOD DETECTION LIMIT IS 0.5 ug/L FOR THE ABOVE COMPOUNDS

12/24/94

STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



Peter Davidson
60 Elm St.
Springfield, CT 010010

Aug. 1 1994

Dear Sir or Madam:

The analytical results from the water sample taken at your home on June 7, 1994 have been received and recorded at my office. Your water was tested for the presence of ethylene dibromide (EDB) and other volatile organic compounds (VOCs). A copy of the results is attached.

Please note the following: (Only those comments that are checked apply to your home.)

EDB was not detected in your water at this time. We will be sampling your well several times over the next 5 years to ensure that EDB does not impact you. If at some time in the future your well does become contaminated with EDB at a concentration greater than the action level, you will be notified as to what action should be taken.

EDB was detected at 0.025 ppb in your water. The action level for EDB is 0.10 ppb.

EDB is present in your water at concentrations below the action level. At these levels it is not considered to be a risk to your health. We will be sampling your water again in 12 month(s) to ensure that the level of EDB remains low.

1,2-dichloropropane was not detected in your water supply.

1,2-dichloropropane was detected at a concentration of 6.6 ppb in your water. The action level for 1,2-dichloropropane is 5.0 ppb.

1,2-dichloropropane is present in your water at a concentration below the action level.

1,2-dichloropropane is present in your water at a concentration above the action level. Bottled water will be supplied to your residence for drinking and cooking purposes until arrangements have been made for implementation of a permanent water supply alternative (GAC filter system or public water).

If you have any questions, please contact me at 566-3654.

Sincerely,

Naomi Davidson
Supervising Environmental Analyst
Permitting, Enforcement and Remediation
Division

enclosure

STATE OF CONNECTICUT

Division of Water Quality Assessment
Bureau of Laboratories
10 Clinton St.
P.O. Box 1689
Hartford, CT 06144
TELEPHONE: (203) 566-5646

MR:601

16297573

ACI 142

INFORMATION

123 SIMSBURY
PETE O'LAUGHLIN
60 COUNTY RD.
SIMSBURY

DEP-P-E.R.D. POTABLE WATER
BOX 5066
79 ELM ST.
HARTFORD

CT 06106

COLLECTED BY	RECEIVED BY	REPORTED
8707794	05/08/94	05/16/94

FINAL REPORT

COMMENT

TEST(S)

RESULTS

SAMPLING POINT: WITCHES TAP

COLLECTOR: S GAURA

TITLE: EA 1

PRIVATE WELL TREATMENT

DATE ANALYZED

6/14/94

EPA METHOD 504

MEASUREMENT OF 1,2-DIBROMOETHANE (EDB) AND
1,2-DIBROMO-3-CHLOROPROPANE (DBCP) IN DRINKING WATER
BY MICROEXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON
CAPTURE DETECTOR.

THE FOLLOWING COMPOUNDS CAN BE DETERMINED BY THIS METHOD:

COMPOUND	METHOD DETECTION LIMIT (UG/L)
1,2-DIBROMOETHANE (EDB)	0.02
1,2-DIBROMO-3-CHLOROPROPANE (DBCP)	0.02

EPA 504

COMPOUND

QUANTITY (UG/L)

1,2-DIBROMOETHANE (EDB)

0.025

1,2-DIBROMO-3-CHLOROPROPANE (DBCP)

NONE DETECTED

RECEIVED

JUN 23 1994

WATER MANAGEMENT
PERMITTING, ENFORCEMENT
& REMEDIATION DIVISION

6/17/94

STATE OF CONNECTICUT

Dept. of Public Health and Addiction Services
Bureau of Laboratories
19 Clinton St.
P.O. Box 1689
Hartford, CT 06144
TELEPHONE: (203) 566-5063

NP:600

16039573

POC142

INFORMAL

DEP-P.E.R.D. POTABLE WATER
BOX 5065
79 ELM ST.
HARTFORD

CT 06106

1283IMSURY
PETE O'LAUGHLIN
SO COUNTY RD

IMSURY

CT

COLLECTED

RECEIVED

REPORTED

06/07/94
16:5506/08/94
10:4506/20/94
14:03

FINAL REPORT

ACCOMPLISHMENT

TESTS

RESULTS

SAMPLING POINT: KITCHEN TAP

COLLECTOR: S GAURA

TITLE: EA 1

PRIVATE WELL TREATMENT

DATE ANALYZED

6/9/94

ANALYTICAL METHOD: EPA METHOD 524.2
MEASUREMENT OF ORGANIC COMPOUNDS IN WATER BY
CAPILLARY COLUMN GAS CHROMATOGRAPHY/MASS SPECTROMETRY.

EPA 524.2

FINAL RESULT:

COMPOUND	QUANTITY (UG/L)
BENZENE	ND
BROMOBENZENE	ND
BROMOCHLOROMETHANE	ND
BROMODICHLOROMETHANE	ND
BROMOFORM	ND
BROMOMETHANE	ND
N-BUTYLBENZENE	ND
SEC-BUTYLBENZENE	ND
TERT BUTYLBENZENE	ND
CARBON TETRACHLORIDE	ND
CHLOROBENZENE	ND
CHLOROETHANE	ND
CHLOROFORM	ND
CHLORMETHANE	ND
2-CHLOROTOLUENE	ND
4-CHLOROTOLUENE	ND
DIBROMOCHLOROMETHANE	ND
1,2-DIBROMO-3-CHLOROPROPANE	ND
1,2-DIBROMOETHANE	ND
DIBROMOMETHANE	ND
1,2-DICHLOROBENZENE	ND
1,3-DICHLOROBENZENE	ND
1,4-DICHLOROBENZENE	ND
DICHLORODIFLUOROMETHANE	ND
1,1-DICHLOROETHANE	ND
1,2-DICHLOROETHANE	ND

RECEIVED
JUN 24 1994
WATER MANAGEMENT
& REGULATION DIVISION
PERMITTING, ENFORCEMENT

*** CONTINUED ***

DEPARTMENT OF ENVIRONMENT

State of Connecticut
Division of Water Pollution Control
Bureau of Laboratories
10 Clinton St.
P.O. Box 1689
Hartford, CT 06144
TELEPHONE: (203) 566-5063

LR-1601

16099575

EOL132

DEP-P.E.R.D. POTABLE WATER
BOX 5066
79 ELM ST.
HARTFORD

CT 06106

118 SIMSBURY
PETE O'LAUGHLIN
50 COUNTY RD
SIMSBURY

CT

DETECTED	NOT DETECTED	REPORTED
06/07/94	06/08/94	06/20/94
16:55	10:45	14:08

REPORT

FINAL REPORT


COMMENT

TESTS	RESULTS
1,1-DICHLOROETHENE	ND
CIS 1,2 DICHLOROETHENE	ND
TRANS-1,2-DICHLOROETHENE	ND
1,2-DICHLOROPROPANE	6.6
1,3-DICHLOROPROPANE	ND
2,2 DICHLOROPROPANE	ND
1,1-DICHLOROPROPENE	ND
CIS-1,3-DICHLOROPROPENE	ND
TRANS-1,3-DICHLOROPROPENE	ND
ETHYLBENZENE	ND
HEXACHLOROBUTADIENE	ND
ISOPROPYLBENZENE	ND
4-ISOPROPYLtoluene	ND
METHYLENE CHLORIDE	ND
METHYL T-BUTYL ETHER	ND
NAPHTHALENE	ND
PROPYLBENZENE	ND
STYRENE	ND
1,1,1,2-TETRACHLOROETHANE	ND
1,1,2,2-TETRACHLOROETHANE	ND
TETRACHLOROETHENE	ND
TOLUENE	ND
1,2,3-TRICHLOROBENZENE	ND
1,2,4-TRICHLOROBENZENE	ND
1,1,1-TRICHLOROETHANE	ND
1,1,2 TRICHLOROETHANE	ND
TRICHLOROETHENE	ND
TRICHLOROFUOROMETHANE	ND
1,2,3-TRICHLOROPROPANE	0.6
1,2,4-TRIMETHYLBENZENE	ND
1,3,5-TRIMETHYLBENZENE	ND
VINYL CHLORIDE	ND
M,O,P-XYLENES (TOTAL)	ND

NOTE: ND = NONE DETECTED

METHOD DETECTION LIMIT IS 0.5 ug/L FOR THE ABOVE COMPOUNDS

RMM
6/21/94



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



April 28, 2010

Ketchabau Residence
64 County Road
Simsbury, CT 06070

Dear Mr. and Mrs. Ketchabu:

Enclosed is a copy of the laboratory analysis for the unfiltered (raw) water sample collected from 64 County Road on 4/15/2010. The water sample was analyzed for the presence of ethylene dibromide (EDB), 1,2,3 -Trichloropropane (TCP), and 1,2 dibromo-3-chloropropane (DBCP).

Results from the analyses are summarized in Table 1 (attached). Table 1 also includes each compound's respective action level set by the Connecticut Department of Public Health (DPH). Please note that only established action levels are included in Table 1. If an action level has not been listed it means that an action level has not been established for that particular compound and its detection does not render the water unsafe for drinking or other domestic uses.

Referring to Table 1, the water sample collected from your water supply did not contain detectable concentrations of pollutants at concentrations at or above their respective action level. An action level is the concentration at or above which the DPH has determined there could be a risk to the health of persons consuming the water. Consequently, your water is considered to be potable.

If you have any questions or comments please contact me at (860) 424-3796.

Sincerely,

MaryAnne Danyluk
Environmental Analyst 2
Remediation Division
DEP/Bureau of Water Protection and Land Reuse

Enclosure(s)

TABLE ONE
Raw Water Sample Results
64 County Road
Simsbury, Connecticut

<u>COMPOUND ANALYZED</u>	<u>CONCENTRATION DETECTED ug/l</u>	<u>ACTION LEVEL ug/l</u>
1,2 dibromoethane (EDB)	ND	0.05
1,2,3-trichloropropane (TCP)	ND	0.05
1,2 dibromo-3-chloropropane (DBCP)	ND	NAL

Notes: ug/l Microgram per liter
ND Not detected above analytical detection limits
NAL An action level has not been established by the Department of Public Health (DPH)




STATE OF CONNECTICUT

Department of Public Health Laboratory
 Clinical Testing License: CL-0197
 10 Clinton St.
 P.O. Box 1689
 Hartford, CT 06144
 Telephone (860) 509-8500

ID NR: 64	ACCESSION NO. 18024491	ACCOUNT NO. A00142	AGE 0	\$	PAGE 1
INFORMATION					
128 SIMSBURY B&P KETCHABAU 64 COUNTY RD SIMSBURY CT					
DEP - REMEDIATION		COLLECTED 04/15/10 13:30	RECEIVED 04/16/10 09:24	REPORTED 04/20/10 09:20	
79 ELM ST. HARTFORD	CT 06106				

REPORT	FINAL REPORT	COMMENT		
TEST(S)	RESULT(S)			
	SAMPLING POINT: OUTSIDE COLLECTOR: BRIGHTWELL PRIVATE WELL TREATMENT:			
*** DATE ANALYZED	4/20/10			
<p>EPA METHOD 504.1 MEASUREMENT OF 1,2-DIBROMOETHANE (EDB), 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) AND 1,2,3 TRICHLOROPROPANE (123TCP) IN DRINKING WATER BY MICROEXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON CAPTURE DETECTION.</p>				
EPA 504.1	Final Result: [All values expressed in ug/L (ppb)]			
	Compound	Result	MDL	PQL
	1,2-Dibromoethane	ND	0.0016	0.02
	1,2-Dibromo-3-Chloropropane	ND	0.0021	0.02
	1,2,3-Trichloropropane	ND	0.0073	0.04
	ND = None Detected (Result Less Than The PQL) PQL= Practical Quantitation Limit (lowest standard) MDL = method Detection Limit			
	MDL calculated based on a Signal/Noise Ratio of 5:1 according to CFR Part 136 Appendix B			
	<p>WATER PROTECTION AND LAND REUSE <i>Manus</i> APR 23 2010 REMEDIATION DIVISION</p>			
	** END OF REPORT **			



REQUEST FOR ORGANICS / RADIATION WATER EXAMINATION

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH LABORATORY
PO BOX 1689, HARTFORD, CONNECTICUT 06144
10 CLINTON STREET, HARTFORD, CONNECTICUT 06106

Organic Chemistry Section: (860) 509-8547 / Special Chemistry Section: (860) 509-8535

1802 4491-5	Bottles Received 3 Vials	DEP - REMEDIATION
	<input type="checkbox"/> PUBLIC <input checked="" type="checkbox"/> PRIVATE	79 ELM ST. HARTFORD, CT 06106

T.C. 3/2/06

TO BE COMPLETED BY COLLECTOR

Town Number 188	Date Collected (MM/DD/YY) 04/15/2010	Time Collected (Military Time) 1330 Hrs
Name of Utility or Property Owner Bill + Patricia	Ketchabau	Collector's Sample Number 64
Source Outside	Address of Sample Collection 64 County rd	
Collected By Brightwell	Collector's Title	
Collector's Phone Number - 424 - 3293	Town and State of Sample Collection Simsbury ct	Zip Code - 06076

REMARKS (Additional Information: Complaints, Requests, Treatments, Etc.)

REMARKS (Additional Information: Complaints, Requests, Treatments, Etc.)
--

WATER TEST REQUEST


ORGANICS

- 100J EPA 524.2 VOLATILE ORGANICS
- 010H EPA 504.1 EDB AND DBCP
- 1830 EPA 525.2 SEMI-VOLATILE ORGANICS
- 1060 EPA 505 ORGANOCHLORINE PESTICIDES
- 1760 EPA 515.3 CHLORINATED HERBICIDES
- 1780 EPA 531.1 CARBAMATES & CARBAMOYLOXIMES
- 1790 EPA 547 GLYPHOSATE
- 1810 EPA 549.2 DIQUAT
- 1840 EPA 8260b VOLATILE ORGANICS
- 100H CT ETPH
- OTHER _____

RADIATION

- 916R EPA 900.0 GROSS ALPHA
- 917R EPA 900.0 GROSS BETA
- 919R EPA 903.0 RADIUM 226
- 918R EPA 903.0 RADIUM 228
- 915R EPA 913.0 RADON 222
- 920R EPA 908.0 URANIUM
- 151R EPA 905.0 STRONTIUM 89
- 152R EPA 905.0 STRONTIUM 90
- 155R EPA 902.0 IODINE 131
- 511R EPA 906.0 TRITIUM
- 504R EPA 901.1 GAMMA
- OTHER _____

OR 7/11



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



Glen (holder)
70 County Rd
Simsbury (1 06070)

Aug 1 1994

Dear Sir or Madam;

The analytical results from the water sample taken at your home on June 7 1994 have been received and recorded at my office. Your water was tested for the presence of ethylene dibromide (EDB) and other volatile organic compounds (VOCs). A copy of the results is attached.

Please note the following: (Only those comments that are checked apply to your home.)

EDB was not detected in your water at this time. We will be sampling your well several times over the next 5 years to ensure that EDB does not impact you. If at some time in the future your well does become contaminated with EDB at a concentration greater than the action level, you will be notified as to what action should be taken.

EDB was detected at _____ ppb in your water. The action level for EDB is 0.10 ppb.

EDB is present in your water at concentrations below the action level. At these levels it is not considered to be a risk to your health. We will be sampling your water again in _____ month(s) to ensure that the level of EDB remains low.

1,2-dichloropropane was not detected in your water supply.

1,2-dichloropropane was detected at a concentration of _____ in your water. The action level for 1,2-dichloropropane is 5.0, ppb.

1,2-dichloropropane is present in your water at a concentration below the action level.

1,2-dichloropropane is present in your water at a concentration above the action level. Bottled water will be supplied to your residence for drinking and cooking purposes until arrangements have been made for implementation of a permanent water supply alternative (GAC filter system or public water).

If you have any questions, please contact me at 566-3654.

Sincerely,

Naomi Davidson
Supervising Environmental Analyst
Permitting, Enforcement and Remediation
Division

enclosure

Bureau of Water and Air Quality Services
120 Main Street
P.O. Box 1689
Hartford, CT 06144
TELEPHONE: (203) 566-5063

AR:700

15099574

AR:6142

INFORMATION

120 SIMSBURY
GLEN CHALDER
70 COUNTY RD.
SIMSBURY, CT

DEPT. OF E.P.R.D. POTABLE WATER
BOX 5066
79 ELM ST.
HARTFORD

CT 06106

COLLECTED	RECEIVED	REPORTED
05/17/94	05/18/94	05/18/94

REPORT

FINAL REPORT

COMMENT

TESTS	RESULTS
	SAMPLING POINT: OUTSIDE FRONT COLLECTOR: S GAURA TITLE: EA'1 PRIVATE WELL TREATMENT:
DATE ANALYZED	6/14/94
EPA 504	EPA METHOD 504 MEASUREMENT OF 1,2-DIBROMOETHANE (EDB) AND 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) IN DRINKING WATER BY MICROEXTRACTION AND GAS CHROMATOGRAPHY WITH ELECTRON CAPTURE DETECTOR. THE FOLLOWING COMPOUNDS CAN BE DETERMINED BY THIS METHOD COMPOUND METHOD DETECTION LIMIT (UG/L) 1,2-DIBROMOETHANE (EDB) 0.02 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) 0.02 COMPOUND QUANTITY (UG/L) 1,2-DIBROMOETHANE (EDB) NONE DETECTED 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) NONE DETECTED

RECEIVED

JUN 23 1994

WATER MANAGEMENT
PERMITTING, ENFORCEMENT
& REMEDIATION DIVISION

STATE OF CONNECTICUT

Dept. of Public Health and Senior Service
Bureau of Laboratories
10 Clinton St.
P.O. Box 5689
Hartford, CT 06144
TELEPHONE (203) 566-5063

NR-701

16093573

PC0142

DEP-P.E.R.D. POTABLE WATER
BOX 5066
79 ELM ST.
HARTFORD

CT 06106

128 SIMSBURY
GLEN CHALBER
70 COUNTY RD

SIMSBURY

CT

COLLECTED	RECEIVED	REPORTED
06/17/94	06/08/94	06/20/94
16:40	10:44	14:08

REPORT

FINAL REPORT

COMMENT

TEST(S)	RESULT(S)	COMMENT
	SAMPLING POINT: OUTSIDE FRONT COLLECTOR: S SAURA PRIVATE WELL TREATMENT:	TITLE: EA 1
*** DATE ANALYZED	6/17/94	
EPA 524.2	ANALYTICAL METHOD: EPA METHOD 524.2 MEASUREMENT OF ORGANIC COMPOUNDS IN WATER BY CAPILLARY COLUMN GAS CHROMATOGRAPHY/MASS SPECTROMETRY.	
	FINAL RESULT:	
	COMPOUND	QUANTITY (UG/L)
	BENZENE	ND
	BROMOBENZENE	ND
	BROMOCHLOROMETHANE	ND
	BROMODICHLOROMETHANE	ND
	BROMOFORM	ND
	BROMOMETHANE	ND
	N-BUTYLBENZENE	ND
	SEC. BUTYLBENZENE	ND
	TERT-BUTYLBENZENE	ND
	CARBON TETRACHLORIDE	ND
	CHLOROBENZENE	ND
	CHLOROETHANE	ND
	CHLOROFORM	ND
	CHLOROMETHANE	ND
	2-CHLOROTOLUENE	ND
	4-CHLOROTOLUENE	ND
	DIBROMOCHLOROMETHANE	ND
	1,2-DIBROMO-3-CHLOROPROPANE	ND
	1,2-DIBROMOETHANE	ND
	DIBROMOMETHANE	ND
	1,2-DICHLOROBENZENE	ND
	1,3-DICHLOROBENZENE	ND
	1,4-DICHLOROBENZENE	ND
	DICHLORODIFLUOROMETHANE	ND
	1,1-DICHLOROETHANE	ND
	1,2-DICHLOROETHANE	ND

RECEIVED
JUN 24 1994

PERMITTING, ENFORCEMENT
& REMEDIATION DIVISION
WATER MANAGEMENT

PC0142
6/21/94

*** CONTINUED ***

STATE OF CONNECTICUT

Dept. of Public Health and Protection Services
Division of Laboratory Services
16 Clinton St.
P.O. Box 1689
Hartford, CT 06144
TELEPHONE (203) 566-5063

RR-700

1609957

AC142

DEP-P.E.R.D. POTABLE WATER
BOX 5066
79 ELM ST.
HARTFORD

CT 06106

126 SIMSBURY
GLEN CHAELLES
70 COUNTY RD
SIMSBURY

CT

COLLECTED	RECEIVED	REPORTED
06/07/94	06/08/94	06/20/94
16:40	10:44	14:08

REPORT

FINAL REPORT

CONTINUATION

TEST(S)


RESULTS

1,1-DICHLOROETHENE	ND
CIS-1,2-DICHLOROETHENE	ND
TRANS-1,2-DICHLOROETHENE	ND
1,2-DICHLOROPROPANE	ND
1,3-DICHLOROPROPANE	ND
2,2-DICHLOROPROPANE	ND
1,1-DICHLOROPROPENE	ND
CIS-1,3-DICHLOROPROPENE	ND
TRANS-1,3-DICHLOROPROPENE	ND
ETHYLBENZENE	ND
HEXACHLOROBUTADIENE	ND
ISOPROPYLBENZENE	ND
2-ISOPROPYLTOUENE	ND
METHYLENE CHLORIDE	ND
METHYL T-BUTYL ETHER	ND
NAPHTHALENE	ND
PROPYLBENZENE	ND
STYRENE	ND
1,1,1,2-TETRACHLOROETHANE	ND
1,1,2,2-TETRACHLOROETHANE	ND
TETRACHLOROETHENE	ND
TOLUENE	ND
1,2,3-TRICHLOROBENZENE	ND
1,2,4-TRICHLOROBENZENE	ND
1,1,1-TRICHLOROETHANE	ND
1,1,2-TRICHLOROETHANE	ND
TRICHLOROETHENE	ND
TRICHLOROFLUOROMETHANE	ND
1,2,3-TRICHLOROPROPANE	ND
1,2,4-TRIMETHYLBENZENE	ND
1,3,5-TRIMETHYLBENZENE	ND
VINYL CHLORIDE	ND
M,O,P-XYLENES (TOTAL)	ND

NOTE: ND = NONE DETECTED

METHOD DETECTION LIMIT IS 0.5 ug/L FOR THE ABOVE COMPOUNDS

RMM
6/21/94



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



Glen (holder)
70 County Rd
Simsbury (106070)

Aug. 1, 1994

Dear Sir or Madam;

The analytical results from the water sample taken at your home on July 1994 have been received and recorded at my office. Your water was tested for the presence of ethylene dibromide (EDB) and other volatile organic compounds (VOCs). A copy of the results is attached.

Please note the following: (Only those comments that are checked apply to your home.)

EDB was not detected in your water at this time. We will be sampling your well several times over the next 5 years to ensure that EDB does not impact you. If at some time in the future your well does become contaminated with EDB at a concentration greater than the action level, you will be notified as to what action should be taken.

EDB was detected at _____ ppb in your water. The action level for EDB is 0.10 ppb.

EDB is present in your water at concentrations below the action level. At these levels it is not considered to be a risk to your health. We will be sampling your water again in _____ month(s) to ensure that the level of EDB remains low.

1,2-dichloropropane was not detected in your water supply.

1,2-dichloropropane was detected at a concentration of _____ in your water. The action level for 1,2-dichloropropane is 5.0 ppb.

1,2-dichloropropane is present in your water at a concentration below the action level.

1,2-dichloropropane is present in your water at a concentration above the action level. Bottled water will be supplied to your residence for drinking and cooking purposes until arrangements have been made for implementation of a permanent water supply alternative (GAC filter system or public water).

If you have any questions, please contact me at 566-3654.

Sincerely,

Naomi Davidson

Supervising Environmental Analyst
Permitting, Enforcement and Remediation
Division

enclosure