

Exhibit Q

Contingent Approval from Eversource



Distributed Energy Resources
P.O. Box 1409
Hartford, CT 06143-1409

Contingent Approval

Date: August 01, 2018

Attention: Thomas Rollason

RE: West Farm Mall System A1, B and C

Equipment: System A1 (Car Port): 984 kW photovoltaic system

System B (Car Port): 516 kW photovoltaic system

System C: (Roof) 519.5 kW photovoltaic system

Total Generation: 2019.50

Dear Tom:

Eversource has completed the Impact Study in compliance with the Fast Track and Study process for the above stated projects and has determined that the proposed aggregate generation will have a voltage impact on the distribution system. This voltage impact can be corrected by replacing an existing capacitor bank on the Eversource Distribution System. Please note that Eversource has conducted this analysis based on the new revised size as indicated in your email to me on July 27, 2018. This upgrade will be required for any installed generation in excess of 1.189 MW.

It is also important to note that the final connections to the customer switchgear be done outside the metering cabinet. Eversource will require a detailed drawing prior to authorization to energize any of the systems.

Please refer to the Interconnection Agreement (IA) Attachment I & II for further details and a schedule of milestones. Each project will have its own IA. Also remember to update all your documentation and initial applications so the attachment to the IA reflect the correct size of the photovoltaic systems.

Please remember to coordinate directly with Winston when he is back in the office. In the meantime, should you have any questions or concerns please feel free to contact me.

Sincerely,

Joseph N Debs

Joseph N Debs, Distributed Resources Program Manager

Eversource Energy

P.O. Box 1409, Hartford, CT 06143-1409

Tel: 860-665-5616

E-mail: joseph.debs@eversource.com

cc. Winston Brown