



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

May 3, 2019

Justin Adams
Bloom Energy Corporation
1299 Orleans Dr.
Sunnyvale, CA 94089

RE: **PETITION NO. 1368** – Bloom Energy Corporation, as agent for the City of Milford, petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a customer-side 900-kilowatt fuel cell facility and associated equipment to be located at the Beaverbrook Wastewater Treatment Plant, 75 Deerwood Avenue, Milford, Connecticut.

Dear Mr. Adams:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than May 15, 2019. Please forward an original and 15 copies to this office, as well as send a copy via electronic mail. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the May 15, 2019 deadline.


Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

c: Council Members

MB/CW/RM



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

Petition No. 1368

Bloom Energy

Beaverbrook Wastewater Treatment Plant

Milford, CT

Interrogatories

May 3, 2019

1. Referring to the Emergency Response Plan, p. 12 -Training (Section 10). Does Bloom intend to provide on-site training to local emergency responders?
2. Provide an estimate of the total cost of the proposed project. Break down the total cost into categories the Petitioner deems appropriate.
3. What is the height and type of the proposed retaining wall (e.g. block, poured concrete)?
4. Is the fuel cell compound area asphalt, gravel or turf?
5. Is a fence proposed around the proposed facility? If so, provide fence detail.
6. Is the site location within the 500-year flood zone? If so, what is the flood elevation of such zone? Could the proposed facility be installed to one-foot above the 500-foot flood elevation? If so, explain how this can be accomplished. If not, please indicate why not. What is the additional approximate cost to install the facility one foot above the 500 year flood elevation?
7. Referring to Petition *Section C. ii*, has DEEP responded to Bloom's NDDB review request? If so, please submit.
8. Is any portion of the project on prime farmland soils? If so, what is the area of prime farmland soils that would be impacted by the proposed project?
9. Please confirm the owner of the host property (or others) was provided notice of the proposed project and provide information regarding certified mail receipts.