



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

December 24, 2019

Justin Adams
Bloom Energy Corporation
4353 North First Street
San Jose, CA 95134

RE: **PETITION NO. 1391** - Bloom Energy Corporation petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a customer-side 550-kilowatt fuel cell facility and associated equipment to be located at the Altice USA (formerly Cablevision) building, 28 Cross Street, Norwalk, Connecticut.

Dear Mr. Adams:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than January 9, 2020. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as a copy via electronic mail. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the January 9, 2020 deadline.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

MB/RM



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

Petition No. 1391

Bloom Energy Corporation

28 Cross Street, Norwalk

Interrogatories

1. Was the project selected for the LREC/ZREC Program?
2. Are local emergency responders included as part of the Training provision included in Petition Exhibit 4, Section 10? If not, would training be provided to local emergency responders?
3. Petition Site Plan G1.1 shows Energy Server Unit 1 (ES-1) in close proximity to an existing emergency generator. Does the proposed placement of ES-1 comply with Fire Code requirements concerning set back distances from stored combustible liquids that may be used to power the emergency generator?
4. In regards to Petition Exhibit 9, Facility Sound Analysis, please provide the following:
 - a) Page 4 states the maximum sound level is 57 dBA at the nearest commercial property, however Figure 3 shows a projected sound level of 56 dBA at the nearest commercial property. Please clarify.
 - b) Although Figure 3 shows a projected sound level of 47 dBA at 10 Wilton Avenue, and below the adjusted residential noise level threshold of 53 dBA, are there any sound mitigation measures that can be used at the site to reduce potential noise from facility operation?
 - c) Do the Figure 3 projected sound levels represent noise only from facility operation or do the projected sound levels include facility operation and background noise? What sound projection methodology is required under Connecticut Noise Control regulations?