



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

January 2, 2020

Justin Adams
Bloom Energy Corporation
4353 North First Street
San Jose, CA 95134

RE: **PETITION NO. 1090A** – Bloom Energy Corporation request to amend its declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed Phase II construction, maintenance and operation of a second customer-side 250-kilowatt fuel cell facility and associated equipment to be located at the Danbury Fair Mall, 7 Backus Avenue, Danbury, Connecticut.

Dear Mr. Adams:


The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than January 16, 2020. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as a copy via electronic mail. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the January 16, 2020 deadline.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,


Melanie Bachman
Executive Director

MB/RM



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

Petition No. 1090A
Bloom Energy Corporation
Danbury Fair Mall, Danbury
Interrogatories

1. Was the project selected for the LREC/ZREC Program?
2. Are local emergency responders included as part of the Training provision included in Petition Exhibit 4, Section 10? If not, would training be provided to local emergency responders?
3. Petition Exhibit 3, the footnote on the “Daily Customer Load Profile – Annual View” indicates that the nighttime load is below 300 kW and the unit is sized to minimize exports, maintaining an export output of less than 5 percent.
 - a. Does Bloom intend to maintain the export output at less than 12.5 kW? How is the unit controlled to ensure the unit does not export more than the 5 percent threshold if the building load is significantly less than the 250 kW unit rating?
 - b. Are the loads shown on the graph only for the south end of the mall building where the interconnection occurs?



CONNECTICUT SITING COUNCIL

Affirmative Action / Equal Opportunity Employer