



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

### CERTIFIED MAIL RETURN RECEIPT REQUESTED

May 1, 2015

Christopher B. Fisher, Esq.  
Cuddy & Feder LLP  
445 Hamilton Avenue, 14<sup>th</sup> Floor  
White Plains, NY 10601

RE: **PETITION NO. 1106** - New Cingular Wireless PCS, LLC declaratory ruling that no Certificate of Environmental Compatibility and Public Need is required to install a rooftop telecommunications tower on an existing commercial building located at 168 Center Street, Southington, Connecticut.

Dear Attorney Fisher:

At a public meeting held on April 30, 2015, the Connecticut Siting Council (Council) considered and approved the revisions to this petition submitted on April 21, 2015.

This decision is under the exclusive jurisdiction of the Council and is not applicable to any other modification or construction. All work is to be implemented as specified in the petition dated June 2, 2014 and in the revision submission dated April 21, 2015.

Enclosed is a copy of the staff report, dated April 30, 2015.

Very truly yours,

Robert Stein  
Chairman

RS/CMW/lm

Enclosure: Staff Report dated April 30, 2015

c: The Honorable Michael Riccio, Chairman, Town of Southington  
Garry Brumback, Town Manager, Town of Southington  
Robert Phillips, Town Planner, Town of Southington



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

### Petition No. 1106 Revision

AT&T

Southington, Connecticut

Staff Report

April 30, 2015

On October 16, 2014, the Connecticut Siting Council (Council) approved a petition for declaratory ruling New Cingular Wireless PCS, LLC (AT&T) that no Certificate of Environmental Compatibility and Public Need is required for the installation of a rooftop wireless telecommunications tower on an existing building located at 168 Center Street in Southington, Connecticut. On April 22, 2015, AT&T submitted a request to revise the site plan for the facility to relocate the backup generator associated with the project. AT&T had originally proposed locating the generator in the basement of the existing building. Since that time, the Town of Southington building department recommended the generator be located outdoors to avoid the potential accumulation of carbon monoxide indoors. The generator manufacturer agrees that the generator should be located outdoors. AT&T now proposes to locate the backup generator on the southern side of the building adjacent to the existing loading dock for the building.



CONNECTICUT SITING COUNCIL

Affirmative Action / Equal Opportunity Employer