

STATE OF CONNECTICUT

Docket No. 424

Victor Civie


CONNECTICUT SITING COUNCIL

June 15, 2012

Interrogatories 3


Robert E. Carberry, Project Manager  
NEEWS Siting and Permitting  
Northeast Utilities Service Company  
P.O. Box 270  
Hartford, CT 06141-0270

The undersigned respectfully requests your responses to the enclosed interrogatories.



Victor Civie  
160 Beech Mt Road  
Mansfield CT 06250  
860-456-2022

I hereby certify that a copy of the foregoing document was sent electronically or by U.S. mail to the Docket No. 424 service list on June 15, 2012.



Victor Civie

### INTERROGATORIES 3

1. EMF cancellation techniques. Provide a EMF chart (ie mg vs distance) throughout the ROW and beyond of a two 345kv H-frame configuration as proposed in focus area B where EMF cancellations techniques have been used to minimize the EMF fields at one edge of a ROW.

2. In reference to the violations in the report entitled New England East-West Solution (NEEWS):Interstate Reliability Project Component Updated Solution Study Report

a. Question 4.1 in the second set of interrogatories was not addressed. What generation projects at any stage whether or not they received PPA or any other approval were not included in the study. Please include all transmission sources including Real Time Emergency Generation and transmission projects that have not been fully developed.

b. Question 4.1.d clarified from the second set of interrogatories. In reference to the violations, at the time of the violation.

What were the specific conditions of the violations. More specifically, the power values and directions from the study just prior to and after the violations. In addition list the power values and directions prior to and after the violations in lines 395, 3419, 1465, 1870S. Also include the powers values and direction of the Connecticut portion of the new 345kv Greater Springfield Reliability Project Line.