

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: RAW SURFACE WATER ENTRY POINT - CHESTNUT (WSF ID: 00500)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	10/1/23 - 12/31/23		Out of Service
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Surface Water Inorganic Chemicals (RIOCI)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	10/1/23 - 12/31/23		Out of Service
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: RAW SURFACE WATER ENTRY POINT - EUREKA (WSF ID: 00501)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	10/1/23 - 12/31/23		Out of Service
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Surface Water Inorganic Chemicals (RIOCI)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	10/1/23 - 12/31/23		Out of Service
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: RAW SURFACE WATER ENTRY POINT - EUREKA (WSF ID: 00501)

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)	10 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete

Asbestos (1094)	2 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		

Total Coliform (3100)	10 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Disinfectant Byproducts - TTHM & HAA5 (DBP)	2 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING HILL P.S (SWS09)	10/1/23 - 12/31/23	12/1-12/31	Complete
	1/1/24 - 3/31/24	3/1-3/31	
	4/1/24 - 6/30/24	6/1-6/30	
	7/1/24 - 9/30/24	9/1-9/30	
24 DODGINGTOWN RD (SWS10)	10/1/23 - 12/31/23	12/1-12/31	Complete
	1/1/24 - 3/31/24	3/1-3/31	
	4/1/24 - 6/30/24	6/1-6/30	
	7/1/24 - 9/30/24	9/1-9/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU) 20 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/25	6/1-9/30	

Physical Parameters (PPS) 10 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT 1 - CHESTNUT RIDGE (WSF ID: 00700)**

Net Gross Alpha (4000) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/23		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT 1 - CHESTNUT RIDGE (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/21 - 12/31/23		Out of Service
	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/21 - 12/31/23		Out of Service
	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: ENTRY POINT 2 - EUREKA (WSF ID: 00701)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/23		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT 2 - EUREKA (WSF ID: 00701)

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 2 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - EUREKA (3)	1/1/21 - 12/31/23		Out of Service
	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - EUREKA (3)	1/1/21 - 12/31/23		Out of Service
	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Organic Chemicals (VOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - EUREKA (3)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSF ID: 00702)

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MAPLE AVE WELLS (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MAPLE AVE WELLS (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MAPLE AVE WELLS (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MAPLE AVE WELLS (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MAPLE AVE WELLS (3)	1/1/23 - 12/31/23		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSF ID: 00702)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: EUREKA FILTER PLANT (WSF ID: 10)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT - EUREKA (5)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: CHESTNUT RIDGE RESERVOIR (WSF ID: 2001)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHESTNUT RIDGE RES (1)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHESTNUT RIDGE RES (1)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **CHESTNUT RIDGE RESERVOIR (WSF ID: 2001)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **EUREKA LAKE (WSF ID: 2003)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EUREKA LAKE (1)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EUREKA LAKE (1)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **MAPLE AVE WELL 1A (WSF ID: 60721)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **MAPLE AVE WELL 1A (WSF ID: 60721)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MAPLE AVE - WELL 1A (2)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: **MAPLE AVE WELL 2A (WSF ID: 60723)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MAPLE AVE - WELL 2A (2)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: **CHESTNUT RIDGE FILTER PLANT (WSF ID: 9)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT- CHESTNUT RIDGE (5)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT 1 - CHESTNUT RIDGE (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 9/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: ENTRY POINT 1 - CHESTNUT RIDGE (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Water System Facility: ENTRY POINT 2 - EUREKA (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2017		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 7/1/2017		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Water System Facility: EUREKA FILTER PLANT (WSFID: 10)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: CHESTNUT RIDGE FILTER PLANT (WSFID: 9)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a Y
	Offline	12/1/2023 - 12/31/2023	n/a Y
	Offline	1/1/2024 - 1/31/2024	n/a Y
	Offline	2/1/2024 - 2/29/2024	n/a Y
		3/1/2024 - 3/31/2024	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a Y
	Offline	12/1/2023 - 12/31/2023	n/a Y
	Offline	1/1/2024 - 1/31/2024	n/a Y
	Offline	2/1/2024 - 2/29/2024	n/a Y
		3/1/2024 - 3/31/2024	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a Y
	Offline	12/1/2023 - 12/31/2023	n/a Y
	Offline	1/1/2024 - 1/31/2024	n/a Y
	Offline	2/1/2024 - 2/29/2024	n/a Y
		3/1/2024 - 3/31/2024	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
WATERSHED SURVEY REPORT	3/1/2022	
WATERSHED SURVEY REPORT	3/1/2023	
WATERSHED SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

Water System	Water System Facility	Sampling Point	Sampling Point Description	Total Coliform	Lead and Copper	Stage

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Facility ID	Description	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2	DBPR
00500	RAW SURFACE WATER ENTRY POINT - CHESTNUT	1	RAW EP - CHESTNUT	A					
00501	RAW SURFACE WATER ENTRY POINT - EUREKA	1	RAW EP - EUREKA	A					
00502	RAW WELLFIELD ENTRY POINT	2	RAW EP - WELLFIELD	A					
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y				
	ALCS61		36 HIGHLAND AVENUE	A	Y	1			
	ALCS62		78 KINGSWOOD DRIVE	A	Y	2			
	ALCS63		92 KINGSWOOD DRIVE	A	Y	2			
	ALCS64		98 KINGSWOOD DRIVE	A	Y	2			
	ASWS11		10 NASHVILLE RD	A	Y				
	ASWS12		12 MANSFIELD ST	A	Y				
	ASWS13		6 SYMPAUG PARK RD	A	Y				
	ASWS14		17 TROWBRIDGE DR	A	Y				
	ASWS15		81 GREENWOOD AVE	A	Y				
	DOWNSTREAM		WITHIN 5 SERVICE CON	A					
	GWS02		24 GRASSEY PLAIN STE	A	Y				
	GWS03		1 SCHOOL ST	A	Y				
	GWS04		600 WHITLESEY DR	A	Y				
	GWS05		185 GRASSEY PLAIN ST	I	Y				
	GWS06		36 SOUTH ST	A	Y				
	GWS07		1 KINGSWOOD DR	A	Y				
	GWS08		SUMMIT ROAD	A	Y				
	GWS11		154 GRASSEY PLAIN	A	Y				Y
	LCS21		9 SHARON CT	A	Y	1			
	LCS22		1 VERA ST	A	Y	1			
	LCS23		19 SHARON CT	A	Y	1			
	LCS24		80 KINGSWOOD DR	A	Y	2			
	LCS25		76 KNOLLWOOD DR	A	Y	2			
	LCS26		2 PUTNAM PARK RD	A	Y	1			
	LCS27		40 NASHVILLE RD	A	Y	1			
	LCS28		76 KINGSWOOD DR	A	Y	2			
	LCS29		55B KNOLLWOOD DRIVE	A	Y	2			
	LCS30		80 HOYT'S HILL ROAD	A	Y	1			
	LCS31		83 NASHVILLE ROAD	A	Y	1			
	LCS32		5 MAIN STREET #24	A	Y	2			
	LCS33		91 NASHVILLE ROAD	A	Y	1			
	LCS34		12 HIGHVIEW TERRACE	A	Y	1			
	LCS35		21 SHARON COURT	A	Y	1			
	LCS36		14 MILWAUKEE AVENUE	A	Y	1			
	LCS37		7 KAYVIEW AVENUE	A	Y	1			
	LCS38		49 NATURE VIEW TRAIL	A	Y	2			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		LCS39	8 HIGHVIEW TERRACE	A	Y	1		
		LCS40	51 NATURE VIEW TRAIL	A	Y	2		
		LCS41	66 GREENWOOD AVENUE	A	Y	1		
		LCS42	30 HIGHLAND AVENUE	A	Y	1		
		LCS43	24B RESERVOIR STREET	A	Y	1		
		LCS44	10 WHITLOCK AVENUE	A	Y	1		
		LCS45	53A KNOLLWOOD DRIVE	A	Y	2		
		LCS46	57 KNOLLWOOD DRIVE	A	Y	2		
		LCS47	12 BENSON ROAD	A	Y	1		
		LCS48	43B PLUMTREES ACRES	A	Y	2		
		LCS49	45B PLUMTREES ACRES	A	Y	2		
		LCS50	7 MAIN STREET #2	A	Y	2		
		LCS51	27 DEER RUN TRAIL	A	Y	2		
		LCS52	33 DEER RUN TRAIL	A	Y	2		
		LCS53	34 IDLEWOOD DRIVE	A	Y	2		
		LCS54	38 IDLEWOOD DRIVE	A	Y	2		
		LCS55	44 IDLEWOOD DRIVE	A	Y	2		
		LCS56	52 NATURE VIEW TRAIL	A	Y	2		
		LCS57	60 NATURE VIEW TRAIL	A	Y	2		
		LCS58	55 KINGSWOOD DRIVE	A	Y	2		
		LCS59	65 KINGSWOOD DRIVE	A	Y	2		
		LCS60	71 KINGSWOOD DRIVE	A	Y	2		
		SWS01	RESERVOIR ST P.S.	A	Y			
		SWS08	44 CHESTNUT ST	I	Y			Y
		SWS09	SPRING HILL P.S	A	Y			Y
		SWS10	24 DODGINGTOWN RD	A	Y			Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WGWS02	GENERATED BY BATCH	A	Y			
		WGWS03	GENERATED BY BATCH	A	Y			
		WGWS04	GENERATED BY BATCH	A	Y			
		WGWS06	GENERATED BY BATCH	A	Y			
		WGWS07	GENERATED BY BATCH	A	Y			
		WGWS08	GENERATED BY BATCH	A	Y			
		WGWS11	GENERATED BY BATCH	A	Y			
		WSWS01	GENERATED BY BATCH	A	Y			
		WSWS09	GENERATED BY BATCH	A	Y			
		WSWS10	GENERATED BY BATCH	A	Y			
		WSWS11	GENERATED BY BATCH	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00700	ENTRY POINT 1 - CHESTNUT RIDGE	3	EP - CHESTNUT RIDGE	A				
00701	ENTRY POINT 2 - EUREKA	3	EP - EUREKA	A				
00702	ENTRY POINT - MAPLE AVE WELLS	3	EP - MAPLE AVE WELLS	A				
10	EUREKA FILTER PLANT	3	ENTRY POINT - EUREKA	A				
		5	COMBINED FILTER EFFL	A				
1370	MAPLE AVE WELL 1	2	MAPLE AVE WELL 1	A				
1371	MAPLE AVE WELL 2	2	MAPLE AVE WELL 2	A				
2001	CHESTNUT RIDGE RESERVOIR	1	CHESTNUT RIDGE RES	A				
2002	MOUNTAIN POND	1	MOUNTAIN POND	A				
2003	EUREKA LAKE	1	EUREKA LAKE	A				
30013	EUREKA LAKE RESERVOIR INTAKE							
30014	CHESTNUT RIDGE RESERVOIR INTAKE							
46156	MAPLE AVE WELLS TREATMENT PLANT							
51610	CHESTNUT RIDGE CLEARWELLS							
51612	EUREKA WTP CLEARWELLS							
51616	HOYTS HILL BOOSTER STATION							
51618	HOYTS HILL STORAGE TANK							
51621	THE SUMMIT - LOWER PS							
51622	THE SUMMIT - UPPER PS							
58071	INTERCONNECTION - CT0340011 - DANBURY							
59921	SOUTH STREET PUMP STATION							
60721	MAPLE AVE WELL 1A	2	MAPLE AVE - WELL 1A	A				
60723	MAPLE AVE WELL 2A	2	MAPLE AVE - WELL 2A	A				
61053	EUREKA LAKE WATER STORAGE TANK							
61176	BRIAR CLIFF PUMP STATION							
62320	CHESTNUT RIDGE STORAGE TANK							
62322	SUMMIT ATMOSPHERICE TANK							
9	CHESTNUT RIDGE FILTER PLANT	3	ENTRY POINT - CHESTN	A				
		5	COMBINED FILTER EFFL	A				

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CURTIS, KELLY D.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2025
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2024 6/30/2025
KNAPP, EDWARD H.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026

Water System Facility: CHESTNUT RIDGE FILTER PLANT (WSF ID: 9)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KNAPP, EDWARD H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2025 12/31/2024
BECHTOLD, JUSTIN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024 9/30/2026

Water System Facility: EUREKA FILTER PLANT (WSF ID: 10)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KNAPP, EDWARD H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2024 6/30/2025
BECHTOLD, JUSTIN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2026 6/30/2024

Water System Facility: MAPLE AVE WELLS TREATMENT PLANT (WSF ID: 46156)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KNAPP, EDWARD H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2025 12/31/2024
BECHTOLD, JUSTIN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024 9/30/2026

Contact Information

Name		Organization			Job Title	
Mr. Thomas F. Villa		Town of Bethel			Public Utilities Dir	
Mailing Address Line One			Mailing Address Line Two		City	State
1 School Street					Bethel	CT
Zip Code	Business Phone		Extension	Fax	Mobile Phone	Emergency Phone
06801	203-794-8557			203-794-8767		203-313-9982
Email Address			villat@bethel-ct.gov			
Contact Role(s):		Administrative Contact				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			3,300					
Towns Served: BETHEL, DANBURY								
Name			Organization			Job Title		
Mr. Matthew S. Knickerbocker			Town of Bethel			First Selectman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Cjh Municipal Center			1 School Street			Bethel	CT	06801
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-794-8501		203-778-7502	203-482-6731		knickerbockerm@bethel-ct.gov			
Contact Role(s):		Legal Contact						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

Total Coliform (3100) **3 repeat (RP) per period**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/3/24 - 2/8/24		Complete

Total Coliform (3100) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) **5 routine (RT) per six months**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

Physical Parameters (PPS) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT WELL #1 (WSF ID: 00700)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: ENTRY POINT WELL #1 (WSF ID: 00700)

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: ENTRY POINT WELL #2 (WSF ID: 00701)

Nitrate (1040) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: ENTRY POINT WELL #2 (WSF ID: 00701)

Net Gross Alpha (4000)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Uranium (4006)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase II (SOC2)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/23 - 12/31/23		
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Water System Facility: WELL #1 (WSF ID: 1905)			
E. Coli (3014)			1 triggered (TG) per period
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	2/2/24 - 2/8/24		Complete
Water System Facility: WELL #2 (WSF ID: 1906)			
E. Coli (3014)			1 triggered (TG) per period
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: **WELL #2 (WSF ID: 1906)**

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	2/2/24 - 2/8/24		Complete

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2021	
SWTS 1: PWS TO RECOMMEND SOWT	1/3/2022	
CCTS 1: PWS TO RECOMMEND OCCT	1/3/2022	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2022	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	9/30/2022	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2023	
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	9/30/2023	
SANITARY DEFECT CORRECTIVE ACTION	11/2/2023	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/30/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION EXEMPTION	3/1/2026	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
REVISED TOTAL COLIFORM RULE (RTCR) TT Violation	6/25/23 -	2	10/6/2023		10/16/2023	
Physical Parameters M&R Violation	7/1/23 - 7/31/23	3	1/21/2025		1/31/2025	
Total Coliform M&R Violation	7/1/23 - 7/31/23	3	1/21/2025		1/31/2025	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		EC001	BUILDING 83 NUMB 1	A	Y	2	Y	
		EC002	BUILDING 83 NUMB 2	A	Y	2	Y	
		EC003	BUILDING 83 NUMB 3	A	Y	2	Y	
		EC004	BUILDING 83 NUMB 4	A	Y	2	Y	Y
		EC005	BUILDING 83 NUMB 5	A	Y	2	Y	
		EC006	BUILDING 83 NUMB 6	A	Y	2	Y	
		EC007	BUILDING 83 NUMB 7	A	Y	2	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		EC008	BUILDING 83 NUMB 8	A	Y	2	Y	
		EC009	BUILDING NUMB 81	A	Y	2	Y	
		EC010	BUILDING 79 NUMB 1	A	Y	2	Y	
		EC011	BUILDING 79 NUMB 2	A	Y	2	Y	
		EC012	BUILDING 79 NUMB 3	A	Y	2	Y	
		EC013	BUILDING 79 NUMB 4	A	Y	2	Y	
		EC014	BUILDING 79 NUMB 5	A	Y	2	Y	
		EC015	BUILDING 79 NUMB 6	A	Y	2	Y	
		EC016	BUILDING 79 NUMB 7	A	Y	2	Y	
		EC017	BUILDING 79 NUMB 8	A	Y	2	Y	
		EC018	BULDING 77 NUMB 1	A	Y	2	Y	
		EC019	BULDING 77 NUMB 2	A	Y	2	Y	
		EC020	BULDING 77 NUMB 3	A	Y	2	Y	
		EC021	BULDING 77 NUMB 4	A	Y	2	Y	
		EC022	BUILDING 73 NUMB 1	A	Y	2	Y	
		EC023	BUILDING 73 NUMB 2	A	Y	2	Y	
		EC024	BUILDING 73 NUMB 3	A	Y	2	Y	
		EC025	BUILDING 73 NUMB 4	A	Y	2	Y	
		EC026	BUILDING 73 NUMB 5	A	Y	2	Y	
		EC027	APARTMENT 5	A	Y	2	Y	
		EC028	LEAD COPPER APT 4	A	Y	2		
		EC029	LOT 81 C/L	A	Y	2	Y	
		EC030	APT 2 LOT 83	A	Y	2	Y	
		OFFSINK	OFFICE SINK	I	Y	2	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT WELL #1	3	ENTRY POINT WELL #1	A				
00701	ENTRY POINT WELL #2	3	ENTRY POINT WELL #2	A				
1905	WELL #1	2	WELL	A				
1906	WELL #2	2	WELL #2	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

Contact Information

Name	Organization	Job Title		
Mr. Gregory M. Kallas		Member		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			
Towns Served: BETHEL							
5 Bernlou Drive			Danbury		CT	06811	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-733-1983				203-792-6876	gregorykallas@gmail.com		
Contact Role(s):	Administrative Contact, Legal Contact, Owner						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule