

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0580072</b>	<b>PACHAUG MARINA CAMPGROUND</b>	NTNC	310	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
262 SHETUCKET TURNPIKE (RT 165)			124				

Towns Served: GRISWOLD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Asbestos (1094)** **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28	4/1-10/31	

**Total Coliform (3100)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

**Lead And Copper (PBCU)** **10 routine (RT) per six months**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

**Physical Parameters (PPS)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23	10/1-10/31	Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

**Inorganic Chemicals (IOCS)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Nitrate And Nitrite (NOX)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

**Pesticides, Herbicides and PCBs - Phase II & V (SOCS)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Organic Chemicals (VOCS)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0580072</b>	<b>PACHAUG MARINA CAMPGROUND</b>	NTNC	310	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
262 SHETUCKET TURNPIKE (RT 165)			124				

Towns Served: GRISWOLD

## Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ( )	Maximum: 7.6 PH	4
<b>Start Date:</b> 5/1/2018		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	4
<b>Start Date:</b> 5/1/2018		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
	Offline	11/1/2023 - 11/30/2023	n/a Y
	Offline	12/1/2023 - 12/31/2023	n/a Y
	Offline	1/1/2024 - 1/31/2024	n/a Y
	Offline	2/1/2024 - 2/29/2024	n/a Y
		3/1/2024 - 3/31/2024	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2024	
SEASONAL START UP COMPLETION	4/15/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MH019-CH	CLUBHOUSE	A	Y	N	Y	
		MW019	CLUBHOUSE	A	Y	N	Y	
		MW019-110	LOT 110	A	Y	N	Y	
		MW019-43	LOT 43	A	Y	N	Y	
		MW019-5	LOT 5	A	Y	N	Y	
		MW019-7	LOT 7	A	Y	N	Y	
		MW019-77	LOT 77	A	Y	N	Y	
		MW019-CH	CLUBHOUSE	A	Y	N	Y	
		PMC-1	LOT 1	A	Y	N	Y	
		PMC-100	LOT 100	A	Y	N	Y	
		PMC-102	LOT 102	A	Y	N	Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0580072</b>	<b>PACHAUG MARINA CAMPGROUND</b>	NTNC	310	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
262 SHETUCKET TURNPIKE (RT 165)			124				

Towns Served: GRISWOLD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		PMC-103	LOT 103	A	Y	N	Y	
		PMC-109	LOT 109	A	Y	N	Y	
		PMC-114	LOT 114	A	Y	N	Y	
		PMC-115	LOT 115	P	Y	N		
		PMC-12	LOT 12	P	Y	N		
		PMC-121	LOT 121	A	Y	N	Y	
		PMC-13	LOT 13	A	Y	N	Y	
		PMC-15	LOT 15	P	Y	N		
		PMC-17	LOT 17	A	Y	N	Y	
		PMC-2	LOT 2	A	Y	N	Y	
		PMC-21A	LOT 21A	P	Y	N		
		PMC-22	LOT 22	A	Y	N	Y	
		PMC-28	LOT 28	A	Y	N	Y	
		PMC-29	LOT 29	A	Y	N	Y	
		PMC-30	LOT 30	P	Y	N		
		PMC-34	LOT 34	A	Y	N	Y	
		PMC-36	LOT 36	P	Y	N		
		PMC-38	LOT 38	A	Y	N	Y	
		PMC-47	LOT 47	A	Y	N	Y	
		PMC-48	LOT 48	A	Y	N	Y	
		PMC-53	LOT 53	A	Y	N	Y	
		PMC-54	LOT 54	A	Y	N	Y	
		PMC-57	LOT 57	A	Y	N	Y	
		PMC-61	LOT 61	P	Y	N		
		PMC-62	LOT 62	A	Y	N	Y	
		PMC-65	LOT 65	A	Y	N	Y	
		PMC-70	LOT 70	A	Y	N	Y	
		PMC-73	DISTRIBUTION SYSTEM	A	Y	N	Y	
		PMC-79	LOT 79	P	Y	N		
		PMC-8	LOT 8	P	Y	N		
		PMC-80	LOT 80	A	Y	N	Y	
		PMC-85	LOT 85	P	Y	N		
		PMC-88	LOT 88	P	Y	N		
		PMC-93	LOT 93	P	Y	N		
		PMC-95	LOT 95	A	Y	N	Y	
		PMC-97	LOT 97	A	Y	N	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10274	WELL 2	2	WELL 2	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0580072</b>	<b>PACHAUG MARINA CAMPGROUND</b>	NTNC	310	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
262 SHETUCKET TURNPIKE (RT 165)			124				
Towns Served: GRISWOLD							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
52829	WELL 1	2	WELL 1	A				
57670	ATMOSPHERIC STORAGE							
57672	BOOSTER PUMP							
61057	TREATMENT PLANT							

## Certified Operator Information

**Water System Facility:** TREATMENT PLANT (WSF ID: 61057)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2024
HARKINS, STUART A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2025

## Contact Information

Name			Organization			Job Title		
<b>Mr. Michael Lester</b>			Northeast Property Management			Property Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
150 Eugene O'neill Drive						New London	CT	06320
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-437-7005	110			860-705-8937	mlester@neproperty.com			

**Contact Role(s):** Administrative Contact, Legal Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0580084</b>	<b>TULLI'S TAP HOUSE AT RIVER RIDGE</b>	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
259 PRESTON ROAD				1			

Towns Served: GRISWOLD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete		
	1/1/24 - 3/31/24		Complete		
	4/1/24 - 6/30/24				
	7/1/24 - 9/30/24				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/23	6/1-9/30	Complete		
	1/1/24 - 12/31/26	6/1-9/30			
	1/1/27 - 12/31/29	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete		
	1/1/24 - 3/31/24		Complete		
	4/1/24 - 6/30/24				
	7/1/24 - 9/30/24				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete		
	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/21 - 12/31/23		Complete		
	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/21 - 12/31/23		Complete		
	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0580084	TULLI'S TAP HOUSE AT RIVER RIDGE	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
259 PRESTON ROAD				1			

Towns Served: GRISWOLD

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		OM8000	PREP POT SINK	A	Y	N		
		OM8001	KITCHEN SINK 2	A	Y	N		
		OM8002	MENS ROOM	A	Y	N	Y	
		OM8003	BAR SINK	A	Y	N		
		OM8004	WOMENS ROOM	A	Y	N		
		RRG01	PREP HAND SINK	A	Y	N		
		RRG02	KITCHEN SLOP SINK	A	Y	N		
		RRG03	KITCHEN POT SINK	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10275	WELL1	2	WELL1	A				
52188	IRON REMOVAL TREATMENT SYSTEM							
62128	BLADDER TANK							

## Certified Operator Information

Water System Facility: **IRON REMOVAL TREATMENT SYSTEM (WSF ID: 52188)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADICCHI, PAUL J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2024

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0580084</b>	<b>TULLI'S TAP HOUSE AT RIVER RIDGE</b>	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
259 PRESTON ROAD				1			
Towns Served: GRISWOLD							

## Contact Information

Name		Organization			Job Title			
<b>Ms. Pamela Soares</b>		Tullis Tap House - River Ridge			Property Owner			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
259 Preston Road						Griswold	CT	06351
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-376-3268		860-376-7024		860-912-8592	pams194@comcast.net			

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title			
<b>Mr. Albert M. Tulli III</b>		Tullis Tap House - River Ridge			Restaurant Owner			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
259 Preston Road						Griswold	CT	06351
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-591-1047				860-377-8465	tullistaphouse@gmail.com			

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**