

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0815051	MIDDLEBURY COMMONS	C	76	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6				

Towns Served: MIDDLEBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete		
	1/1/24 - 3/31/24		Complete		
	4/1/24 - 6/30/24				
	7/1/24 - 9/30/24				
Lead And Copper (PBCU)		5 routine (RT) per six months			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete		
	1/1/24 - 6/30/24		Complete		
	7/1/24 - 12/31/24				
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete		
	1/1/24 - 3/31/24		Complete		
	4/1/24 - 6/30/24				
	7/1/24 - 9/30/24				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Uranium (4006)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Combined Radium-226/228 (4010)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/21 - 12/31/23		Complete		
	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0815051	MIDDLEBURY COMMONS	C	76	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6				

Towns Served: MIDDLEBURY

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 10/1/2006		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.2 PH	Daily
Start Date: 1/1/2006		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SAMPLING SITE PLAN	6/15/2020	
RESPOND TO SANITARY SURVEY	8/19/2021	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0815051	MIDDLEBURY COMMONS	C	76	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		6					

Towns Served: MIDDLEBURY

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2028	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
401	WELL #1	2	WELL #1	A				
402	WELL #2	2	WELL #2	A				
440	MIDDLEBURY COMMONS PUMPHOUSE							
51069	ATMOSPHERIC TANK							
51071	HYDROPNEUMATIC TANK							

Certified Operator Information

Water System Facility: MIDDLEBURY COMMONS PUMPHOUSE (WSF ID: 440)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
WEID, JEREMIAH J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2024

Contact Information

Name		Organization			Job Title		
Ms. Joanne Cappelletti		Middlebury Commons			Treasurer		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
35 Nutmeg Road- F1					Middlebury	CT	06762
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-758-1160		203-577-4173		203-577-4166	jcappelletti@middlebury-ct.org		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0819031	CTWC - NAUGATUCK REG - HILLCREST	C	120	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			29				

Towns Served: MIDDLEBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
40 MIDDLEBURY RD (2160)	10/1/23 - 12/31/23	12/1-12/31	Complete
	1/1/24 - 3/31/24	3/1-3/31	Complete
	4/1/24 - 6/30/24	6/1-6/30	
	7/1/24 - 9/30/24	9/1-9/30	
Lead And Copper (PBCU)	10 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0819031	CTWC - NAUGATUCK REG - HILLCREST	C	120	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		29			

Towns Served: MIDDLEBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS) **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water Quality Parameters Total Orthophosphate Distribution (WQP7) **2 routine (RT) per six months**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	2059	DISTRIBUTION SYSTEM	A	Y			
		2160	40 MIDDLEBURY RD	A	Y	3		Y
		2161	24 RICHARDSON DR	A	Y	3		
		2162	28 RICHARDSON DR	A	Y	3		
		2163	36 RICHARDSON DR	A		3		
		2164	40 RICHARDSON DR	A	Y	3		
		2165	48 RICHARDSON DR	A	Y	3		
		2167	67 RICHARDSON DR	A	Y	3		
		2168	79 RICHARDSON DR	A	Y	3		
		2169	103 RICHARDSON DR	A	Y	3		
		2170	115 RICHARDSON DR	A	Y	3		
		2171	1201 STRAITS TNPK	A	Y	3		
		2172	1215 STRAITS TNPK	A	Y	3		
		2173	1232 STRAITS TNPK	A	Y	3		
		2174	1238 STRAITS TNPK	A	Y	3		
		2175	1248 STRAITS TNPK	A	Y	3		
		2176	1252 STRAITS TNPK	A	Y	3		
		2177	1264 STRAITS TNPK	A	Y	3		
		2178	1274 STRAITS TNPK	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0819031	CTWC - NAUGATUCK REG - HILLCREST	C	120	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		29					

Towns Served: MIDDLEBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		2179	1292 STRAITS TNPK	A	Y	3		
		2180	1298 STRAITS TNPK	A	Y	3		
		2181	53 FOSTER ST	A	Y	3		
		2182	1 REYNOLDS DR	A	Y	3		
		2183	2 REYNOLDS DR	A	Y	3		
		2184	19 RICHARDSON DR	A	Y	3		
		2185	56 RICHARDSON DR	A	Y	3		
		2186	64 RICHARDSON DR	A	Y	3		
		2187	91 RICHARDSON DR	A	Y	3		
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

62593 INTERCONNECTION - CTWC
CENTRAL SYSTEM

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2025 6/30/2026

Contact Information

Name		Organization			Job Title	
Mr. Craig J. Patla		Connecticut Water Company			Vp, Service Delivery	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6140				800-391-1924	craig.patla@ctwater.com	

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title	
Mr. Gerald McDermott		The Connecticut Water Company			Manager, Service Del	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6125					ctwcdphadmin@ctwater.com	

Contact Role(s): **Administrative Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0819031	CTWC - NAUGATUCK REG - HILLCREST	C	120	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		29					

Towns Served: MIDDLEBURY

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0819061	AQUARION WATER CO OF CT-WEST SHORE	C	100	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST LAKE ROAD			24				

Towns Served: MIDDLEBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) 1 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

Asbestos (1094) 1 routine (RT) per nine years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/24		Complete
	1/1/25 - 12/31/33		

Total Coliform (3100) 1 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Disinfectant Byproducts - TTHM & HAA5 (DBP) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WEST LAKE RD SS (04862)	1/1/23 - 12/31/23	8/1-8/31	Complete
	1/1/24 - 12/31/24	8/1-8/31	
	1/1/25 - 12/31/25	8/1-8/31	

Lead And Copper (PBCU) 5 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/25	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0819061	AQUARION WATER CO OF CT-WEST SHORE	C	100	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST LAKE ROAD			24				
Towns Served: MIDDLEBURY							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/21 - 12/31/23		Complete
	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0819061	AQUARION WATER CO OF CT-WEST SHORE	C	100	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST LAKE ROAD			24				

Towns Served: MIDDLEBURY

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2016			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023	Y	
	12/1/2023 - 12/31/2023	Y	
	1/1/2024 - 1/31/2024	Y	
	2/1/2024 - 2/29/2024	Y	
	3/1/2024 - 3/31/2024		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	4
Start Date: 4/1/2020			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023	Y	
	12/1/2023 - 12/31/2023	Y	
	1/1/2024 - 1/31/2024	Y	
	2/1/2024 - 2/29/2024	Y	
	3/1/2024 - 3/31/2024		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Maximum: 7.8 PH	4
Start Date: 4/1/2020			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	8/18/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
pH M&R Violation	2/1/15 - 2/28/15	3	4/15/2016		4/25/2016	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0819061	AQUARION WATER CO OF CT-WEST SHORE	C	100	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST LAKE ROAD		24					
Towns Served: MIDDLEBURY							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04858	WEST SHORE DIST PT 1	A	Y			
		04862	WEST LAKE RD SS	A	Y		Y	Y
		4	DISTRIBUTION SYSTEM	A				
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
		PB7422	6 WEST LAKE RD	A		N		
		PB7541	3 WEST LAKE RD	A		3		
		PB7887	17 WEST LAKE RD	A		Y	N	
		PB7888	19 WEST LAKE RD	A		N		
		PB7889	18 WEST LAKE RD	A		N		
		PB8366	21 WEST LAKE RD	A		N		
	UPSTREAM WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A				
59286	WELL #2	2	WELL #2	A				
59288	WELL #3	2	WELL #3	A				
59290	WELL #4	2	WELL #4	A				
59294	ATMOSPHERIC TANKS							
59296	BOOSTER STATION							
59300	TREATMENT PLANT							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 59300)			
Facility Classification: CLASS 1 TREATMENT PLANT			
			<i>Certification Expiration</i>
Operator Name	Operator Type	Certification(s)	
BURKE, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2025

Contact Information

Name		Organization			Job Title		
Mr. John P. Walsh		Aquarion Water Company			Vice President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
835 Main Street		Mail Stop 700			Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com		
Contact Role(s): Legal Contact							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0819061	AQUARION WATER CO OF CT-WEST SHORE	C	100	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
WEST LAKE ROAD			24					
Towns Served: MIDDLEBURY								
Name			Organization			Job Title		
Mr. Robert J. Ulrich			Aquarion Water Company of Ct			Vp-Supply & Utility		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Aquarion Water Company of Ct			505 Huntington St.			Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule