

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) 3 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		

Total Coliform (3100) 3 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Disinfectant Byproducts - TTHM & HAA5 (DBP) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
82 LILIBRIDGE ROAD (G4549)	1/1/23 - 12/31/23	8/1-8/31	Complete
	1/1/24 - 12/31/24	8/1-8/31	
	1/1/25 - 12/31/25	8/1-8/31	

Lead And Copper (PBCU) 20 routine (RT) per six months

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

Physical Parameters (PPS) 3 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	3 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT - WELL 1 (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1 (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - WELL 2 (WSF ID: 00701)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 2 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 2 (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 2 (3)	1/1/24 - 12/31/32		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 2 (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 2 (3)	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: WELL 1 (WSF ID: 1215)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **WELL 1 (WSF ID: 1215)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
9/1/24 - 9/30/24			
10/1/24 - 10/31/24			

Water System Facility: **WELL 2 (WSF ID: 1216)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		
	2/1/24 - 2/29/24		
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
9/1/24 - 9/30/24			
10/1/24 - 10/31/24			

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - WELL 1 (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Water System Facility: ENTRY POINT - WELL 1 (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
3/1/2024 - 3/31/2024			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				Y
		G4549	82 LILIBRIDGE ROAD	A				
		G4550	44 RR AVE	A	Y			
		G4551	22 FERNWOOD ST	A		3		
		G4552	4 JAMES ST	A		3		
		G4553	1 MAPLESHADE AVE	A		3		
		G4554	40 MAPLESHADE AVE	A		3		
		G4555	12 EASY ST	A		N		
		G4556	15 ROBIN RD	A		3		
		G4557	55 BEECHWOOD BLVD	A		1		
		G4558	10 SPRING ST	A		N		
		G4559	19 EASY ST	A		3		
		G4560	1 ROBIN ST	A		3		
		G4561	3 JAMES ST	A		3		
		G4562	10 BIRCH ST	A		3		
		G4563	30 FERNWOOD	A		3		
		G4564	7 S. PINE ST	A		3		
		G4565	12 JAMES ST	A		3		
		G4566	1 JAMES ST	A		3		
		G4567	13 FERNWOOD	A		3		
		G4568	11 BUTTERNUT RD	A		3		
		G4569	58 BEECHWOOD BLVD	A		3		
		G4570	8 BEECHWOOD BLVD	A		3		
		G4571	720 NORWICH ROAD	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		G4572	4 WEST PARKWAY	A	Y			
		G4573	59 BEECHWOOD BLVD	A		1		
		G4574	63 BEECHWOOD BLVD	A		1		
		G4575	67 BEECHWOOD BLVD	A		1		
		G4576	68 BEECHWOOD BLVD	A		1		
		G4577	71 BEECHWOOD BLVD	A		1		
		G4578	72 BEECHWOOD BLVD	A		1		
		G4579	75 BEECHWOOD BLVD	A		1		
		G4580	76 BEECHWOOD BLVD	A		1		
		G4581	5 BLOOM DR	A		1		
		G4582	7 BLOOM DR	A		1		
		G4583	8 BLOOM DR	A		1		
		G4584	9 BLOOM DR	A		1		
		G4585	11 BLOOM DR	A		1		
		G4586	14 BLOOM DR	A		1		
		G4587	15 BLOOM DR	A		1		
		G4588	18 BLOOM DR	A		1		
		G4589	4 CARRIE LANE	A		1		
		G4590	7 CHARLES ST	A		1		
		G4591	22 COLONIAL RD	A		1		
		G4592	26 COLONIAL RD	A		1		
		G4593	30 COLONIAL RD	A		1		
		G4594	32 COLONIAL RD	A		1		
		G4595	34 COLONIAL RD	A		1		
		G4596	3 CONNECTICUT DR	A		1		
		G4597	7 CONNECTICUT DR	A		1		
		G4598	15 CONNECTICUT DR	A		1		
		G4599	21 CONNECTICUT DR	A		1		
		G4600	26 CONNECTICUT DR	A		1		
		G4601	28 CONNECTICUT DR	A		1		
		G4602	29 CONNECTICUT DR	A		1		
		G4603	30 CONNECTICUT DR	A		1		
		G4604	34 CONNECTICUT DR	A		1		
		G4605	35 CONNECTICUT DR	A		1		
		G4606	36 CONNECTICUT DR	A		1		
		G4607	40 CONNECTICUT DR	A		1		
		G4608	41 CONNECTICUT DR	A		1		
		G4609	42 CONNECTICUT DR	A		1		
		G4610	44 CONNECTICUT DR	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		G4611	46 CONNECTICUT DR	A		1		
		G4612	48 CONNECTICUT DR	A		1		
		G4613	49 CONNECTICUT DR	A		1		
		G4614	50 CONNECTICUT DR	A		1		
		G4615	60 CONNECTICUT DR	A		1		
		G4616	8 ERIN DR	A		1		
		G4617	13 ERIN DR	A		1		
		G4618	21 ERIN DR	A		1		
		G4619	40 ERIN DR	A		1		
		G4620	48 ERIN DR	A		1		
		G4621	12 HEMLOCK DR	A		1		
		G4622	30 HEMLOCK DR	A		1		
		G4623	5 JAMES ST	A		1		
		G4624	21 OAKWOOD BLVD	A		1		
		G4625	40 PARK AVE	A		1		
		G4626	18 BEECHWOOD BLVD	A		3		
		G4627	24 BEECHWOOD BLVD	A		3		
		G4628	28 BEECHWOOD BLVD	A		3		
		G4629	33 BEECHWOOD BLVD	A		3		
		G4630	34 BEECHWOOD BLVD	A		3		
		G4631	39 BEECHWOOD BLVD	A		3		
		G4632	42 BEECHWOOD BLVD	A		3		
		G4633	49 BEECHWOOD BLVD	A		3		
		G4634	50 BEECHWOOD BLVD	A		3		
		G4635	53 BEECHWOOD BLVD	A		3		
		G4636	64 BEECHWOOD BLVD	A		3		
		G4637	44 ERIN DR	A		3		
		G4638	47 FERNWOOD ST	A		3		
		G4639	48 FERNWOOD ST	A		3		
		G4640	9 GOLDEN DR	A		3		
		G4641	33 MAPLESHADE AVE	A		3		
		G4642	39 MAPLESHADE AVE	A		3		
		G4643	9 OAK ST	A		3		
		G4644	11 OAKWOOD BLVD	A		3		
		G4645	14 OAKWOOD BLVD	A		3		
		G4646	25 OAKWOOD BLVD	A		3		
		G4647	31 OAKWOOD BLVD	A		3		
		G4648	35 OAKWOOD BLVD	A		3		
		G4649	39 OAKWOOD BLVD	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		G4650	45 OAKWOOD BLVD	A		3		
		G4651	48 OAKWOOD BLVD	A		3		
		G4652	54 OAKWOOD BLVD	A		3		
		G4653	55 OAKWOOD BLVD	A		3		
		G4654	59 OAKWOOD BLVD	A		3		
		G4655	60 OAKWOOD BLVD	A		3		
		G4656	64 OAKWOOD BLVD	A		3		
		G4657	65 OAKWOOD BLVD	A		3		
		G4658	67 OAKWOOD BLVD	A		3		
		G4659	17 PINE ST	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELL 1	3	EP - WELL 1	A				
00701	ENTRY POINT - WELL 2	3	EP - WELL 2	A				
1215	WELL 1	2	WELL 1	A				
1216	WELL 2	2	WELL 2	A				
224	GALLUP WATER SERVICE - WELL 1							
46521	PARK AVE PRESSURE TANKS							
46523	PLAINFIELD INDUSTRIAL PARK TANK 1							
46525	PLAINFIELD INDUSTRIAL PARK TANK 2							
52581	RUTH DRIVE PUMP STATION							
61526	GALLUP WATER SERVICE - WELL 2							
62072	INTERCONNECTION - CT1090081 - PLAINFIELD							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CONNORS, JAMES	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2024
SEHL, ROBERT A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 3/31/2025

Water System Facility: GALLUP WATER SERVICE - WELL 1 (WSF ID: 224)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WILCOX, MELISSA	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2025
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090031	CTWC - GALLUP SYSTEM	C	2,538	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			977	82	26		

Towns Served: PLAINFIELD

Certified Operator Information

Water System Facility: **GALLUP WATER SERVICE - WELL 2 (WSF ID: 61526)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WILCOX, MELISSA	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2025
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Contact Information

Name		Organization			Job Title		
Mr. Craig J. Patla		Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
93 West Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-664-6140				800-391-1924	craig.patla@ctwater.com		

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title		
Mr. Paul C. Lowry		Connecticut Water Company			Manager		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
93 W Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-292-2809		860-654-1903		800-208-5700	ctwcdphadmin@ctwater.com		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
219 MAIN ST, MOOSUP (P4450)	1/1/23 - 12/31/23	8/10-8/16	Complete
	1/1/24 - 12/31/24	8/10-8/16	
	1/1/25 - 12/31/25	8/10-8/16	
Lead And Copper (PBCU)	20 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		
Physical Parameters (PPS)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **TREATMENT PLANT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: **WELL 1 (WSF ID: 1330)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Monitoring Requirements

Water System Facility: **WELL 1 (WSF ID: 1330)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 2 (WSF ID: 1331)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **TREATMENT PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2008		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility: **TREATMENT PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 4/1/2009		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 4/1/2009		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		P4450	219 MAIN ST, MOOSUP	A	Y			Y
		P4451	57 WAUREGAN RD	A	Y			
		P4452	37 CHARLOTTE DR	A		1		
		P4453	18 CHARLOTTE DR	A		1		
		P4454	22 CHARLOTTE DR	A		1		
		P4455	21 CHARLOTTE DR	A		1		
		P4456	4 CHARLOTTE DR	A		1		
		P4457	8 CHARLOTTE DR	A		1		
		P4458	38 CHARLOTTE DR	A		1		
		P4459	27 CHARLOTTE DR	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		605	44	7	20		

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		P4460	28 CHARLOTTE DR	A		1		
		P4461	32 CHARLOTTE DR	A		1		
		P4462	234 SHEPARD HILL RD.	A	Y			
		P4463	9 LORI DR.	A	Y			
		P4464	112 E SHEPARD HILL R	A	Y	1		
		P4465	79 CRANSKA OAKS RD	A	Y	1		
		P4466	5 CHARLOTTE DR	A	Y	1		
		P4467	11 CHARLOTTE DR	A	Y	1		
		P4468	12 CHARLOTTE DR	A	Y	1		
		P4469	17 CHARLOTTE DR	A	Y	1		
		P4470	33 CHARLOTTE DR	A	Y	1		
		P4471	209 SHEPARD HILL RD	A	Y	1		
		P4472	225 SHEPARD HILL RD	A	Y	1		
		P4473	229 SHEPARD HILL RD	A	Y	1		
		P4474	235 SHEPARD HILL RD	A	Y	1		
		P4475	249 SHEPARD HILL RD	A	Y	1		
		P4476	106 E SHEPARD HILL R	A	Y	3		
		P4477	40 MAIN ST	A	Y	3		
		P4478	15 PUTNAM RD	A	Y	3		
		P4479	17 PUTNAM RD	A	Y	3		
		P4480	43 ALLEN ST	A	Y	3		
		P4481	61 ALLEN ST	A	Y	3		
		P4482	6 BITGOOD VILLAGE	A	Y	3		
		P4483	7 BITGOOD VILLAGE	A	Y	3		
		P4484	10 BITGOOD VILLAGE	A	Y	3		
		P4485	15 BITGOOD VILLAGE	A	Y	3		
		P4486	22 BITGOOD VILLAGE	A	Y	3		
		P4487	23 BITGOOD VILLAGE	A	Y	3		
		P4488	27 BITGOOD VILLAGE	A	Y	3		
		P4489	32 BITGOOD VILLAGE	A	Y	3		
		P4490	34 BITGOOD VILLAGE	A	Y	3		
		P4491	36 BITGOOD VILLAGE	A	Y	3		
		P4492	26 BITGOOD VLG	A	Y	3		
		P4493	35 CHURCH ST	A	Y	3		
		P4494	51 CRANSKA OAKS RD	A	Y	3		
		P4495	67 CRANSKA OAKS RD	A	Y	3		
		P4496	75 CRANSKA OAKS RD	A	Y	3		
		P4497	1 CRANSKA RD	A	Y	3		
		P4498	21 CRANSKA RD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		P4499	77 CRANSKA RD	A	Y	3		
		P4500	28 DAGGETT ST	A	Y	3		
		P4501	48 DAGGETT ST	A	Y	3		
		P4502	55 DAGGETT ST	A	Y	3		
		P4503	63 DAGGETT ST	A	Y	3		
		P4504	18 GROVE ST	A	Y	3		
		P4505	8-10 LAKE ST	A	Y	3		
		P4506	4 LINNELL ST	A	Y	3		
		P4507	16 LINNELL ST	A	Y	3		
		P4508	17 LINNELL ST	A	Y	3		
		P4509	25 LINNELL ST	A	Y	3		
		P4510	51 MAIN ST	A	Y	3		
		P4511	57 MAIN ST	A	Y	3		
		P4512	77 MAIN ST	A	Y	3		
		P4513	87 MAIN ST	A	Y	3		
		P4514	121 MAIN ST	A	Y	3		
		P4515	133 MAIN ST	A	Y	3		
		P4516	143 MAIN ST	A	Y	3		
		P4517	179 MAIN ST	A	Y	3		
		P4518	191 MAIN ST	A	Y	3		
		P4519	6 POTVIN AVE	A	Y	3		
		P4520	30 POTVIN AVE	A	Y	3		
		P4521	85 PROSPECT ST	A	Y	3		
		P4522	40 RIVER ST	A	Y	3		
		P4523	21 TURCOTTE AVE	A	Y	3		
		P4524	23 TURCOTTE AVE	A	Y	3		
		P4525	29 UNION ST	A	Y	3		
		P4526	1 BLUEBERRY LANE	A	Y	3		
		P4527	2 BLUEBERRY LANE	A	Y	3		
		P4528	3 BLUEBERRY LANE	A	Y	3		
		P4529	4 BLUEBERRY LANE	A	Y	3		
		P4530	6 BLUEBERRY LANE	A	Y	3		
		P4531	5 BLUEBERRY LANE	A	Y	3		
		P4532	7 BLUEBERRY LANE	A	Y	3		
		P4533	8 BLUEBERRY LANE	A	Y	3		
		P4534	4 GROVE ST	A	Y	3		
		P4535	2 MOOSUP POND RD	A	Y	3		
		P4536	4 MOOSUP POND RD	A	Y	3		
		P4537	8 MOOSUP POND RD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		605	44	7	20		

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		P4538	12 MOOSUP POND RD	A	Y	3		
		P4539	1 PATTY LANE	A	Y	3		
		P4540	2 PATTY LANE	A	Y	3		
		P4541	3 PATTY LANE	A	Y	3		
		P4542	4 PATTY LANE	A	Y	3		
		P4543	5 PATTY LANE	A	Y	3		
		P4544	6 PATTY LANE	A	Y	3		
		P4545	2 PLAINVIEW DR	A	Y	3		
		P4546	3 PLAINVIEW DR	A	Y	3		
		P4547	4 PLAINVIEW DR	A	Y	3		
		P4548	5 PLAINVIEW DR	A	Y	3		
		P4549	6 PLAINVIEW DR	A	Y	3		
		P4550	7 PLAINVIEW DR	A	Y	3		
		P4551	193 SHEPHERD HILL RD	A	Y	3		
		P5000	MARIE ST SMP STAT	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	TREATMENT PLANT	3	ENTRY POINT	A				
1330	WELL 1	2	WELL 1	A				
1331	WELL 2	2	WELL 2	A				
1332	WELL 3	2	WELL 3	A				
46519	STORAGE TANK 2							
62074	INTERCONNECTION - CT1090031 - GALLUP							
62387	PATTY LANE TANK							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CONNORS, JAMES	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2024
LEPINE, TODD	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026

Water System Facility: TREATMENT PLANT (WSF ID: 00700)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WILCOX, MELISSA	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2025
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090081	CTWC - PLAINFIELD SYSTEM	C	1,713	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			605	44	7	20	

Towns Served: BROOKLYN, KILLINGLY, PLAINFIELD

Contact Information

Name		Organization			Job Title		
Mr. Craig J. Patla		Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
93 West Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-664-6140				800-391-1924	craig.patla@ctwater.com		

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title		
Mr. Paul C. Lowry		Connecticut Water Company			Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
93 W Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-292-2809		860-654-1903		800-208-5700	ctwcdphadmin@ctwater.com		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		

Total Coliform (3100) **3 repeat (RP) per period**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/19/23 - 12/24/23		Complete

Total Coliform (3100) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) **5 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/27	6/1-9/30	

Physical Parameters (PPS) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: WELL 1 (WSF ID: 1103)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **WELL 1 (WSF ID: 1103)**

E. Coli (3014) **1 triggered (TG) per period**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	12/18/23 - 12/24/23		Complete

E. Coli (3014) **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION EXEMPTION	3/1/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WT001	1 TERRACE DRIVE	A	Y	N		
		WT002	2 TERRACE DRIVE	A		N		
		WT003	3 TERRACE DRIVE	A	Y	N		
		WT004	4 TERRACE DRIVE	A		N		
		WT005	5 TERRACE DRIVE	A	Y	N		
		WT006	6 TERRACE DRIVE	A		N		
		WT007	7 TERRACE DRIVE	A		N		
		WT008	8 TERRACE DRIVE	A		N		
		WT009	9 TERRACE DRIVE	A		N		
		WT010	10 TERRACE DRIVE	A		N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		WT011	11 TERRACE DRIVE	A		N		
		WT012	12 TERRACE DRIVE	A	Y	N		
		WT013	13 TERRACE DRIVE	A		N		
		WT014	14 TERRACE DRIVE	A		N		
		WT015	15 TERRACE DRIVE	A		N		
		WT016	16 TERRACE DRIVE	A		N		
		WT017	17 TERRACE DRIVE	A		N		
		WT018	18 TERRACE DRIVE	A		N		
		WT019	19 TERRACE DRIVE	A		N		
		WT020	20 TERRACE DRIVE	A		N		
		WT021	21 TERRACE DRIVE	A		N		
		WT022	22 TERRACE DRIVE	A		N		
		WT023	23 TERRACE DRIVE	A	Y	N		
		WT024	24 TERRACE DRIVE	A		N		
		WT025	25 TERRACE DRIVE	A		N		
00700	ENTRY POINT	3	ENTRY POINT	A				
1103	WELL 1	2	WELL 2	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2024
LAFRAMBOISE, ERIC	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
STARK, TYLER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2025

Contact Information

Name		Organization			Job Title		
Mr. Matthew J Ricciardella		Crystal View Capital			Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
9515 Hillwood Dr.					Las Vegas	NV	89134
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
702-541-6379				959-207-8240	jenniferm@crystalviewcapital.com		
Contact Role(s):		Administrative Contact, Owner					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090161	WESTVIEW TERRACE MOBILE HOME PARK	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		24					

Towns Served: PLAINFIELD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 GORMAN ST, MOOSUP			89				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		

Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) 10 routine (RT) per six months

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

Physical Parameters (PPS) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 GORMAN ST, MOOSUP			89				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	<spaces> ()	Maximum: 3.0 MG/L	2
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 GORMAN ST, MOOSUP			89				

Towns Served: PLAINFIELD

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	<spaces> ()	Maximum: 3.0 MG/L	2
Start Date: 1/1/2023		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.5 MG/L	2
Start Date: 1/1/2023		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.3 PH	Daily
Start Date: 9/1/2016		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	
pH	<spaces> ()	Maximum: 7.8 PH	Daily
Start Date: 9/1/2016		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	
Phosphate (as PO4)	<spaces> ()	Minimum: 0.1 MG/L	2
Start Date: 9/1/2016		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 GORMAN ST, MOOSUP			89				

Towns Served: PLAINFIELD

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	<spaces> ()	Minimum: 0.1 MG/L	2
Start Date: 9/1/2016		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		BLDG1-001A	APT 1A KITCHEN	A	Y	2		
		BLDG1-001B	APT 1B KITCHEN	A	Y	2		
		BLDG1-001C	APT 1C KITCHEN	A	Y	2		
		BLDG1-001D	APT 1D KITCHEN	A	Y	2		
		BLDG1-001E	APT 1E KITCHEN	A	Y	2		
		BLDG1-001F	APT 1F KITCHEN	A	Y	2		
		BLDG1-001G	APT 1G KITCHEN	A	Y	2		
		BLDG1-001H	APT 1H KITCHEN	A	Y	2		
		BLDG1-001I	APT 1I KITCHEN	A	Y	2		
		BLDG1-001J	APT 1J KITCHEN	A	Y	2		
		BLDG10-COMM	BUILDING 10 KITCHEN	A	Y	2	Y	
		BLDG2-002A	APT 2A KITCHEN	A	Y	2		
		BLDG2-002B	APT 2B KITCHEN	A	Y	2		
		BLDG2-002C	APT 2C KITCHEN	A	Y	2		
		BLDG2-002D	APT 2D KITCHEN	A	Y	2		
		BLDG2-002E	APT 2E KITCHEN	A	Y	2		
		BLDG2-002F	APT 2F KITCHEN	A	Y	2		
		BLDG2-002G	APT 2G KITCHEN	A	Y	2		
		BLDG2-002H	APT 2H KITCHEN	A	Y	2		
		BLDG2-002I	APT 2I KITCHEN	A	Y	2		
		BLDG2-002J	APT 2J KITCHEN	A	Y	2		
		BLDG3-003A	APT 3A KITCHEN	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 GORMAN ST, MOOSUP			89				

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		BLDG3-003B	APT 3B KITCHEN	A	Y	2		
		BLDG3-003C	APT 3C KITCHEN	A	Y	2		
		BLDG3-003D	APT 3D KITCHEN	A	Y	2		
		BLDG3-003E	APT 3E KITCHEN	A	Y	2		
		BLDG3-003F	APT 3F KITCHEN	A	Y	2		
		BLDG3-003G	APT 3G KITCHEN	A	Y	2		
		BLDG3-003H	APT 3H KITCHEN	A	Y	2		
		BLDG3-003I	APT 3I KITCHEN	A	Y	2		
		BLDG3-003J	APT 3J KITCHEN	A	Y	2		
		BLDG4-004A	APT 4A KITCHEN	A	Y	2		
		BLDG4-004B	APT 4B KITCHEN	A	Y	2		
		BLDG4-004C	APT 4C KITCHEN	A	Y	2		
		BLDG4-004D	APT 4D KITCHEN	A	Y	2		
		BLDG4-004E	APT 4E KITCHEN	A	Y	2		
		BLDG4-004F	APT 4F KITCHEN	A	Y	2		
		BLDG4-004G	APT 4G KITCHEN	A	Y	2		
		BLDG4-004H	APT 4H KITCHEN	A	Y	2		
		BLDG4-004I	APT 4I KITCHEN	A	Y	2		
		BLDG4-004J	APT 4J KITCHEN	A	Y	2		
		BLDG5-005A	APT 5A KITCHEN	A	Y	2		
		BLDG5-005B	APT 5B KITCHEN	A	Y	2		
		BLDG5-005C	APT 5C KITCHEN	A	Y	2		
		BLDG5-005D	APT 5D KITCHEN	A	Y	2		
		BLDG5-005E	APT 5E KITCHEN	A	Y	2		
		BLDG5-005F	APT 5F KITCHEN	A	Y	2		
		BLDG5-005G	APT 5G KITCHEN	A	Y	2		
		BLDG5-005H	APT 5H KITCHEN	A	Y	2		
		BLDG5-005I	APT 5I KITCHEN	A	Y	2		
		BLDG5-005J	UNIT 5 ROOM 5J	A	Y			
		BLDG6-006A	APT 6A KITCHEN	A	Y	2		
		BLDG6-006B	APT 6B KITCHEN	A	Y	2		
		BLDG6-006C	APT 6C KITCHEN	A	Y	2		
		BLDG6-006D	APT 6D KITCHEN	A	Y	2		
		BLDG6-006E	APT 6E KITCHEN	A	Y	2		
		BLDG6-006F	APT 6F KITCHEN	A	Y	3		
		BLDG6-006G	APT 6G KITCHEN	A	Y	2		
		BLDG6-006H	APT 6H KITCHEN	A	Y	2		
		BLDG6-006I	APT 6I KITCHEN	A	Y	2		
		BLDG6-006J	APT 6J KITCHEN	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 GORMAN ST, MOOSUP			89				

Towns Served: PLAINFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		BLDG7-007A	APT 7A KITCHEN	A	Y	2		
		BLDG7-007B	APT 7B KITCHEN	A	Y	2		
		BLDG7-007C	APT 7C KITCHEN	A	Y	2		
		BLDG7-007D	APT 7D KITCHEN	A	Y	2		
		BLDG7-007E	APT 7E KITCHEN	A	Y	2		
		BLDG7-007F	APT 7F KITCHEN	A	Y	2		
		BLDG7-007G	APT 7G KITCHEN	A	Y	2		
		BLDG7-007H	APT 7H KITCHEN	A	Y	2		
		BLDG7-007I	APT 7I KITCHEN	A	Y	2		
		BLDG7-007J	APT 7J KITCHEN	A	Y	2		
		BLDG8-008A	APT 8A KITCHEN	A	Y	2		
		BLDG8-008B	APT 8B KITCHEN	A	Y	2		
		BLDG8-008C	APT 8C KITCHEN	A	Y	2		
		BLDG8-008D	APT 8D KITCHEN	A	Y	2		
		BLDG8-008E	APT 8E KITCHEN	A	Y	2		
		BLDG8-008F	APT 8F KITCHEN	A	Y	2		
		BLDG8-008G	APT 8G KITCHEN	A	Y	2		
		BLDG8-008H	APT 8H KITCHEN	A	Y	2		
		BLDG8-008I	APT 8I KITCHEN	A	Y	2		
		BLDG8-008J	APT 8J KITCHEN	A	Y	2		
		BLDG9-009A	APT 9A KITCHEN	A	Y	2		
		BLDG9-009B	APT 9B KITCHEN	A	Y	2		
		BLDG9-009C	APT 9C KITCHEN	A	Y	2		
		BLDG9-009D	APT 9D KITCHEN	A	Y	2		
		BLDG9-009E	APT 9E KITCHEN	A	Y	2		
		BLDG9-009F	APT 9F KITCHEN	A	Y	2		
		BLDG9-009G	APT 9G KITCHEN	A	Y	2		
		BLDG9-009H	APT 9H KITCHEN	A	Y	2		
		BLDG9-009I	APT 9I KITCHEN	A	Y	2		
		BLDG9-009J	APT 9J KITCHEN	A	Y	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1102	WELL 1	2	WELL 1	A				
1106	WELL 2	2	WELL 2	A				
50602	ATMOSPHERIC STORAGE							
60286	TREATMENT PLANT							
61656	VFD TRANSFER PUMPS							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1090221	MOOSUP GARDEN APARTMENTS	C	270	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 GORMAN ST, MOOSUP			89				
Towns Served: PLAINFIELD							

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 60286)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2024
HARKINS, STUART A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2025

Contact Information

Name		Organization			Job Title	
Mr. Arthur Greenblatt		Vesta Corporation			President 175 Power F	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
175 Power Forest Drive				Weatogue	CT	06089
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-916-0258					arthur@vestacorp.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1094201	JUMBO APARTMENTS	C	35	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
164-168 PROSPECT ST			11				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		

Total Coliform (3100) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) **5 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/27	6/1-9/30	

Physical Parameters (PPS) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1094201	JUMBO APARTMENTS	C	35	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
164-168 PROSPECT ST			11				
Towns Served: PLAINFIELD							

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040) **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Nitrite (1041) **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) **1 routine (RT) per six years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/20 - 12/31/25		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	1/12/2022	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION EXEMPTION	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		JA001	PUMP HOUSE	A				
		JA002	182 PROSPECT	A		3		
		JA003	164 PROSPECT	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1094201	JUMBO APARTMENTS	C	35	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
164-168 PROSPECT ST			11				
Towns Served: PLAINFIELD							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		JA004	166 PROSPECT	A		3		
		JA005	168 PROSPECT	A		3		
		JA006	170 PROSPECT	A		3		
		JA007	172 PROSPECT	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1104	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2024
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2024

Contact Information

Name		Organization			Job Title	
Ms. Briana Paul		Prospect Rentals, LLC				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
123 Elvira Heights				Putnam	CT	06260
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
			860-377-9487		jandbrentals@gmail.com	

Contact Role(s): Administrative Contact, Legal Contact, Owner

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099131	MOOSUP MANOR	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 SARA LANE			1				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete		
	12/1/23 - 12/31/23		Complete		
	1/1/24 - 1/31/24		Complete		
	2/1/24 - 2/29/24		Complete		
	3/1/24 - 3/31/24		Complete		
	4/1/24 - 4/30/24				
	5/1/24 - 5/31/24				
	6/1/24 - 6/30/24				
	7/1/24 - 7/31/24				
	8/1/24 - 8/31/24				
	9/1/24 - 9/30/24				
	10/1/24 - 10/31/24				
Lead And Copper (PBCU)		5 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete		
	1/1/24 - 12/31/24	6/1-9/30			
	1/1/25 - 12/31/25	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete		
	12/1/23 - 12/31/23		Complete		
	1/1/24 - 1/31/24		Complete		
	2/1/24 - 2/29/24		Complete		
	3/1/24 - 3/31/24		Complete		
	4/1/24 - 4/30/24				
	5/1/24 - 5/31/24				
	6/1/24 - 6/30/24				
	7/1/24 - 7/31/24				
	8/1/24 - 8/31/24				
	9/1/24 - 9/30/24				
	10/1/24 - 10/31/24				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099131	MOOSUP MANOR	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 SARA LANE			1				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/21 - 12/31/23		Complete
	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	6/26/2022	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	3/13/2024

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099131	MOOSUP MANOR	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 SARA LANE			1				

Towns Served: PLAINFIELD

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW020	REC ROOM	A	Y			
		MW020-12	APT 12	A	Y	2		
		MW020-13	APT 13	A	Y			
		MW020-15	APT 15	A	Y			
		MW020-16	APT 16	A	Y			
		MW020-17	APT 17	A	Y			
		MW020-18	APT 18	A	Y			
		MW020-19	APT 19	A	Y			
		MW020-20	APT 20	A	Y			
		MW020-21	APT 21	A	Y			
		MW020-22	APT 22	A	Y	2		
		MW020-23	APT 23	A	Y			
		MW020-24	APT 24	A	Y	2		
		MW020-3	APT 3	A	Y	2		
		MW020-4	APT 4	A	Y	2		
		MW020-5	APT 5	A	Y			
		MW020-7	APT 7	A	Y			
		MW020-8	APT 8	A	Y			
		MW020-REC	REC ROOM	A	Y			
		MW027-REC	REC ROOM	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1959	WELL 1	2	WELL 1	A				
51577	ATMOSPHERIC TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099131	MOOSUP MANOR	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 SARA LANE			1				

Towns Served: PLAINFIELD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2024

Contact Information

Name		Organization			Job Title		
Ms. Pauline Galbreath		Rural Consulting & Management			Property Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
Property Manager		P.O. Box 499			Dayville	CT	06241-0499
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-564-0838		860-564-6581			rcm550@aol.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Name		Organization			Job Title		
Moosup Manor Partnership							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
PO Box 499					Dayville	CT	06241
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		

Contact Role(s): **Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099141	ARNIO DRIVE LLC	C	33	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
2-10 ARNIO DR			11				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

Total Coliform (3100) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete

Lead And Copper (PBCU) 5 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Physical Parameters (PPS) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per six years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/24		
	1/1/25 - 12/31/30		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099141	ARNIO DRIVE LLC	C	33	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
2-10 ARNIO DR			11				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION EXEMPTION	3/1/2029	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>	
00600	DISTRIBUTION SYSTEM	10 ARNIO	KITCHEN FAUCET	A	Y	N	Y		
		194 LAKE	KITCHEN FAUCET	A	Y	N	Y		
		196 LAKE	KITCHEN FAUCET	A	Y	N	Y		
		198 LAKE	KITCHEN FAUCET	A	Y	N	Y		
		2 ARNIO	KITCHEN FAUCET	A	Y	N	Y		
		200 LAKE	KITCHEN FAUCET	A	Y	N	Y		
		202 LAKE	KITCHEN FAUCET	A	Y	N	Y		
		204 LAKE	KITCHEN FAUCET	A	Y	N	Y		
		4	DISTRIBUTION	A					
		4 ARNIO	KITCHEN FAUCET	A	Y	N	Y		
		6 ARNIO	KITCHEN FAUCET	A	Y	N	Y		
		8 ARNIO	KITCHEN FAUCET	A	Y	N	Y		
	DOWNSTREAM	WITHIN 5 SERVICE CON	A						
	UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A					
53882	WELL 1	2	WELL 1	A					

Contact Information

Name	Organization	Job Title		
Arnio Drive LLC				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
550 South Street		Shrewsbury	MA	01545

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1099141	ARNIO DRIVE LLC	C	33	P	GW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
2-10 ARNIO DR		11				

Towns Served: PLAINFIELD

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-326-9100					

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title
Miss Suba Durairajan	Arnio Drive LLC	Manager

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
550 South Street		Shewsbury	MA	01545

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
773-630-9115				773-630-9115	suba.arun@gmail.com

Contact Role(s): **Administrative Contact**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099181	MOOSUP POND TERRACE, LLC	C	46	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MOOSUP POND RD			3				

Towns Served: PLAINFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094) 1 routine (RT) per nine years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

Total Coliform (3100) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Lead And Copper (PBCU) 5 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/25	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099181	MOOSUP POND TERRACE, LLC	C	46	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MOOSUP POND RD			3				
Towns Served: PLAINFIELD							

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2021	
RESPOND TO SANITARY SURVEY	3/6/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	3/13/2024
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	267LB	267LB	A	Y	2		
		267LC	267LC	A	Y	2		
		267LPD	267LPD	A	Y	2		
		4	DISTRIBUTION SYSTEM	A				
		523MPC	523MPC	A	Y	2		
		523MPD	523MPD	A	Y	2	Y	
		524 CC	APT 524 CC	A	Y			
		524 D	APT 524 D	A	Y			
		531 B	APT 531 B	A	Y			
		531 C	APT 531 C	A	Y			
		531 D	APT 531 D	A	Y			
		531MPA2	531MPA2	A	Y	2		
		531MPB2	531MPB2	A	Y	2		
		531MPC2	531MPC2	A	Y	2		
		531MPD2	531MPD2	A	Y	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MPEP	ENTRY POINT	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1099181	MOOSUP POND TERRACE, LLC	C	46	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MOOSUP POND RD		3					
Towns Served: PLAINFIELD							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
57833	WELL 1	2	WELL 1	A				
57835	WELL 2	2	WELL 2	A				
57839	WELL 2 TREATMENT PLANT							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NAPIERATA, KYLE	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2024
LAFRAMBOISE, PAUL F.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2024

Contact Information

Name		Organization			Job Title	
Mr. Michael Baldi Jr.		Baldi, LLC			Member of LLC	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
349 Mack Road				Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-603-2689					mike.baldi@baldivaluation.com	

Contact Role(s): Administrative Contact

Name		Organization			Job Title	
Baldi, LLC						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
349 Mack Road				Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	

Contact Role(s): Legal Contact, Owner

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule