

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1490011</b>	<b>HOPKINS SUPPLY</b>	NTNC	77	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
HOPKINS RD						9	

Towns Served: WARREN

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Asbestos (1094) 1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

**Total Coliform (3100) 2 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

**Lead And Copper (PBCU) 5 routine (RT) per six months**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

**Physical Parameters (PPS) 2 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

**Water Quality Parameters (WQPD) 2 routine (RT) per six months**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1490011</b>	<b>HOPKINS SUPPLY</b>	NTNC	77	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
HOPKINS RD						9	

Towns Served: WARREN

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
<b>Lead And Copper (PBCU)</b>	<b>1 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 6/30/24		Complete
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Water Quality Parameters - Basic (WQP1)</b>	<b>2 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/23 - 12/31/23		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
<b>Start Date:</b> 9/1/2005	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1490011</b>	<b>HOPKINS SUPPLY</b>	NTNC	77	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
HOPKINS RD						9	

Towns Served: WARREN

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
RESPOND TO SANITARY SURVEY	11/23/2022	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2022	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2023	
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	3/1/2024	2/26/2024
LEAD PUBLIC EDUCATION REPORT TO STATE	3/10/2024	2/26/2024
SWTS 1: PWS TO RECOMMEND SOWT	6/16/2024	
CCTS 1: PWS TO RECOMMEND OCCT	6/30/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	12/28/2024	
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	12/31/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CCTS 5: PWS OCCT INSTALLATION	12/31/2025	

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Lead and Copper M&R Violation	10/1/22 - 6/14/23	3	11/23/2023		12/3/2023	
Physical Parameters M&R Violation	1/1/23 - 3/31/23	3	6/7/2024		6/17/2024	
Total Coliform M&R Violation	1/1/23 - 3/31/23	3	6/7/2024		6/17/2024	
Pesticides, Herbicides and PCBs-Phase V M&R Violation	1/1/20 - 12/31/22	3	6/7/2024		6/17/2024	
Pesticides, Herbicides and PCBs-Phase II M&R Violation	1/1/20 - 12/31/22	3	6/7/2024		6/17/2024	
Total Coliform M&R Violation	10/1/22 - 12/31/22	3	6/7/2024		6/17/2024	
Physical Parameters M&R Violation	10/1/22 - 12/31/22	3	6/7/2024		6/17/2024	
Physical Parameters M&R Violation	7/1/22 - 9/30/22	3	6/7/2024		6/17/2024	
Total Coliform M&R Violation	7/1/22 - 7/31/22	3	6/7/2024		6/17/2024	
Water Quality Parameters - Basic M&R Violation	7/1/23 - 12/31/23	3	2/15/2025		2/25/2025	
Water Quality Parameters M&R Violation	7/1/23 - 12/31/23	3	2/15/2025		2/25/2025	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		HS-04	AFTER STORAGE TANK	A				
		HS-05	WINERY TASTING SINK	A	Y	1		
		HS-06	INN TASTING SINK	A	Y	1		
		HS-07	HOPKINS KITCHEN SINK	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1490011</b>	<b>HOPKINS SUPPLY</b>	NTNC	77	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
HOPKINS RD						9	
Towns Served: WARREN							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		HS-08	BORDEN KITCHEN SINK	A		1		
		HS-09	KING KITCHEN SINK	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10643	WELL	2	WELL	A				
45067	TREATMENT PLANT							
50420	ATMOSPHERIC STORAGE							

## Certified Operator Information

**Water System Facility:** TREATMENT PLANT (WSF ID: 45067)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FOSSLAND, TORRENCE J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

## Contact Information

Name		Organization			Job Title		
Ms. Beth P. Schober		Hopkins Inn			President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
22 Hopkins Road					New Preston	CT	06777
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-868-7295		860-868-7464		860-868-2506	bethschober@charter.net		
<b>Contact Role(s): Administrative Contact, Legal Contact</b>							
Name		Organization			Job Title		
Mr. William L. Hopkins		Hopkins Brothers LLC					
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
19 Hopkins Road					Warren	CT	06777
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-868-7954					WLHopkins@charter.net		
<b>Contact Role(s): Owner</b>							

- Please note the following:**
- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
  - If a Collection Period is specified, all water quality samples must be collected during the specified period.
  - Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1490102</b>	<b>WARREN ELEMENTARY SCHOOL</b>	NTNC	140	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 SACKETT HILL ROAD				2			
Towns Served: WARREN							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Asbestos (1094)** **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

**Total Coliform (3100)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

**Lead And Copper (PBCU)** **5 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	

**Physical Parameters (PPS)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

**Inorganic Chemicals (IOCS)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Nitrate And Nitrite (NOX)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

**Pesticides, Herbicides and PCBs - Phase II & V (SOCS)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Organic Chemicals (VOCS)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490102	WARREN ELEMENTARY SCHOOL	NTNC	140	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 SACKETT HILL ROAD				2			
Towns Served: WARREN							

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WARREN001	KITCHEN SINK 1	A	Y	2		
		WARREN002	KITCHEN SINK 2	A	Y	2		
		WARREN003	KITCHEN SINK 3	A	Y	2		
		WARREN004	GIRLS LAV AT KITCHEN	A	Y	2		
		WARREN005	BOYS LAV AT KITCHEN	A	Y	2		
		WARREN006	ROOM 29	A	Y	2		
		WARREN007	ROOM 25 NURSE	A	Y	2		
		WARREN008	GIRLS LAV NEAR GYM	A	Y	2		
		WARREN009	BOYS LAV NEAR GYM	A	Y	2		
		WARREN010	ART ROOM RM 10	A	Y	2		
		WARREN011	ROOM 13	A	Y	2		
		WARREN012	ROOM 15	A	Y	2		
		WARREN013	ROOM 14 SINK 1	A	Y	2		
		WARREN014	ROOM 14 SINK 2	A	Y	2		
		WARREN015	ROOM 12 SINK 1	A	Y	2		
		WARREN016	ROOM 12 SINK 2	A	Y	2		
		WARREN017	ROOM 17	A	Y	2		
		WARREN018	ROOM 19	A	Y	2		
		WARREN019	ROOM 16	A	Y	2		Y
		WARREN020	GIRLS LAVATORY	A	Y	2		Y
		WARREN021	BOYS LAVATORY	A	Y	2		Y
WARREN022	ROOM 39 LIBRARY	A	Y	2				
WARREN023	PUMP ROOM	A	Y	2				
00700	ENTRY POINT	3	ENTRY POINT	A				
		WARREN023	PUMP ROOM	A				
52442	WELL #2	2	WELL #2	A				
52444	WELL #3	2	WELL #3	A				
52446	ATMOSPHERIC STORAGE TANKS (4)							
52450	PUMP STATION							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1490102</b>	<b>WARREN ELEMENTARY SCHOOL</b>	NTNC	140	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 SACKETT HILL ROAD				2			
Towns Served: WARREN							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
54023	TREATMENT PLANT						

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 54023)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2025

## Contact Information

Name			Organization			Job Title		
<b>Town of Warren</b>								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
50 Cemetery Rd						Warren	CT	06754
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-868-7881		860-868-7746						

Contact Role(s): **Owner**

Name			Organization			Job Title		
<b>Mr. Leonard Fasano</b>			Regional School District			Maintenance Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
35 Wamogo Road						Litchfield	CT	06759
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-605-7897				860-605-7897	lfasano@rsd6.org			

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490024	WARREN CONGREGATIONAL CHURCH	NTNC	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
6 SACKETT HILL ROAD				1			

Towns Served: WARREN

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete		
	1/1/24 - 3/31/24		Complete		
	4/1/24 - 6/30/24				
	7/1/24 - 9/30/24				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete		
	1/1/24 - 12/31/24	6/1-9/30			
	1/1/25 - 12/31/25	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete		
	1/1/24 - 3/31/24		Complete		
	4/1/24 - 6/30/24				
	7/1/24 - 9/30/24				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete		
	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490024	WARREN CONGREGATIONAL CHURCH	NTNC	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
6 SACKETT HILL ROAD				1			
Towns Served: WARREN							

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WARREN001	MAIN KIT-HAND SINK	A	Y	2	Y	
		WARREN002	MAIN KIT-ISLAND SINK	A	Y	2	Y	
		WARREN003	CHURCH BATHROOM	A	Y	3	Y	
		WARREN004	PARSONAGE	A	Y	3	Y	
WARREN005	ACADEMY BLD	A	Y	3	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
48759	TREATMENT PLANT							
55081	WELL #1A	2	WELL #1A	A				

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 48759)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025
KILBOURN, JORDAN H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024

## Contact Information

Name			Organization			Job Title		
Mr. Carl Hetzel			Warren Congregational Church			Moderator		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
6 Sackett Hill Road						Warren	CT	06754
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-868-7106		860-868-1067		860-619-8009	carlpamh@yahoo.com			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1490024</b>	<b>WARREN CONGREGATIONAL CHURCH</b>	NTNC	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
6 SACKETT HILL ROAD				1			
Towns Served: WARREN							

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**